

**OHA - Drinking Water Program -Turbidity Monitoring Report Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Lane**  
 Month/Year: **Dec-25**

System Name: **Mapleton Water District** ID#: **41 00507** WTP : **WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.015	0.015	0.015	0.015	0.015	0.016	0.016
2	0.015	0.015	0.015	0.015	OFF	OFF	0.015
3	0.015	0.015	0.015	0.015	0.015	0.016	0.016
4	0.015	0.015	0.015	0.015	0.015	0.015	0.015
5	0.015	0.015	0.015	0.015	0.015	0.015	0.015
6	0.015	0.015	0.015	0.015	0.015	0.015	0.015
7	0.015	0.015	0.015	0.015	0.016	0.016	0.016
8	0.016	0.015	0.015	0.015	0.016	0.015	0.016
9	0.015	0.015	0.015	0.015	0.015	0.015	0.015
10	0.015	0.015	0.015	0.015	0.015	0.015	0.015
11	0.015	OFF	OFF	OFF	0.015	0.016	0.016
12	0.016	0.016	0.016	0.015	0.015	0.015	0.016
13	0.015	0.015	0.015	0.015	0.015	0.016	0.016
14	0.016	0.016	0.016	0.016	0.015	0.017	0.017
15	0.016	0.016	0.016	0.016	0.016	0.016	0.016
16	0.016	0.016	0.016	0.015	0.015	0.015	0.016
17	0.015	0.015	0.015	0.015	0.015	0.015	0.015
18	OFF	OFF	OFF	0.015	0.015	0.015	0.015
19	0.015	0.015	0.015	0.015	0.015	0.015	0.015
20	0.015	0.015	0.015	0.015	0.015	0.015	0.015
21	0.015	0.015	0.015	0.015	0.016	0.016	0.016
22	0.020	0.015	0.015	0.015	0.016	0.015	0.020
23	0.015	0.015	0.015	0.015	0.015	0.016	0.016
24	0.016	0.016	0.016	0.016	OFF	OFF	0.016
25	OFF	OFF	OFF	OFF	OFF	0.016	0.016
26	0.016	OFF	0.015	0.016	0.015	0.015	0.016
27	0.016	0.015	0.015	0.015	0.015	OFF	0.016
28	OFF	OFF	OFF	0.015	0.015	0.015	0.015
29	0.015	0.016	0.016	0.015	0.015	0.015	0.016
30	0.015	0.015	0.015	0.015	0.015	0.015	0.015
31	0.015	0.015	0.015	0.015	0.015	0.015	0.015

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <b>✓ Yes / No</b>	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? <b>✓ Yes / No</b>	<b>✓ Yes / No</b>	<b>✓ Yes / No</b>

<b>Notes:</b>	<b>PRINTED NAME: David Terrusa</b>	
	<b>SIGNATURE: /S/ David Terrusa</b>	<b>DATE: 9 Jan 25</b>
	<b>PHONE #: 541-253-7556</b>	<b>CERT #: 3960</b>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**WTP - : WTP-D**

**System Name: Mapleton Water District ID#: 41 00507**

**Month/Year: Dec-25**

**Disinfection  
Giardia Log  
Inactiv:**

**0.5**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT C x T	Temp	pH	Required CT	CT Met? <sup>3</sup> Yes or No	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	formula	[° C]		formula	formula	[GPM]
1	9:00 AM	2.05	70	143.5	6.7	7.8	36.1	Yes	125
2	9:00AM	1.94	70	135.8	6.8	7.8	35.4	Yes	125
3	9:00AM	2.04	70	142.8	6.0	7.8	37.9	Yes	125
4	9:00AM	1.9	70	133.0	5.8	7.8	37.8	Yes	125
5	9:00AM	1.68	70	117.6	6.3	7.8	35.6	Yes	125
6	9:00AM	1.56	70	109.2	6.7	7.7	32.9	Yes	125
7	9:00AM	1.12	70	78.4	8.0	7.7	28.6	Yes	124.9
8	9:00AM	1.42	70	99.4	8.7	7.8	29.3	Yes	125
9	9:00AM	1.39	70	97.3	7.9	7.8	30.8	Yes	124.9
10	9:00AM	1.49	70	104.3	7.0	7.8	33.2	Yes	125
11	9:00AM	1.57	70	109.9	7.7	7.7	30.8	Yes	125
12	9:00AM	1.44	70	100.8	8.0	7.8	30.8	Yes	125
13	9:00AM	1.17	70	81.9	8.5	7.9	29.9	Yes	125
14	9:00AM	1.2	70	84.0	8.8	7.7	27.4	Yes	125
15	9:00AM	1.44	70	100.8	8.4	7.8	30.0	Yes	125
16	9:00AM	1.37	70	95.9	8.9	7.7	27.7	Yes	125
17	9:00AM	0.99	70	69.3	8.9	7.6	25.6	Yes	OFF
18	9:00AM	1.11	70	77.7	10.0	7.6	24.1	Yes	125
19	9:00AM	1.3	70	91.0	10.5	7.7	24.7	Yes	125
20	9:00AM	1.54	70	107.8	10.3	7.6	24.8	Yes	125
21	9:00AM	1.36	70	95.2	9.7	7.8	27.2	Yes	125
22	9:00AM	1.49	70	104.3	9.6	7.6	25.9	Yes	125
23	9:00AM	1.55	70	108.5	9.6	7.7	27.0	Yes	125
24	9:00AM	1.58	70	110.6	9.7	7.7	26.9	Yes	125
25	9:00AM	1.08	70	75.6	9.2	7.7	26.3	Yes	125
26	9:00AM	1.62	70	113.4	9.5	7.6	26.4	Yes	112.4
27	9:00AM	1.6	70	112.0	9.6	7.7	27.1	Yes	114.7
28	9:00AM	1.79	70	125.3	10.0	7.7	27.0	Yes	113.8
29	9:00AM	1.61	70	112.7	9.6	7.7	27.2	Yes	114.4
30	9:00AM	1.86	70	130.2	9.2	7.7	28.7	Yes	114
31	9:00AM	1.34	70	93.8	9.8	7.7	26.0	Yes	124.8

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013