

OREGON HEALTH DIVISION DRINKING WATER SECTION

TRIBDITY MONITORING REPORT FORM

SYSTEM NAME: CITY OF MAPLETON

ID# 4100507

Jun-21

DAY	12:00 am	4:00 AM	8:00 am	NOON	4:00 pm	8:00 pm	Highest Reading	Peak Hourly Flow (GPM)
	NTU	NTU	NTU	NTU	NTU	NTU	NTU	
1	0.03	0.03	0.03	0.03	0.03	0.04	0.04	140
2	0.03	0.03	0.03	OFF	OFF	OFF	0.03	140
3	OFF	OFF	OFF	OFF	0.03	0.03	0.03	140
4	0.03	0.03	0.03	OFF	OFF	OFF	0.03	140
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	0.03	0.03	0.03	0.03	140
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03	140
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	0.03	0.03	0.03	0.03	140
11	0.03	0.03	0.03	0.03	OFF	OFF	0.03	140
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	0.03	0.04	0.03	0.04	140
15	0.03	0.03	0.03	0.03	OFF	OFF	0.03	140
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	OFF	OFF	OFF	0.03	0.03	0.03	0.03	140
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03	140
19	0.03	0.03	0.03	0.03	OFF	OFF	0.03	140
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	0.03	0.03	0.03	0.03	0.03	140
22	0.03	0.03	0.04	0.03	0.03	0.03	0.04	140
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	0.03	0.03	0.03	0.03	0.03	140
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03	140
26	0.03	0.03	0.03	0.03	OFF	OFF	0.03	140
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	0.03	OFF	0.03	140
29	OFF	OFF	OFF	OFF	0.03	0.03	0.03	140
30	0.03	0.03	0.03	0.03	OFF	OFF	0.03	140
31	#REF!	#REF!	#REF!	#REF!	#REF!	#REF!	#REF!	#REF!

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?	yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Remarks: Revised June Report

Printed Darrel Lockard

 SIGNATURE: *Darrel Lockard*

7/19/2021

Phone# 541-222-9997

CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

