

OREGON HEALTH DIVISION DRINKING WATER SECTION

TRIBDITY MONITORING REPORT FORM

SYSTEM NAME: CITY OF MAPLETON

ID# 4100507

Jul-21

DAY	12:00 am	4:00 AM	8:00 am	NOON	4:00 pm	8:00 pm	Highest Reading	Peak Hourly Flow (GPM)
	NTU	NTU	NTU	NTU	NTU	NTU	NTU	
1	OFF	OFF	OFF	OFF	0.03	0.03	0.03	140
2	0.03	0.03	0.04	0.03	OFF	OFF	0.04	140
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	140
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	140
5	OFF	OFF	OFF	0.04	0.03	0.03	0.04	140
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03	140
7	0.03	0.03	OFF	OFF	OFF	OFF	0.03	140
8	OFF	OFF	OFF	OFF	0.03	0.03	0.03	140
9	0.03	0.04	0.03	0.03	0.03	0.03	0.04	140
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	140
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	140
12	OFF	OFF	OFF	0.03	0.04	0.04	0.04	140
13	0.03	0.03	0.03	0.04	0.03	0.03	0.04	140
14	0.03	0.03	0.03	OFF	OFF	OFF	0.03	140
15	OFF	OFF	OFF	OFF	0.03	0.03	0.03	140
16	0.03	0.03	0.03	OFF	OFF	OFF	0.03	140
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF	140
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	140
19	OFF	OFF	OFF	0.03	0.04	0.03	0.04	140
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03	140
21	0.03	0.03	0.03	OFF	OFF	OFF	0.03	140
22	OFF	OFF	OFF	OFF	0.03	0.03	0.03	140
23	0.03	0.04	0.03	0.03	OFF	OFF	0.04	140
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	140
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	140
26	OFF	OFF	OFF	0.05	0.03	0.03	0.05	140
27	0.04	0.03	0.03	0.03	0.03	0.03	0.04	140
28	0.03	0.04	0.03	0.03	OFF	OFF	0.04	140
29	OFF	OFF	OFF	0.03	0.03	0.03	0.03	140
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03	140

		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:	Printed Darrel Lockard SIGNATURE: <i>Darrel Lockard</i> 8/9/21 Phone# 541-222-9997 CERT# 2853
--------	--

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

