

OREGON HEALTH DIVISION DRINKING WATER SECTION

TRIBDITY MONITORING REPORT FORM

SYSTEM NAME: CITY OF MAPLETON

ID# 4100507

Sep-21

DAY	12:00 am	4:00 AM	8:00 am	NOON	4:00 pm	8:00 pm	Highest Reading	Peak Hourly Flow (GPM)
	NTU	NTU	NTU	NTU	NTU	NTU	NTU	
1	OFF	OFF	OFF	0.04	0.04	0.04	0.04	140
2	0.04	0.04	0.04	0.04	OFF	OFF	0.04	140
3	OFF	OFF	OFF	0.04	0.04	0.04	0.04	140
4	0.04	0.04	0.04	0.04	0.04	0.04	0.04	140
5	0.04	0.04	0.04	0.04	0.04	0.04	0.04	140
6	0.04	0.04	0.04	0.04	0.04	0.04	0.04	140
7	0.04	0.04	0.04	0.04	0.04	0.07	0.07	140
8	0.04	0.04	0.04	0.05	0.07	0.05	0.07	140
9	0.07	0.05	0.05	0.05	OFF	OFF	0.07	140
10	OFF	OFF	OFF	0.04	0.04	0.05	0.05	140
11	0.04	0.04	0.04	0.04	0.04	0.04	0.04	140
12	0.04	0.04	0.04	0.04	0.04	0.04	0.04	140
13	0.05	0.05	0.05	0.05	0.05	0.05	0.05	140
14	0.05	0.05	0.05	OFF	0.05	0.05	0.05	140
15	0.05	0.06	0.05	OFF	0.05	0.05	0.06	140
16	0.05	0.05	0.05	OFF	OFF	OFF	0.05	140
17	OFF	OFF	OFF	0.04	0.04	0.04	0.04	140
18	0.05	0.05	0.05	OFF	OFF	0.05	0.05	140
19	OFF	OFF	0.05	0.05	0.05	0.05	0.05	140
20	0.05	0.06	0.05	OFF	0.1	0.05	0.06	139
21	0.05	0.05	0.05	0.05	0.01	0.05	0.05	140
22	0.05	0.05	OFF	0.05	0.05	0.05	0.05	140
23	0.05	0.05	0.05	0.05	0.05	0.05	0.05	140
24	0.05	0.05	0.05	0.05	0.05	0.05	0.05	139
25	0.05	0.05	0.05	0.05	0.05	0.05	0.05	138
26	0.05	0.05	0.05	0.05	0.05	0.05	0.05	138
27	0.06	0.06	0.06	0.06	0.06	0.06	0.06	139
28	0.06	0.06	0.06	0.06	0.06	0.06	0.06	139
29	0.06	0.06	0.06	0.06	0.06	0.06	0.06	139
30	0.06	0.06	0.06	0.06	0.06	0.06	0.06	140
31								

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings \leq 0.3 NTU?	yes	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes: Updated form required CT tables are updated from last report, Inactivation log value changed from 1.0 to 0.5, Required CT table filled in

Printed Darrel Lockard	
SIGNATURE:	10/29/21
Phone# 541- 222-9997	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Efl. (333-061-0040(1)(d)(B&C))

