

OREGON HEALTH DIVISION DRINKING WATER SECTION

TRIBDITY MONITORING REPORT FORM

SYSTEM NAME: CITY OF MAPLETON

ID# 4100507

Dec-21

DAY	12:00 am	4:00 AM	8:00 am	NOON	4:00 pm	8:00 pm	Highest Reading	Peak Hourly
	NTU	NTU	NTU	NTU	NTU	NTU	NTU	Flow (GPM)
1	0.10	0.08	0.10	0.08	0.08	0.08	0.10	119
2	0.08	0.08	0.08	0.08	0.08	0.08	0.08	136
3	0.08	0.08	0.06	0.06	0.06	0.06	0.08	127
4	0.06	0.10	0.08	0.08	0.08	0.08	0.10	125
5	0.10	0.10	0.06	0.08	0.06	0.06	0.10	124
6	0.06	0.06	0.06	0.08	0.06	0.06	0.08	112
7	0.06	0.06	0.06	0.06	0.06	0.06	0.06	115
8	0.10	0.06	0.06	0.06	0.06	0.06	0.10	116
9	0.10	0.06	OFF	OFF	0.06	0.06	0.10	113
10	0.10	0.10	0.03	0.03	0.06	OFF	0.10	113
11	OFF	OFF	OFF	0.06	0.06	OFF	0.06	114
12	0.03	0.08	0.03	0.04	0.05	0.03	0.05	116
13	0.03	0.07	0.03	0.03	0.03	0.03	0.07	125
14	0.03	0.03	0.03	0.03	OFF	0.03	0.03	124
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03	124
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03	124
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03	122
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03	123
19	0.03	0.03	0.03	0.03	0.03	0.04	0.04	118
20	0.05	0.06	0.06	0.07	0.03	0.02	0.07	116
21	0.03	0.03	OFF	0.03	0.03	0.03	0.03	113
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03	106
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03	108
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03	105
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03	127
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03	105
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03	104
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03	104
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03	102
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03	104
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03	98

Monthly Summary (Answer Yes or No)

 95% of 4-hour turbidity readings \leq 0.15 NTU?

 yes

 All 4-hour turbidity readings \leq 1 NTU?

 Yes

 All turbidity readings < IFE² triggers

 Yes

 CT's met everyday?
(see back)

 Yes

 All Cl₂ residual at entry point
 \geq 0.2 mg/l?

 Yes

Notes: Amended data sheet to a new onsite trainee taking over daily data collection working long hours. Filtrate NTU decimal recorded in the wrong place starting 12/17-12/31. This data sheet reflects additional training. Data recorded from photos of data collection events.

Printed Darrel Lockard

SIGNATURE:



01/14/22

Phone# 541- 222-9997

CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

