

OREGON HEALTH DIVISION DRINKING WATER SECTION

TRIBDITY MONITORING REPORT FORM

Log removal

SYSTEM NAME: **CITY OF MAPLETON**

ID# **4100507**

Feb-22

0.5

DAY	12:00 am	4:00 AM	8:00 am	NOON	4:00 pm	8:00 pm	Highest Reading	Peak Hourly Flow (GPM)
	NTU	NTU	NTU	NTU	NTU	NTU	NTU	
1	0.031	0.031	0.031	0.031	0.031	0.031	0.031	140
2	0.031	0.031	0.032	0.031	0.031	0.031	0.032	140
3	0.031	0.031	0.031	0.031	0.031	0.031	0.031	139
4	0.031	0.031	0.031	0.031	0.031	0.031	0.031	139
5	0.031	0.031	0.031	0.031	0.031	0.031	0.031	139
6	0.031	0.031	0.031	0.032	0.031	0.031	0.031	139
7	0.032	0.032	0.032	0.032	0.032	0.032	0.032	138
8	0.032	0.032	0.032	0.032	0.032	0.032	0.032	139
9	0.032	0.032	0.032	0.032	0.032	0.033	0.033	140
10	0.033	0.033	0.033	0.033	0.033	0.033	0.033	139
11	0.033	0.033	0.033	0.033	0.033	0.034	0.034	140
12	0.034	0.034	0.034	0.034	0.034	0.034	0.034	139
13	0.034	0.034	0.034	0.034	0.034	0.034	0.034	139
14	0.034	0.034	0.034	0.034	0.034	0.034	0.034	139
15	0.034	0.034	0.034	0.034	0.034	0.034	0.034	140
16	0.035	0.035	0.034	0.035	0.035	0.035	0.035	138
17	0.035	0.035	0.035	0.035	OFF	OFF	0.035	139
18	OFF	OFF	OFF	OFF	0.035	0.035	0.035	139
19	0.035	0.035	0.035	0.034	0.034	0.034	0.035	140
20	0.035	0.035	0.035	0.035	0.035	0.035	0.035	139
21	0.035	0.035	0.035	0.035	0.035	0.035	0.035	139
22	0.035	0.035	0.035	0.035	0.035	0.035	0.035	139
23	0.035	0.035	0.035	0.035	0.035	0.035	0.035	140
24	0.035	0.035	0.035	0.035	0.035	0.035	0.035	139
25	0.035	0.035	0.035	0.035	0.035	0.035	0.035	141
26	0.035	0.035	0.035	0.035	0.035	OFF	0.035	139
27	0.035	0.035	0.035	0.035	0.035	0.035	0.035	139
28	0.036	0.036	0.036	0.036	0.037	0.037	0.037	139
29								
30								
31								

<p>95% of 4-hour turbidity readings \leq 0.3 NTU? yes</p> <p>All 4-hour turbidity readings \leq 1 NTU? Yes</p> <p>All turbidity readings $<$ IFE² triggers Yes</p>	<p>Monthly Summary (Answer Yes or No)</p> <table style="width: 100%;"> <tr> <td style="width: 50%;"> CT's met everyday? (see back) Yes </td> <td style="width: 50%;"> All Cl2 residual at entry point \geq 0.2 mg/l? Yes </td> </tr> </table>	CT's met everyday? (see back) Yes	All Cl2 residual at entry point \geq 0.2 mg/l? Yes
CT's met everyday? (see back) Yes	All Cl2 residual at entry point \geq 0.2 mg/l? Yes		

<p>Notes:</p>	<p>Printed Darrel Lockard</p> <table style="width: 100%;"> <tr> <td style="width: 80%;">SIGNATURE: <i>Darrel Lockard</i></td> <td style="width: 20%; text-align: right;">03/08/22</td> </tr> <tr> <td>Phone# 541- 222-9997</td> <td style="text-align: right;">CERT# 2853</td> </tr> </table>	SIGNATURE: <i>Darrel Lockard</i>	03/08/22	Phone# 541- 222-9997	CERT# 2853
SIGNATURE: <i>Darrel Lockard</i>	03/08/22				
Phone# 541- 222-9997	CERT# 2853				

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

