

OREGON HEALTH DIVISION DRINKING WATER SECTION								Log removal
TRIBIDITY MONITORING REPORT FORM							2022	0.5
SYSTEM NAME: CITY OF MAPLETON				ID# 4100507				
DAY	12:00 am	4:00 AM	8:00 am	NOON	4:00 pm	8:00 pm	Highest Reading	Peak Hourly Flow (GPM)
	NTU	NTU	NTU	NTU	NTU	NTU	NTU	
1	0.042	0.042	0.042	0.042	0.042	0.042	0.042	140
2	0.042	0.042	0.042	0.043	0.043	0.043	0.043	140
3	0.043	0.043	0.043	0.043	0.043	0.043	0.043	138
4	0.044	0.044	0.044	0.044	OFF	OFF	0.044	139
5	OFF	OFF	OFF	0.050	0.043	0.043	0.050	136
6	0.043	0.043	0.043	0.043	0.043	0.043	0.043	140
7	0.043	0.043	0.043	0.043	0.043	0.044	0.044	135
8	0.044	0.044	0.044	0.044	0.044	0.044	0.044	141
9	0.044	0.044	0.044	0.044	0.044	0.044	0.044	140
10	0.044	0.044	0.044	0.044	0.044	0.044	0.044	139
11	0.044	0.044	0.044	OFF	0.044	0.044	0.044	139
12	0.044	0.044	0.044	0.044	0.044	0.044	0.044	140
13	0.044	0.044	0.044	0.045	0.045	0.045	0.045	140
14	0.045	0.045	0.045	0.045	0.045	0.045	0.045	139
15	0.045	0.045	0.045	0.045	0.045	0.045	0.045	140
16	0.045	0.045	0.045	0.045	0.045	0.045	0.045	137
17	0.045	0.046	0.046	0.046	0.046	0.046	0.046	140
18	0.046	0.046	0.046	0.046	0.046	0.046	0.046	140
19	0.046	0.046	0.046	OFF	OFF	0.046	0.046	140
20	0.046	0.046	0.046	0.047	OFF	OFF	0.047	141
21	OFF	OFF	OFF	0.047	0.047	0.047	0.047	139
22	0.047	0.047	0.047	0.047	0.047	0.047	0.047	140
23	0.047	0.047	0.047	0.047	0.047	0.047	0.047	139
24	0.047	0.047	0.047	0.047	0.048	0.048	0.048	138
25	0.048	0.048	0.048	0.048	0.048	0.048	0.048	140
26	0.049	0.049	0.049	0.049	0.049	0.049	0.049	140
27	0.049	0.049	0.049	0.049	0.049	0.049	0.049	138
28	0.049	0.049	0.049	0.049	0.049	0.049	0.049	140
29	0.049	0.049	0.049	0.049	0.049	0.050	0.050	133
30	0.050	0.050	0.050	0.050	0.050	0.050	0.050	139
31								

Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/>	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/>		

Notes:	Printed Darrel Lockard	
	SIGNATURE: <i>Darrel Lockard</i>	5/9/22
	Phone# 541- 222-9997	CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

