

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lane
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: MAPLETON WATER DISTRICT **ID #:** OR4100507 **WTP-:** WTP-A **Month/Year:** Nov 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.0350	.0350	.0350	.0350	.0350	.0350	.0350
2	.0351	.0351	.0351	.0351	.0351	.0351	.0351
3	.0352	.0352	.0352	.0352	.0352	.0352	.0352
4	.0352	.0352	.0352	.0352	.0352	.0352	.0352
5	.0353	.0353	.0353	.0353	.0353	.0353	.0353
6	.0353	.0353	.0354	.0354	.0354	.0354	.0354
7	.0255	.0255	.0255	.0255	.0255	.0255	.0255
8	.0255	.0255	.0255	.0255	.0255	.0255	.0255
9	.0255	.0255	.0255	.0256	.0256	.0256	.0256
10	.0256	.0256	.0256	.0257	.0257	.0257	.0257
11	.0257	.0258	.0258	.0258	.0258	.0258	.0258
12	.0258	.0258	.0258	.0258	.0258	.0258	.0258
13	.0258	.0258	.0258	.0258	.0259	.0259	.0259
14	.0259	.0259	.0259	.0259	.0259	.0259	.0259
15	.0258	.0258	.0258	.0258	.0258	.0258	.0258
16	.0258	.0258	.0258	.0258	.0258	.0258	.0258
17	.0258	.0258	.0258	.0258	.0258	.0258	.0258
18	.0258	.0258	.0259	.0259	.0259	.0259	.0259
19	.0259	.0259	.0259	.0259	.0259	.0259	.0259
20	.0259	.0259	.0259	.0259	.0259	.0259	.0259
21	.0259	.0259	.0260	.0259	.0259	.0260	.0260
22	.0260	.0260	.0261	.0261	.0261	.0261	.0261
23	.0261	.0261	.0261	.0262	.0262	.0262	.0262
24	.0262	.0264	.0264	.0264	.0264	.0264	.0264
25	.0264	.0264	.0264	.0264	.0264	.0264	.0264
26	.0264	.0264	.0264	.0264	.0264	.0264	.0264
27	.0265	.0265	.0265	.0265	.0265	.0265	.0265
28	.0266	.0266	.0266	.0266	.0266	.0266	.0266
29	.0266	.0267	.0267	.0267	.0267	.0267	.0267
30	.0268	.0268	.0268	.0268	.0268	.0268	.0268
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² ☒ Yes / No	CT's met everyday? (see back) ☒ Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes / No	
All daily turbidity readings ≤ 5 NTU? ☒ Yes / No			
Notes:	PRINTED NAME: Joe Rechon		
	SIGNATURE: [Signature]	DATE: Nov 22	
	PHONE #: (541) 999-6730	CERT #: N/A	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : WTP-D

System Name: Mapleton Water District ID#: 41 00507

Month/Year:

Disinfection
Giardia Log
Inactiv:

0.5

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT C x T	Temp	pH	Required CT	CT Met? ³ Yes or No	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	formula	[° C]		formula	formula	[GPM]
1	9:00 AM	1.54	70	107.8	9.1	8.8	41.2	Yes	138
2	9:00AM	1.54	70	107.8	8.6	8.8	43.1	Yes	134
3	9:00AM	1.54	70	107.8	9.2	8.7	39.9	Yes	131
4	9:00AM	1.51	70	105.7	9.3	8.8	40.9	Yes	129
5	9:00AM	1.53	70	107.1	8.4	8.7	42.0	Yes	133
6	9:00AM	1.54	70	107.8	8.9	8.7	40.6	Yes	142
7	9:00AM	1.54	70	107.8	9.1	8.7	40.1	Yes	136
8	9:00AM	1.42	70	99.4	9.0	8.8	41.5	Yes	140
9	9:00AM	1.49	70	104.3	9.1	8.8	41.5	Yes	127
10	9:00AM	1.49	70	104.3	8.9	8.7	40.3	Yes	141
11	9:00AM	1.52	70	106.4	8.9	8.7	40.6	Yes	133
12	9:00AM	1.54	70	107.8	9.1	8.2	33.4	Yes	135
13	9:00AM	1.49	70	104.3	8.1	8.8	44.4	Yes	135
14	9:00AM	1.57	70	109.9	7.1	8.8	48.0	Yes	131
15	9:00AM	1.54	70	107.8	6.6	8.8	49.6	Yes	137
16	9:00AM	1.54	70	107.8	6.6	8.8	49.6	Yes	135
17	9:00AM	1.54	70	107.8	6.6	8.8	49.6	Yes	135
18	9:00AM	1.53	70	107.1	6.6	8.6	46.0	Yes	136
19	9:00AM	1.53	70	107.1	6.6	8.8	49.5	Yes	138
20	9:00AM	1.54	70	107.8	6.9	8.8	48.5	Yes	138
21	9:00AM	1.54	70	107.8	5.4	8.8	53.9	Yes	139
22	9:00AM	1.54	70	107.8	5.2	8.8	54.7	Yes	133
23	9:00AM	1.54	70	107.8	6.5	8.7	47.9	Yes	134
24	9:00AM	1.53	70	107.1	8.2	8.7	42.7	Yes	140
25	9:00AM	1.54	70	107.8	8.1	8.6	41.5	Yes	137
26	9:00AM	1.54	70	107.8	8.3	8.8	44.0	Yes	137
27	9:00AM	1.54	70	107.8	8.1	8.8	44.6	Yes	136
28	9:00AM	1.53	70	107.1	8.3	8.9	45.6	Yes	134
29	9:00AM	1.54	70	107.8	8.1	8.8	44.6	Yes	138
30	9:00AM	1.54	70	107.8	8.2	8.8	44.3	Yes	141
31			70					No	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013