

OHA - Drinking Water Services -Turbidity Monitoring Report Form Conventional or Direct Filtration							County: Clackamas
							Month/Year: Apr-25
System Name:		City Of Molalla		ID#: 41 -00534			WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	0.02	0.02	OFF	0.03	OFF	0.05
2	OFF	OFF	0.04	0.04	0.03	0.03	0.07
3	OFF	OFF	0.02	0.02	0.02	OFF	0.04
4	OFF	OFF	0.02	0.03	0.03	OFF	0.06
5	OFF	OFF	0.03	0.04	0.03	0.03	0.07
6	OFF	OFF	OFF	0.03	0.03	OFF	0.04
7	OFF	0.04	0.03	0.03	0.02	OFF	0.14
8	OFF	OFF	0.03	0.03	0.02	0.03	0.07
9	OFF	OFF	OFF	0.02	0.02	OFF	0.03
10	OFF	OFF	0.02	0.02	0.06	OFF	0.12
11	OFF	OFF	0.03	0.08	0.03	0.03	0.14
12	OFF	OFF	0.03	0.03	0.03	0.03	0.07
13	OFF	OFF	0.03	0.05	0.03	0.03	0.09
14	OFF	OFF	OFF	0.03	0.03	OFF	0.04
15	OFF	OFF	0.03	0.04	0.03	0.03	0.08
16	OFF	OFF	0.03	0.03	0.03	OFF	0.04
17	OFF	OFF	0.03	0.04	0.03	0.03	0.08
18	OFF	OFF	0.03	0.03	0.04	OFF	0.13
19	OFF	OFF	0.04	0.03	0.03	0.03	0.05
20	OFF	OFF	0.03	0.03	0.03	0.04	0.09
21	OFF	OFF	0.04	0.03	0.03	0.03	0.06
22	OFF	OFF	0.04	0.03	0.03	0.04	0.09
23	OFF	OFF	OFF	0.03	0.03	0.03	0.08
24	OFF	OFF	OFF	0.03	0.03	0.04	0.11
25	OFF	OFF	0.04	0.04	0.03	OFF	0.09
26	0.03	0.03	0.03	0.03	0.03	OFF	0.04
27	OFF	0.03	0.04	0.04	0.04	0.03	0.07
28	OFF	OFF	0.03	0.03	0.06	OFF	0.06
29	OFF	OFF	0.04	0.04	0.03	OFF	0.07
30	OFF	OFF	0.03	0.03	0.03	0.04	0.05
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?				Yes / No	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?				Yes / No	Yes / No		Yes / No
All turbidity readings < IFE ² triggers				Yes / No			
Notes:					PRINTED NAME: Darrel Lockard		
					SIGNATURE:		DATE: 5/6/2025
					PHONE #: (541) 505-9968		CERT #: 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form				WTP - :	
System Name:	ID#: 41 - 00534	Month/Year	25-Apr	Disinfection Giardia Log Inactive:	0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 20:30	0.81	47	38.0	8.7	7.81	27.4	YES	1054
2 / 08:21	0.80	47	37.7	8.6	7.78	27.2	YES	1025
3 / 10:18	0.80	47	37.7	8.7	7.80	27.2	YES	1061
4 / 14:54	0.83	47	39.1	8.8	7.69	26.0	YES	1730
5 / 12:29	0.84	47	39.5	9.1	7.67	25.4	YES	1674
6 / 13:56	0.87	47	41.1	9.4	7.73	25.6	YES	948
7 / 19:04	0.87	47	41.0	10.0	7.71	24.3	YES	867
8 / 07:36	0.85	47	39.8	10.2	7.73	24.2	YES	1004
9 / 20:02	0.83	47	38.8	9.9	7.67	24.1	YES	891
10 / 15:54	0.82	47	38.6	9.9	7.65	23.9	YES	1395
11 / 07:46	0.81	47	38.1	10.1	7.70	24.0	YES	808
12 / 10:09	0.85	47	39.8	10.2	7.67	23.7	YES	922
13 / 11:08	0.84	47	39.5	10.2	7.69	23.8	YES	994
14 / 17:09	0.84	47	39.6	10.5	7.67	23.2	YES	921
15 / 20:11	0.83	47	39.0	10.8	7.71	23.1	YES	958
16 / 13:30	0.82	47	38.5	10.9	7.68	22.7	YES	984
17 / 10:13	0.81	47	37.8	11.0	7.74	22.9	YES	1090
18 / 14:40	0.82	47	38.6	11.3	7.69	22.2	YES	1011
19 / 10:02	0.82	47	38.5	11.2	7.71	22.4	YES	1032
20 / 09:28	0.82	47	38.5	11.4	7.74	22.3	YES	1008
21 / 12:03	0.84	47	39.7	11.9	7.76	21.8	YES	1360
22 / 11:44	0.86	47	40.3	11.7	7.74	22.0	YES	1138
23 / 19:24	0.87	47	40.9	11.8	7.76	22.1	YES	936
24 / 20:12	0.86	47	40.5	11.7	7.77	22.1	YES	1042
25 / 11:38	0.85	47	39.9	11.8	7.77	22.1	YES	1378
26 / 12:52	0.86	47	40.3	12.2	7.75	21.4	YES	1624
27 / 13:09	0.85	47	40.0	12.4	7.68	20.6	YES	1391
28 / 17:17	0.84	47	39.3	12.4	7.74	21.0	YES	2192
29 / 10:54	0.82	47	38.5	12.7	7.75	20.6	YES	1139
30 / 09:17	0.80	47	37.5	12.6	7.71	20.3	YES	1030

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dlp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

