

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Polk

Cartridge or Bag Filtration

Month/Year: Feb-26

System Name: City of Monmouth ID#: 4100537 WTP ID: TP- A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	17.57	15.37	2.20	22.00	0.02	0.03
2	17.67	15.39	2.28	22.00	0.02	0.03
3	16.67	15.38	1.29	22.00	0.02	0.03
4	17.69	15.38	2.31	22.00	0.03	0.03
5	17.80	15.38	2.42	22.00	0.02	0.03
6	17.82	15.36	2.46	22.00	0.02	0.03
7	17.86	15.38	2.48	22.00	0.03	0.03
8	17.89	15.38	2.51	22.00	0.02	0.02
9	17.96	15.37	2.59	22.00	0.02	0.03
10	18.06	15.38	2.68	22.00	0.02	0.03
11	18.12	15.40	2.72	22.00	0.02	0.03
12	18.03	15.37	2.66	22.00	0.02	0.03
13	18.17	15.38	2.79	22.00	0.03	0.03
14	18.20	15.37	2.83	22.00	0.02	0.03
15	18.25	15.38	2.87	22.00	0.03	0.03
16	18.26	15.37	2.89	22.00	0.02	0.03
17	18.35	15.37	2.98	22.00	0.02	0.03
18	18.50	15.38	3.12	22.00	0.03	0.03
19	18.47	15.37	3.10	22.00	0.02	0.03
20	18.42	15.37	3.05	22.00	0.02	0.03
21	18.44	15.37	3.07	22.00	0.03	0.03
22	18.57	15.37	3.20	22.00	0.02	0.03
23	18.69	15.37	3.32	22.00	0.02	0.02
24	18.90	15.38	3.52	22.00	0.02	0.03
25	19.89	15.38	4.51	22.00	0.02	0.03
26	20.73	15.38	5.35	22.00	0.03	0.03
27	21.37	15.37	6.00	22.00	0.02	0.03
28	22.19	15.37	6.82	22.00	0.03	0.03

<b>Cartridge &amp; Bag Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes: PSI = pounds per square inch  
 PSID = pounds per square inch difference (before filter - after filter)  
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Matt Johnson  
 SIGNATURE: *[Signature]* DATE: 3/10/26  
 PHONE #: ( 503 ) 838-2173 CERT #: 6734

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: : A

System Name:	City of Monmouth	ID#: 4100537	Month/Year:	Feb-26	Disinfection Giardia Log Inactiv:	1
--------------	------------------	--------------	-------------	--------	---	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-9:14am	0.78	85	66.3	13.5	7.53	35.7	Yes	625
2-7:00am	0.76	85	64.6	13.2	7.56	36.8	Yes	630
3-7:00am	0.8	85	68.0	12.3	7.45	38.0	Yes	625
4-7:00am	0.79	85	67.2	13.5	7.37	33.7	Yes	625
5-7:02am	0.81	85	68.9	13.3	7.36	34.1	Yes	670
6-7:00am	0.82	85	69.7	13.1	7.43	35.5	Yes	665
7-5:02am	0.84	85	71.4	13.0	7.40	35.4	Yes	665
8-6:34am	0.88	85	74.8	13.4	7.42	34.9	Yes	650
9-7:04AM	0.73	85	62.1	13.1	7.49	35.9	Yes	650
10-7:01AM	0.8	85	68.0	11.8	7.49	39.8	Yes	650
11-7:02am	0.8	85	68.0	11.3	7.51	41.4	Yes	675
12-7:00am	0.83	85	70.6	11.8	7.38	38.4	Yes	665
13-7:03am	0.83	85	70.6	14.1	7.40	32.9	Yes	665
14-7:08am	0.74	85	62.9	13.7	7.28	32.0	Yes	630
15-7:41am	0.94	85	79.9	11.3	7.34	39.6	Yes	630
16-7:00am	0.74	85	62.9	12.5	7.32	35.2	Yes	670
17-7:00am	0.77	85	65.5	7.8	7.31	48.5	Yes	665
18-7:00am	0.98	85	83.3	11.9	7.46	39.9	Yes	660
19-7:00am	0.92	85	78.2	12.4	7.31	36.4	Yes	660
20-7:00am	0.92	85	78.2	12.4	7.24	35.6	Yes	635
21-6:30am	0.85	85	72.3	12.5	7.48	37.8	Yes	590
22-6:25am	0.88	85	74.8	12.3	7.53	39.4	Yes	590
23-7:02am	0.92	85	78.2	13.3	7.43	35.5	Yes	590
24-7:00am	0.91	85	77.4	13.1	7.53	37.2	Yes	590
25-7:00am	0.82	85	69.7	11.8	7.47	39.6	Yes	590
26-7:00am	0.81	85	68.9	10.6	7.42	42.0	Yes	590
27-7:00am	0.91	85	77.4	12.6	7.45	37.4	Yes	590
28-5:19am	0.88	85	74.8	11.6	7.43	39.8	Yes	590

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmwce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

*M* 3/10/2026