

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Benton**
 Month/Year: **Jan-21**

System Name: **Monros, City of** ID#: **41 00540** WTP: TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	Off						0.00
2	Off						0.00
3	Off						0.00
4				0.130	0.128		0.13
5				0.134	0.132	0.130	0.13
6				0.128	0.130	0.129	0.13
7				0.124	0.132	0.130	0.13
8				0.135	0.133	0.133	0.14
9	Off						0.00
10	Off						0.00
11				0.138	0.132	0.129	0.14
12				0.131	0.131	0.130	0.13
13	Off						0.00
14				0.133	0.131	0.134	0.13
15				0.128	0.124	0.129	0.13
16					0.133	0.130	0.13
17				0.135	0.130	0.125	0.14
18			0.131	0.129	0.125	0.122	0.13
19			0.122	0.121	0.119		0.12
20			0.110	0.105	0.101		0.11
21			0.102	0.100	0.100		0.10
22			0.094	0.090			0.09
23	Off						0.00
24	Off						0.00
25				0.101	0.091	0.089	0.10
26					0.092		0.09
27				0.095	0.091		0.10
28				0.091	0.088		0.09
29			0.088	0.090	0.089		0.09
30	Off						0.00
31	Off						0.00

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point \geq 0.2 mg/l? Yes / No
All daily turbidity readings \leq 5 NTU? Yes / No		

Notes:

PRINTED NAME: **Charles Scholz**
 SIGNATURE: *[Signature]* DATE: **2/10/21**
 PHONE #: **(541) 995-6655** CERT #: **6060**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : TP-A
 Disinfection *Giardia*
 Log Inactiv: 0.5

System Name: Monroe, City of ID#: 41 00540 Month/Year: Jan-21

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
01/Off								
02/Off								
03/Off								
04/1200	1.05	49	51.5	7.4	7.7	29.9	YES	350
04/1600	1.19	49	58.3	7.2	7.8	31.3	YES	350
05/1200	2.52	49	123.5	7.1	7.8	36.5	YES	350
05/1600	2.51	49	123.0	7.5	7.7	34.8	YES	350
05/2000	1.98	49	97.0	7.4	7.7	32.3	YES	350
06/1200	1.32	49	64.7	7.4	7.6	29.6	YES	350
08/1600	1.55	49	76.0	7.7	7.7	30.5	YES	350
06/2000	1.76	49	86.2	7.4	7.6	31.1	YES	350
07/1200	1.92	49	94.1	7.8	7.6	31.1	YES	350
07/1600	2.21	49	108.3	8.1	7.8	33.2	YES	350
07/2000	1.84	49	90.2	7.9	7.7	31.8	YES	350
08/1200	1.22	49	59.8	8.1	7.8	30.0	YES	350
08/1600	1.35	49	66.2	8.4	7.8	29.2	YES	350
08/2000	1.86	49	91.1	8.3	7.7	30.0	YES	350
09/Off								
10/Off								
11/1200	1.16	49	56.8	8.1	7.6	27.8	YES	350
11/1600	1.87	49	91.6	8.5	7.7	30.4	YES	350
11/2000	2.11	49	103.4	8.2	7.9	33.6	YES	350
12/1200	1.59	49	77.9	8.5	7.8	30.3	YES	350
12/1600	1.84	49	90.2	8.8	7.7	29.5	YES	350
12/2000	1.96	49	96.0	8.8	7.7	29.7	YES	350
13/Off								
14/1200	1.11	49	54.4	10.0	7.9	26.9	YES	350
14/1600	1.48	49	72.5	10.1	7.8	27.2	YES	350
14/2000	1.67	49	81.8	10.2	7.8	26.8	YES	350
15/1200	1.07	49	52.4	10.1	7.8	25.4	YES	350
15/1600	1.24	49	60.8	10.3	7.9	26.7	YES	350
15/2000	1.57	49	76.9	10.5	7.9	27.2	YES	350
16/1600	0.75	49	36.8	10.1	7.9	25.8	YES	350
16/2000	1.60	49	78.4	10.4	7.8	26.5	YES	350
17/1200	0.94	49	46.1	10.3	7.7	23.8	YES	350
17/1600	1.58	49	77.4	10.5	7.7	25.7	YES	350
17/2000	2.04	49	100.0	10.4	7.8	27.9	YES	350
18/0800	1.90	49	93.1	10.2	7.7	27.0	YES	350
18/1200	2.03	49	99.5	10.1	7.9	29.6	YES	350
18/1600	1.72	49	84.3	9.9	7.9	29.4	YES	350
18/2000	1.71	49	83.8	9.8	7.7	27.3	YES	350
19/0800	1.51	49	74.0	9.7	7.9	28.5	YES	350
19/1200	1.73	49	84.8	9.6	7.9	29.8	YES	350
19/1600	2.10	49	102.9	9.3	7.8	30.4	YES	350
20/0800	1.76	49	86.2	9.2	7.8	29.2	YES	350
20/1200	1.84	49	90.2	8.5	7.9	32.8	YES	350
20/1600	1.80	49	88.2	8.3	7.9	32.6	YES	350
21/0800	1.46	49	71.5	8.2	7.8	30.8	YES	350
21/1200	1.75	49	85.8	8.4	7.8	30.7	YES	350
21/1600	1.86	49	91.1	8.5	7.7	29.8	YES	350
22/0800	1.48	49	72.5	8.4	7.7	28.7	YES	350
22/1200	1.81	49	88.7	8.4	7.8	31.7	YES	350

23/Off								
24/Off								
25/1200	1.18	49	57.8	8.7	7.9	29.3	YES	350
25/1600	1.49	49	73.0	7.5	7.8	31.6	YES	350
25/2000	2.10	49	102.9	7.3	7.8	34.3	YES	350
26/1600	1.77	49	86.7	7.4	7.9	35.0	YES	350
27/1200	1.46	49	71.5	6.5	7.7	33.4	YES	350
27/1600	1.88	49	92.1	5.8	7.8	38.2	YES	350
28/1200	1.57	49	76.9	6.0	7.9	37.3	YES	350
28/1600	1.76	49	86.2	6.4	7.7	34.4	YES	350
29/0800	1.45	49	71.1	6.6	7.9	35.7	YES	350
29/1200	1.77	49	86.7	6.7	7.8	34.5	YES	350
29/1600	2.01	49	98.5	6.7	7.9	37.0	YES	350
30/Off								
31/Off								

³ If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2