

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Benton**
 Month/Year: **Sep-22**
 WTP: TP - **A**

System Name:	Monroe, City of		ID#: 41 00540		WTP: TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.066	0.055	0.054		0.07
2			0.063	0.058			0.06
3	Off						
4	Off						
5	Off						
6				0.079	0.057		0.08
7				0.070	0.056	0.053	0.07
8			0.062	0.054			0.06
9			0.064	0.063	0.057	0.049	0.06
10	Off						
11	Off						
12	Off						
13			0.069	0.055	0.062		0.07
14			0.059	0.053	0.052		0.06
15			0.065	0.053	0.045		0.07
16	Off						
17	Off						
18	Off						
19			0.077	0.053	0.047		0.08
20			0.059	0.054	0.050		0.06
21				0.053	0.048	0.050	0.05
22			0.048	0.051	0.052		0.05
23				0.062	0.053	0.055	0.06
24	Off						
25	Off						
26			0.061	0.056	0.050		0.06
27			0.059	0.053	0.046		0.06
28			0.055	0.046			0.06
29	Off						
30	Off						

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
		Yes / No

Notes:

PRINTED NAME: Charles Scholz

SIGNATURE: *[Signature]* DATE: 10-4-22

PHONE #: (541) 995-6655 CERT #: 6060

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : TP-A

Disinfection *Giardia*

Log Inactiv:

0.5

System Name: Monroe, City of

ID#: 41

00540

Month/Year: Sep-22

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
01/0800	1.83	49	89.7	24.9	7.7	10.1	YES	350
01/1200	1.98	49	97.0	24.4	7.8	10.9	YES	350
01/1600	1.94	49	95.1	25.0	7.7	10.1	YES	350
02/0800	0.97	49	47.5	24.9	7.8	9.3	YES	350
02/1200	1.44	49	70.6	24.3	7.9	10.5	YES	350
03/Off								
04/Off								
05/Off								
06/1200	0.61	49	29.9	23.9	7.7	9.2	YES	350
06/1600	1.60	49	78.4	23.3	7.9	11.5	YES	350
07/1200	0.85	49	41.7	23.6	8.0	11.0	YES	350
07/1600	1.95	49	95.6	22.9	7.9	12.3	YES	350
07/2000	1.76	49	86.2	23.4	8.0	12.4	YES	350
08/0800	1.07	49	52.4	23.3	8.1	11.8	YES	350
08/1200	1.69	49	82.8	22.2	7.8	12.4	YES	350
09/0800	1.14	49	55.9	22.4	7.8	11.4	YES	350
09/1200	2.00	49	98.0	21.5	7.8	13.4	YES	350
09/1600	1.97	49	96.5	21.7	7.7	12.8	YES	350
09/2000	1.71	49	83.8	21.4	8.0	13.7	YES	350
10/Off								
11/Off								
12/Off								
13/0800	0.66	49	32.3	21.7	8.2	12.9	YES	350
13/1200	1.64	49	80.4	21.2	7.8	13.1	YES	350
13/1600	2.20	49	107.8	21.4	7.7	13.2	YES	350
14/0800	1.05	49	51.5	21.5	7.8	12.1	YES	350
14/1200	1.78	49	87.2	21.0	7.8	13.6	YES	350
14/1600	1.96	49	96.0	21.4	7.7	13.0	YES	350
15/0800	1.15	49	56.4	21.5	7.9	12.6	YES	350
15/1200	1.69	49	82.8	21.0	7.8	13.2	YES	350
15/1600	2.20	49	107.8	21.2	7.9	14.5	YES	350
16/Off								
17/Off								
18/Off								
19/0800	0.72	49	35.3	21.1	7.6	10.7	YES	350
19/1200	1.46	49	71.5	19.4	7.7	13.7	YES	350
19/1600	1.53	49	75.0	19.7	7.9	14.8	YES	350
20/0800	1.05	49	51.5	19.7	8.1	15.0	YES	350
20/1200	1.55	49	76.0	19.0	8.0	15.9	YES	350
20/1600	1.62	49	79.4	19.4	7.8	14.8	YES	350
21/1200	1.04	49	51.0	19.5	7.7	13.0	YES	350
21/1600	1.57	49	76.9	18.9	7.8	14.9	YES	350
21/2000	1.53	49	75.0	19.2	7.9	15.0	YES	350
22/0800	0.97	49	47.5	19.3	8.0	14.9	YES	350
22/1200	1.38	49	67.6	18.8	7.8	14.8	YES	350
22/1600	2.02	49	99.0	19.0	7.9	16.4	YES	350
23/1200	1.23	49	60.3	19.0	7.8	14.2	YES	350
23/1600	1.95	49	95.6	18.8	7.7	15.1	YES	350
23/2000	1.98	49	97.0	19.7	8.0	16.4	YES	350
24/Off								
25/Off								
26/0800	0.91	49	44.6	19.7	8.1	14.5	YES	350

26/1200	2.01	49	98.5	19.6	7.9	15.6	YES	350
26/1600	2.02	49	99.0	20.5	8.0	15.5	YES	350
27/0800	1.43	49	70.1	20.6	8.1	14.9	YES	350
27/1200	1.71	49	83.8	20.3	7.9	14.5	YES	350
27/1600	1.73	49	84.8	20.9	8.0	14.5	YES	350
28/0800	1.45	49	71.1	20.9	8.0	14.0	YES	350
28/1200	2.02	49	99.0	19.5	7.9	15.8	YES	350
29/Off								
30/Off								

³ If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2