

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Benton**  
 Month/Year: **Sep-21**  
 WTP : TP - **A**

System Name: **Monroe, City of** ID#: **41 00540**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			0.127	0.124	0.122		0.13
2			0.117	0.119	0.116		0.12
3			0.121	0.124	0.119		0.12
4	Off						
5	Off						
6	Off						
7				0.117	0.119	0.122	0.12
8				0.124	0.119		0.12
9				0.122	0.119	0.120	0.12
10				0.116	0.117		0.12
11	Off						
12	Off						
13			0.127	0.125	0.121		0.13
14				0.122	0.119	0.118	0.12
15				0.119	0.121	0.124	0.12
16				0.121	0.117		0.12
17				0.120	0.119		0.12
18	Off						
19	Off						
20				0.125	0.117		0.13
21				0.117	0.122		0.12
22				0.125	0.119		0.13
23				0.119	0.117		0.12
24				0.128	0.121		0.13
25	Off						
26	Off						
27				0.128	0.122		0.13
28				0.121	0.126		0.13
29				0.124	0.123		0.12
30	Off						
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes:	PRINTED NAME: Charles Scholz		
	SIGNATURE: <i>[Signature]</i>		DATE: 09/24
	PHONE #: (541) 995-6655		CERT #: 6060

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.



27/1200	0.83	49	40.7	20.3	8.0	13.7	YES	350
27/1600	2.05	49	100.5	19.2	7.8	15.4	YES	350
28/1200	1.80	49	88.2	19.1	7.9	15.8	YES	350
28/1600	2.03	49	99.5	17.6	7.9	17.8	YES	350
29/1200	1.19	49	58.3	18.0	7.9	15.8	YES	350
29/1600	1.56	49	76.4	17.5	7.9	17.0	YES	350
30/Off								

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

**Return by 10th of following month by email, fax, or mail to:**  
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350