

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Benton**  
 Month/Year: **Dec-21**

System Name: **Monroe, City of** ID#: **41 00540** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1				0.119	0.118		0.12
2				0.118	0.118		0.12
3				0.120	0.121		0.12
4	Off						
5	Off						
6				0.118	0.117		0.12
7				0.122	0.122		0.12
8				0.128	0.127	0.124	0.13
9				0.129	0.124		0.13
10	Off						
11	Off						
12	Off						
13				0.133	0.132	0.130	0.13
14				0.130	0.132	0.134	0.13
15				0.133	0.130	0.128	0.13
16				0.129	0.131	0.133	0.13
17				0.118	0.118	0.119	0.12
18	Off						
19	Off						
20				0.133	0.131	0.132	0.13
21				0.134	0.129	0.130	0.13
22				0.129	0.132	0.132	0.13
23				0.130	0.129	0.133	0.13
24				0.133	0.130		0.13
25	Off						
26	Off						
27				0.130	0.128		0.13
28				0.126	0.123		0.13
29				0.122	0.124		0.12
30				0.126	0.121		0.13
31	Off						

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes / No</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes / No</b>		

Notes:

PRINTED NAME: **Charles Scholz**  
 SIGNATURE: *[Signature]* DATE: **1-3-21**  
 PHONE #: **(541) 995-6655** CERT #: **6060**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

