

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Benton**
 Month/Year: **Oct-22**

System Name: **Monroe, City of** ID#: **41 00540** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	Off						
2	Off						
3				0.069	0.049		0.07
4			0.053	0.046			0.05
5			0.047	0.050			0.05
6			0.063	0.060			0.06
7				0.063	0.046		0.06
8	Off						
9	Off						
10				0.055	0.053		0.06
11				0.088	0.061	0.054	0.09
12			0.070	0.058			0.07
13			0.072	0.059			0.07
14			0.086	0.062			0.09
15	Off						
16	Off						
17			0.103	0.079	0.067		0.10
18				0.063	0.057		0.06
19			0.061	0.052	0.050		0.06
20			0.054	0.052			0.05
21			0.062	0.066			0.07
22	Off						
23	Off						
24				0.074	0.054		0.07
25			0.067	0.059			0.07
26			0.075	0.067			0.08
27				0.058	0.057		0.06
28	Off						
29	Off						
30	Off						
31			0.064	0.076	0.069		0.08

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes:

PRINTED NAME: **Charles Scholz**
 SIGNATURE: *[Signature]* DATE: **11/4/22**
 PHONE #: **(541) 995-6655** CERT #: **6060**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

30/Off								
31/0800	1.18	49	57.8	14.9	8.2	22.1	YES	350
31/1200	2.05	49	100.5	14.6	8.2	24.8	YES	350
31/1600	2.00	49	98.0	14.6	7.8	21.4	YES	350

³ If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2