

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Benton**  
 Month/Year: **May-23**

System Name:	Monroe, City of		ID#: 41	00540		WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1				0.068	0.070	0.063	0.07
2			0.071	0.052	0.056		0.07
3			0.073	0.056	0.062		0.07
4				0.067	0.071	0.061	0.07
5			0.071	0.053			0.07
6			0.072	0.054	0.067		0.07
7	Off						
8			0.066	0.056	0.056		0.07
9			0.072	0.047	0.085		0.09
10			0.066	0.073	0.070		0.07
11			0.058	0.070	0.100		0.10
12			0.073	0.072	0.064		0.07
13	Off						
14	Off						
15			0.076	0.074	0.102		0.10
16			0.077	0.097	0.084		0.10
17			0.079	0.084	0.086		0.09
18			0.085	0.087	0.096		0.10
19			0.085	0.076	0.077		0.09
20	Off						
21	Off						
22			0.083	0.079	0.075		0.08
23			0.083	0.070	0.071		0.08
24			0.098	0.056	0.071		0.10
25			0.058	0.065	0.046		0.07
26			0.106	0.064	0.062		0.11
27	Off						
28			0.086	0.074	0.072		0.09
29	Off						
30			0.078	0.062	0.074		0.08
31			0.062	0.058	0.061		0.06

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b> 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes / No</b> All daily turbidity readings ≤ 5 NTU? <b>Yes / No</b>	<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <b>Yes / No</b> All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes / No</b>	
	PRINTED NAME: Charles Scholz SIGNATURE: <i>[Signature]</i> DATE: 6-8-23 PHONE #: (541) 995-6655 CERT #: 6060	
Notes:		

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.



21/Off								
22/0800	0.73	49	35.8	21.9	7.8	11.0	YES	350
22/1200	1.65	49	80.9	21.0	7.8	13.2	YES	350
22/1600	1.93	49	94.6	20.6	8.0	14.9	YES	350
23/0800	1.47	49	72.0	20.0	7.8	13.6	YES	350
23/1200	1.89	49	92.6	19.4	7.9	15.7	YES	350
23/1600	1.93	49	94.6	19.6	7.8	14.9	YES	350
24/0800	1.75	49	85.8	19.1	8.0	16.1	YES	350
24/1200	2.03	49	99.5	18.2	8.0	17.9	YES	350
24/1600	2.34	49	114.7	19.0	8.0	17.3	YES	350
25/0800	1.74	49	85.3	19.2	7.9	15.7	YES	350
25/1200	1.90	49	93.1	18.9	8.1	17.2	YES	350
25/1600	1.95	49	95.6	19.8	8.0	16.0	YES	350
26/0800	1.36	49	66.6	20.7	7.8	13.2	YES	350
26/1200	1.73	49	84.8	20.4	8.0	14.7	YES	350
26/1600	1.86	49	91.1	22.0	7.8	12.8	YES	350
27/Off								
28/0800	0.96	49	47.0	21.5	7.9	12.1	YES	350
28/1200	1.64	49	80.4	20.9	7.9	13.5	YES	350
28/1600	1.81	49	88.7	21.9	7.8	12.5	YES	350
29/Off								
30/0800	0.92	49	45.1	21.7	7.7	11.3	YES	350
30/1200	1.59	49	77.9	20.4	7.8	13.8	YES	350
30/1600	1.75	49	85.8	20.3	8.0	14.8	YES	350
31/0800	1.35	49	66.2	20.6	7.6	12.4	YES	350
31/1200	1.76	49	86.2	19.3	7.8	15.0	YES	350
31/1600	1.74	49	85.3	19.4	7.7	14.4	YES	350

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2