

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Benton**
 Month/Year: **Dec-23**

System Name: **Monroe, City of** ID#: **41 00540** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.042	0.039	0.044		0.04
2	Off						
3	Off						
4				0.079	0.052		0.08
5			0.047	0.045			0.05
6			0.038	0.041	0.045		0.05
7			0.041	0.044			0.04
8			0.045	0.046			0.05
9	Off						
10	Off						
11			0.040	0.041			0.04
12			0.040	0.039	0.043		0.04
13			0.035	0.042	0.038		0.04
14			0.035	0.039	0.042		0.04
15			0.035	0.036	0.041		0.04
16	Off						
17	Off						
18			0.044	0.042	0.045		0.05
19			0.039	0.042	0.043		0.04
20			0.036	0.034	0.036		0.04
21			0.037	0.037	0.046		0.05
22			0.041	0.044			0.04
23	Off						
24	Off						
25	Off						
26	Off						
27			0.058	0.042			0.06
28			0.047	0.037			0.05
29			0.036	0.038			0.04
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No <i>(Yes)</i>	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No <i>(Yes)</i>	Yes / No <i>(Yes)</i>	Yes / No <i>(Yes)</i>
Notes:	PRINTED NAME: Charles Scholz		
	SIGNATURE: <i>Charles Scholz</i>		1-10-24
	PHONE #: (541) 995-6655		CERT #: 6060

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

26/Off								
27/0800	0.97	49	47.5	9.5	8.2	30.8	YES	350
27/1200	1.34	49	65.7	8.8	8.1	31.9	YES	350
28/0800	1.17	49	57.3	8.9	8.1	31.4	YES	350
28/1200	2.54	49	124.5	8.8	8.0	36.1	YES	350
29/0800	1.58	49	77.4	9.0	8.1	32.4	YES	350
29/1200	1.83	49	89.7	8.9	8.2	34.8	YES	350

³ If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2