

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Grant  
 Month/Year: JAA 2021  
 WTP: TP - A

System Name: Monument, City of ID#: 41 00541

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			.24				
2			.27				
3			.25				
4			.25				
5			.22				
6			.30				
7			.31				
8			.20				
9			.29				
10			.28				
11			.33				
12			.29				
13			.27				
14			.30				
15			.30				
16			.38				
17			.47				
18			.39				
19			.33				
20			.33				
21			.25				
22			.27				
23			.31				
24			.39				
25			.30				
26			.29				
27			.27				
28			.35				
29			.38				
30			.34				
31			.29				

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: <u>Carmie Jewell</u> SIGNATURE: <u>[Signature]</u> DATE: <u>02-03-2021</u> PHONE #: <u>(541) 934-2025</u> CERT #: <u>N/A</u>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-A

System Name: Monument, City of ID#: 41 00541 Month/Year: 01/2021

Disinfection Giardia Log Inactiv: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[°C]		tables or formul	Yes / No	[GPM]
1	.2	315	63	13	7.5	42	Yes	
2	.2	315	63	13	7.5	42	Yes	
3	.2	315	63	13	7.4	42	no	
4	.3	315	94.5	12	7.5	42	no	
5	.3	315	94.5	12	7.6	50	no	
6	.3	315	94.5	11	7.6	50	no	
7	.3	315	94.5	13	7.6	50	no	
8	.3	315	94.5	12	7.6	50	no	
9	.3	315	94.5	14	7.6	50	no	
10	.3	315	94.5	14	7.5	42	yes	
11	.3	315	94.5	13	7.6	50	no	
12	.3	315	94.5	13	7.5	42	yes	
13	.3	315	94.5	12	7.6	50	no	
14	.3	315	94.5	11	7.6	50	no	
15	.3	315	94.5	12	7.5	42	no	
16	.3	315	94.5	13	7.7	50	yes	
17	.3	315	94.5	13	7.7	50	yes	
18	.3	315	94.5	14	7.5	42	no	
19	.3	315	94.5	11	7.6	50	no	
20	.4	315	126	12	7.5	42	yes	
21	.4	315	126	13	7.5	42	yes	
22	.4	315	126	12	7.9	50	yes	
23	.4	315	126	12	8.0	50	yes	
24	.4	315	126	11	7.7	50	yes	
25	.4	315	126	12	7.6	50	yes	
26	.4	315	126	11	7.6	50	no	
27	.4	315	126	14	7.6	50	yes	
28	.4	315	126	13	7.6	50	yes	
29	.4	315	126	12	7.7	50	yes	
30	.4	315	126	12	7.7	50	yes	
31	.4	315	126	13	7.5	42	yes	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013