

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Grant
 Month/Year: April 2024

System Name:	Monument, City of		ID#: 41	00541	WTP: TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			.38				
2			.44				
3			.53				
4			.46				
5			.46				
6			.38				
7			.44				
8			.47				
9			.53				
10			.55				
11			.55				
12			.58				
13			.60				
14			.58				
15			.55				
16			.46				
17			.58				
18			.40				
19			.49				
20			.47				
21			.60				
22			.71				
23			.72				
24			.88				
25			.88				
26			.83				
27			.88				
28			.79				
29			.88				
30			.56				
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: <u>Dorothy Jordan</u>	DATE: <u>5-5-2024</u>
		SIGNATURE: <u>[Signature]</u>	CERT #: <u>NA</u>
		PHONE #: <u>(541) 934-2025</u>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- A

System Name: Monument, City of ID#: 41. 00541 Month/Year:

Disinfection Giardia Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	CXT	[°C]	tables or formul	Yes / No	[GPM]	
1	.5	315	157.5	15	7.4	28	Yes	
2	.5	315	157.5	14	7.5	42	Yes	
3	.5	315	157.5	14	7.4	42	Yes	
4	.4	315	126	14	7.4	42	Yes	
5	.4	315	126	14	7.5	42	Yes	
6	.4	315	126	12	7.5	42	Yes	
7	.3	315	94.5	12	7.6	50	Yes	
8	.3	315	94.5	14	7.4	50	Yes	
9	.3	315	94.5	15	7.5	28	Yes	
10	.3	315	94.5	16	7.3	28	Yes	
11	.2	315	63	14	7.4	42	Yes	
12	.3	315	94.5	11	7.4	42	Yes	
13	.3	315	94.5	13	7.5	42	Yes	
14	.3	315	94.5	13	7.5	42	Yes	
15	.2	315	63	15	7.4	42	Yes	
16	.2	315	63	16	7.3	28	Yes	
17	.2	315	63	15	7.3	28	Yes	
18	.2	315	63	15	7.4	28	Yes	
19	.4	315	126	15	7.3	28	Yes	
20	.4	315	126	14	7.3	42	Yes	
21	.4	315	126	14	7.2	42	Yes	
22	.4	315	126	14	7.3	42	Yes	
23	.4	315	126	14	7.4	42	Yes	
24	.4	315	126	15	7.3	28	Yes	
25	.4	315	126	16	7.4	28	Yes	
26	.3	315	94.5	16	7.3	28	Yes	
27	.3	315	94.5	16	7.4	28	Yes	
28	.3	315	94.5	16	7.4	28	Yes	
29	.5	315	157.5	16	7.5	28	Yes	
30	.2	315	63	19	7.5	28	Yes	
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013