

OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Grant  
 Month/Year: July 2022  
 WTP: TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			.39				
2			.59				
3			.40				
4			.26				
5			.21				
6			.29				
7			.38				
8			.36				
9			.54				
10			.52				
11			.36				
12			.18				
13			.18				
14			.36				
15			.16				
16			.15				
17			.11				
18			.23				
19			.23				
20			.27				
21			.14				
22			.16				
23			.19				
24			.15				
25			.13				
26			.27				
27			.13				
28			.15				
29			.27				
30			.16				
31			.14				

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
Notes:		PRINTED NAME: <u>Carrie Jewell</u> SIGNATURE: <u>Carrie Jewell</u> DATE: <u>8-1-2022</u> PHONE #: <u>(541) 934-2025</u> CERT #: <u>NA</u>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- A  
Disinfection Giardia Log  
Inactiv: 1.0

System Name: Monument, City of ID#: 41 00541 Month/Year: July 2022

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp ↓	pH ↑	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[°C]		tables or formul	Yes / No	[GPM]
1	1.0	126		20	6.7	9	Yes	
2	.5	126	63	21	6.9	9	Yes	
3	1.5	126		20	7.0	10	Yes	
4	.9	126	113.4	20	6.8	9	Yes	
5	.9	126	113.4	20	6.8	9	Yes	
6	1.0	126	126	21	6.8	9	Yes	
7	1.0	126	126	21	6.8	9	Yes	
8	.8	126	100.8	21	6.9	18	Yes	
9	.8	126	100.8	22	7.1	9	Yes	
10	1.0	126	126	22	6.8	9	Yes	
11	.8	126	100.8	21	6.9	9	Yes	
12	.9	126	113.4	21	6.7	9	Yes	
13	.7	126	88.2	22	6.7	9	Yes	
14	1.5	126	189	22	6.8	10	Yes	
15	.8	126	100.8	22	6.9	9	Yes	
16	.7	126	88.2	23	6.7	9	Yes	
17	1.0	126	126	22	6.7	9	Yes	
18	.2	126	25.2	22	6.7	9	Yes	
19	1.1	126	138.6	21	6.9	9	Yes	
20	.6	126	75.6	22	7.0	9	Yes	
21	1.2	126	151.2	22	6.9	10	Yes	
22	.8	126	100.8	22	6.9	9	Yes	
23	1.0	126	126	21	7.0	9	Yes	
24	.9	126	113.4	22	6.9	9	Yes	
25	1.5	126	189	22	6.8	10	Yes	
26	.9	126	113.4	22	7.0	9	Yes	
27	.8	126	97.8	22	6.7	9	Yes	
28	.9	126	113.4	22	6.8	9	Yes	
29	.5	126	63	22	6.7	9	Yes	
30	1.4	126	176.4	21	6.9	10	Yes	
31	.7	126	88.2	24	6.9	9	Yes	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.