

OHA - Drinking Water Services -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Apr-21

System Name:	Clarks Branch Water Association		ID#: 41	00548			WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	POL	POL	0.05	0.05	0.05	0.05	0.05	
2	POL	POL	POL	0.05	POL	POL	0.05	
3	POL	POL	POL	0.06	0.05	0.05	0.06	
4	0.05	0.05	POL	POL	POL	POL	0.05	
5	POL	POL	POL	0.05	0.03	0.05	0.05	
6	POL	POL	POL	POL	POL	POL	POL	
7	POL	POL	POL	0.06	0.05	0.05	0.06	
8	POL	POL	POL	POL	0.05	0.03	0.05	
9	0.05	0.05	0.05	POL	POL	POL	0.05	
10	POL	POL	0.03	POL	POL	POL	0.03	
11	POL	POL	0.05	POL	POL	POL	0.05	
12	POL	POL	0.05	0.05	0.05	0.05	0.05	
13	0.05	0.05	0.06	0.07	0.05	POL	0.07	
14	POL	POL	POL	POL	POL	POL	POL	
15	POL	POL	POL	0.06	0.09	0.08	0.09	
16	0.08	POL	POL	POL	POL	POL	0.08	
17	POL	POL	POL	0.07	0.11	0.11	0.11	
18	0.11	0.11	POL	POL	0.10	0.10	0.11	
19	POL	POL	POL	0.06	POL	POL	0.06	
20	POL	POL	0.11	0.06	0.08	0.08	0.11	
21	POL	POL	POL	0.11	POL	POL	0.11	
22	0.08	0.08	0.08	POL	POL	POL	0.08	
23	POL	POL	0.08	0.06	0.06	0.06	0.08	
24	POL	POL	POL	POL	POL	POL	POL	
25	POL	POL	POL	0.09	POL	POL	0.09	
26	POL	POL	POL	POL	0.06	0.08	0.08	
27	0.08	0.08	0.06	0.09	0.08	POL	0.09	
28	POL	POL	POL	POL	POL	POL	POL	
29	0.06	0.08	0.08	POL	POL	POL	0.08	
30	POL	POL	0.12	0.08	0.09	0.11	0.12	
31								

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: Daryn McNeil	DATE: 5-10-21
		SIGNATURE: <i>[Signature]</i>	CERT #: 09178
		PHONE #: (541) 680-4513	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Clarks Branch Water Association		ID#: 41	00548	Month/Year: April	Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	94	112.8	14.0	7.80	40.0	YES	57
2	1.3	94	122.2	16.0	7.80	35.5	YES	57
3	1.2	94	112.8	13.0	7.90	44.4	YES	57
4	POL	94	POL	POL	POL	POL	POL	57
5	1.2	94	112.8	14.0	7.80	40.0	YES	57
6	1	94	94.0	13.0	7.60	38.9	YES	57
7	0.8	94	75.2	14.0	7.80	38.3	YES	57
8	1.4	94	131.6	18.0	7.90	32.6	YES	57
9	POL	94	POL	POL	POL	POL	POL	57
10	1.5	94	141.0	16.0	7.80	36.3	YES	57
11	1.4	94	131.6	12.0	7.60	43.7	YES	57
12	1.3	94	122.2	14.0	7.30	33.7	YES	57
13	1.4	94	131.6	14.0	7.40	35.3	YES	57
14	POL	94	POL	POL	POL	POL	POL	57
15	1.3	94	122.2	14.0	7.40	34.9	YES	57
16	POL	94	POL	POL	POL	POL	POL	57
17	1.2	94	112.8	16.0	7.60	32.6	YES	57
18	0.9	94	84.6	15.0	7.60	33.6	YES	57
19	POL	94	POL	POL	POL	POL	POL	57
20	0.8	94	75.2	16.0	7.60	31.1	YES	57
21	1	94	94.0	16.0	7.70	33.0	YES	57
22	1	94	94.0	16.0	7.80	34.3	YES	57
23	0.9	94	84.6	16.0	7.80	33.9	YES	57
24	0.8	94	75.2	17.0	7.90	32.5	YES	57
25	0.8	94	75.2	16.0	7.80	33.5	YES	57
26	0.8	94	75.2	16.0	7.80	33.5	YES	57
27	0.9	94	84.6	15.0	7.70	34.9	YES	57
28	POL	94	POL	POL	POL	POL	POL	57
29	1.4	94	131.6	15.0	7.60	35.6	YES	57
30	1	94	94.0	15.0	7.60	34.0	YES	57
31		94						57

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.