


OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Jan-22**

System Name: **Clarks Branch Water Association** **ID#: 41** **00548** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	0.09	0.08	0.08	0.09
3	0.06	POL	POL	0.09	POL	POL	0.09
4	POL	POL	POL	POL	POL	POL	POL
5	POL	0.12	0.16	0.15	0.25	POL	0.25
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	0.14	0.12	0.14	0.14
8	0.14	POL	POL	POL	POL	POL	0.14
9	POL	POL	POL	0.19	0.12	0.13	0.19
10	0.12	POL	POL	POL	POL	POL	0.12
11	POL	POL	POL	0.10	0.13	0.13	0.13
12	0.12	0.12	POL	POL	POL	POL	0.12
13	POL	POL	POL	POL	0.14	0.13	0.14
14	0.13	0.12	POL	POL	POL	POL	0.13
15	POL	POL	POL	POL	POL	0.12	0.12
16	0.12	0.12	POL	POL	POL	POL	0.12
17	POL	POL	POL	0.09	0.11	0.11	0.11
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	0.11	0.09	0.09	0.11
20	0.09	POL	POL	POL	POL	POL	0.09
21	POL	POL	POL	0.09	0.09	0.09	0.09
22	0.09	0.08	POL	POL	POL	POL	0.09
23	POL	POL	POL	0.10	0.10	0.09	0.10
24	0.09	POL	POL	POL	POL	POL	0.09
25	POL	POL	POL	POL	0.08	0.09	0.09
26	0.09	POL	POL	POL	POL	POL	0.09
27	POL	POL	POL	0.08	0.10	0.09	0.10
28	0.08	POL	POL	POL	POL	POL	0.08
29	POL	POL	POL	0.12	0.08	0.08	0.12
30	0.08	0.08	POL	POL	POL	POL	0.08
31	POL	POL	POL	POL	0.08	0.08	0.08

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Daryn McNeil
	SIGNATURE:  DATE: 1-2-22
	PHONE #: (541) 680-4513 CERT #: 09178

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name: Clarks Branch Water Association		ID#: 41	00548	Month/Year: Jan-22	Disinfection <i>Giardia</i> Log Inactiv:		1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	94	POL	POL	POL	POL	POL	57
2	1.2	94	112.8	8.0	7.70	57.8	YES	57
3	1.3	94	122.2	9.0	7.80	56.6	YES	57
4	POL	94	POL	POL	POL	POL	POL	57
5	1	94	94.0	9.0	7.50	49.1	YES	57
6	POL	94	POL	POL	POL	POL	POL	57
7	1	94	94.0	10.0	7.50	46.0	YES	57
8	POL	94	POL	POL	POL	POL	POL	57
9	POL	94	POL	POL	POL	POL	POL	57
10	POL	94	POL	POL	POL	POL	POL	57
11	1.2	94	112.8	12.0	7.60	42.7	YES	57
12	POL	94	POL	POL	POL	POL	POL	57
13	1.2	94	112.8	11.0	7.20	39.6	YES	57
14	POL	94	POL	POL	POL	POL	POL	57
15	POL	94	POL	POL	POL	POL	POL	57
16	POL	94	POL	POL	POL	POL	POL	57
17	1	94	94.0	12.0	7.30	37.6	YES	57
18	POL	94	POL	POL	POL	POL	POL	57
19	1	94	94.0	12.0	7.40	38.9	YES	57
20	POL	94	POL	POL	POL	POL	POL	57
21	1	94	94.0	13.0	7.40	36.1	YES	57
22	POL	94	POL	POL	POL	POL	POL	57
23	POL	94	POL	POL	POL	POL	POL	57
24	1.2	94	112.8	13.0	7.40	46.0	YES	57
25	POL	94	POL	POL	POL	POL	POL	57
26	POL	94	POL	POL	POL	POL	POL	57
27	1	94	94.0	13.0	7.40	45.0	YES	57
28	POL	94	POL	POL	POL	POL	POL	57
29	1	94	94.0	10.0	7.40	45.0	YES	57
30	POL	94	POL	POL	POL	POL	POL	57
31	POL	94	POL	POL	POL	POL	POL	57

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.