

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jun-24

System Name: Clarks Branch Water Association ID#: 41 00548 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.05	0.05	0.05	POL	POL	0.05	0.05
2	0.05	0.05	0.05	0.05	0.05	POL	0.05
3	POL	POL	POL	POL	POL	0.05	0.05
4	0.05	0.05	0.05	0.05	POL	POL	0.05
5	POL	POL	POL	0.05	0.05	0.05	0.05
6	0.05	0.05	0.05	0.05	POL	POL	0.05
7	POL	POL	POL	0.05	0.05	0.05	0.05
8	0.05	0.05	0.05	0.06	0.06	0.06	0.06
9	POL	POL	POL	POL	POL	0.06	0.06
10	0.06	0.06	0.06	0.06	0.05	0.05	0.06
11	0.05	0.05	0.05	0.06	POL	POL	0.06
12	POL	POL	POL	0.05	0.06	0.06	0.06
13	0.05	0.05	0.05	0.05	POL	POL	0.05
14	POL	0.05	0.05	0.05	0.05	0.05	0.05
15	0.05	0.05	0.05	0.05	0.05	0.05	0.05
16	0.05	0.05	POL	POL	POL	POL	0.05
17	0.05	0.05	POL	POL	0.05	0.05	0.05
18	0.05	0.05	POL	POL	POL	POL	0.05
19	0.05	0.05	0.05	0.05	0.05	0.05	0.05
20	0.06	POL	POL	POL	0.06	0.05	0.06
21	0.05	0.05	0.05	0.05	0.05	0.05	0.05
22	POL	POL	POL	POL	0.05	0.05	0.05
23	0.05	0.05	0.05	0.05	0.05	0.05	0.05
24	0.05	POL	POL	POL	POL	0.05	0.05
25	0.05	0.05	0.05	0.05	0.05	0.05	0.05
26	0.05	POL	POL	POL	0.05	0.05	0.05
27	0.05	0.05	0.05	0.05	0.05	0.05	0.05
28	POL	POL	POL	POL	0.06	0.06	0.06
29	0.06	0.06	0.06	0.06	0.06	0.06	0.06
30	POL	POL	POL	POL	0.06	0.06	0.06
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes: A Typo occurred on June 6 2024. The error consisted of adding a zero after the decimal. The correct Reading of 0.9 has been entered.		PRINTED NAME: Daryn McNeil	DATE: 7-18-24
		SIGNATURE:	CERT #: 09178
		PHONE #: (541) 680-4513	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Clarks Branch Water Association ID#: 41 00548 Month/Year: Jun-24 Disinfection *Giardia* Log Inactiv: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.8	94	75.2	17.0	7.40	29.0	Yes	57
2	0.8	94	75.2	17.0	7.30	29.0	Yes	57
3	0.8	94	75.2	17.0	7.30	29.0	Yes	57
4	0.8	94	75.2	17.0	7.30	29.0	Yes	57
5	1	94	94.0	17.0	7.40	30.0	Yes	57
6	0.9	94	84.6	17.0	7.40	30.0	Yes	57
7	0.8	94	75.2	18.0	7.30	29.0	Yes	57
8	1	94	94.0	19.0	7.50	30.0	Yes	57
9	1	94	94.0	18.0	7.30	30.0	Yes	57
10	0.7	94	65.8	19.0	7.40	29.0	Yes	57
11	0.5	94	47.0	19.0	7.40	29.0	Yes	57
12	0.7	94	65.8	19.0	7.40	29.0	Yes	57
13	1	94	94.0	19.0	7.30	30.0	Yes	57
14	1	94	94.0	19.0	7.40	30.0	Yes	57
15	0.8	94	75.2	19.0	7.30	29.0	Yes	57
16	0.6	94	56.4	19.0	7.30	29.0	Yes	57
17	0.6	94	56.4	19.0	7.30	29.0	Yes	57
18	0.6	94	56.4	19.0	7.30	29.0	Yes	57
19	0.7	94	65.8	19.0	7.40	22.0	Yes	57
20	0.9	94	84.6	20.0	7.10	22.0	Yes	57
21	0.8	94	75.2	20.0	7.40	22.0	Yes	57
22	0.8	94	75.2	20.0	7.30	22.0	Yes	57
23	0.7	94	65.8	23.0	7.30	22.0	Yes	57
24	0.7	94	65.8	22.0	7.30	22.0	Yes	57
25	0.8	94	75.2	22.0	7.20	22.0	Yes	57
26	0.8	94	75.2	22.0	7.30	22.0	YES	57
27	0.8	94	75.2	22.0	7.30	22.0	YES	57
28	0.8	94	75.2	23.0	7.20	22.0	YES	57
29	0.8	94	75.2	23.0	7.40	22.0	YES	57
30	0.8	94	75.2	23.0	7.30	22.0	YES	57
31		94	0.0					57

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013