

**OHA - Drinking Water Services -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: **Douglas**  
 Month/Year: **Mar-25**

| System Name: <b>Clark Branch Water Association</b> |                | ID#: <b>41</b> |               | <b>00548</b>  |               | WTP : TP - <b>A</b> |                                               |
|----------------------------------------------------|----------------|----------------|---------------|---------------|---------------|---------------------|-----------------------------------------------|
| Day                                                | 12 AM<br>[NTU] | 4 AM<br>[NTU]  | 8 AM<br>[NTU] | NOON<br>[NTU] | 4 PM<br>[NTU] | 8 PM<br>[NTU]       | Highest Reading of the Day <sup>1</sup> [NTU] |
| 1                                                  | POL            | POL            | 0.08          | 0.05          | 0.06          | 0.05                | 0.08                                          |
| 2                                                  | POL            | POL            | POL           | POL           | POL           | 0.06                | 0.06                                          |
| 3                                                  | 0.06           | 0.05           | POL           | POL           | POL           | POL                 | 0.06                                          |
| 4                                                  | POL            | POL            | 0.09          | 0.08          | POL           | POL                 | 0.09                                          |
| 5                                                  | POL            | POL            | POL           | POL           | 0.09          | POL                 | 0.09                                          |
| 6                                                  | POL            | POL            | 0.15          | 0.11          | POL           | POL                 | 0.15                                          |
| 7                                                  | POL            | POL            | POL           | POL           | POL           | 0.09                | 0.09                                          |
| 8                                                  | 0.09           | POL            | POL           | POL           | POL           | POL                 | 0.09                                          |
| 9                                                  | 0.11           | 0.09           | 0.08          | POL           | POL           | POL                 | 0.11                                          |
| 10                                                 | POL            | POL            | 0.09          | POL           | 0.15          | 0.10                | 0.15                                          |
| 11                                                 | 0.09           | POL            | POL           | POL           | POL           | POL                 | 0.09                                          |
| 12                                                 | POL            | 0.08           | 0.08          | 0.06          | POL           | POL                 | 0.08                                          |
| 13                                                 | POL            | POL            | 0.08          | 0.08          | 0.06          | POL                 | 0.08                                          |
| 14                                                 | POL            | POL            | POL           | 0.09          | 0.08          | 0.06                | 0.09                                          |
| 15                                                 | POL            | POL            | 0.09          | 0.08          | 0.08          | POL                 | 0.09                                          |
| 16                                                 | POL            | POL            | POL           | POL           | POL           | 0.08                | 0.08                                          |
| 17                                                 | POL            | 0.19           | 0.25          | 0.34          | 0.11          | 0.09                | 0.34                                          |
| 18                                                 | 0.08           | 0.08           | 0.08          | 0.14          | 0.09          | 0.08                | 0.14                                          |
| 19                                                 | POL            | POL            | POL           | 0.11          | 0.08          | POL                 | 0.11                                          |
| 20                                                 | POL            | POL            | POL           | 0.09          | 0.08          | POL                 | 0.09                                          |
| 21                                                 | POL            | POL            | POL           | POL           | 0.09          | 0.08                | 0.09                                          |
| 22                                                 | POL            | POL            | 0.08          | 0.09          | 0.08          | POL                 | 0.09                                          |
| 23                                                 | POL            | POL            | 0.10          | 0.09          | 0.08          | 0.06                | 0.10                                          |
| 24                                                 | 0.06           | POL            | POL           | POL           | POL           | POL                 | 0.06                                          |
| 25                                                 | POL            | POL            | POL           | POL           | 0.28          | 0.07                | 0.28                                          |
| 26                                                 | 0.07           | 0.06           | 0.07          | POL           | POL           | POL                 | 0.07                                          |
| 27                                                 | POL            | POL            | POL           | 0.09          | POL           | POL                 | 0.09                                          |
| 28                                                 | POL            | POL            | POL           | 0.09          | 0.06          | 0.06                | 0.09                                          |
| 29                                                 | 0.06           | 0.06           | 0.06          | 0.09          | 0.08          | 0.09                | 0.09                                          |
| 30                                                 | 0.08           | POL            | 0.09          | 0.09          | POL           | POL                 | 0.09                                          |
| 31                                                 | POL            | POL            | POL           | POL           | 0.08          | 0.08                | 0.08                                          |

| Conventional or Direct Filtration                                                                                                                                                                                                                                                              |  | Monthly Summary (Answer Yes or No)                                                                                 |                                                                                                 |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------|
| 95% of 4-hour turbidity readings ≤ 0.3 NTU? <span style="float:right"><b>Yes</b> / No</span><br>All 4-hour turbidity readings ≤ 1 NTU? <span style="float:right"><b>Yes</b> / No</span><br>All turbidity readings < IFE <sup>2</sup> triggers <span style="float:right"><b>Yes</b> / No</span> |  | CT's met everyday?<br>(see back) <span style="float:right"><b>Yes</b> / No</span>                                  | All Cl2 residual at entry point<br>≥ 0.2 mg/l? <span style="float:right"><b>Yes</b> / No</span> |
| <b>Notes:</b><br><br>                                                                                                                                                                                                                                                                          |  | <b>PRINTED NAME:</b> <i>Daryn McNeil</i><br><b>SIGNATURE:</b> <i>[Signature]</i><br><b>PHONE #:</b> (541) 680-4513 | <b>DATE:</b> 4-1-25<br><b>CERT #:</b> 09178                                                     |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

# OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

|              |                                |         |       |             |        |                                           |   |
|--------------|--------------------------------|---------|-------|-------------|--------|-------------------------------------------|---|
| System Name: | Clark Branch Water Association | ID#: 41 | 00548 | Month/Year: | Mar-25 | Disinfection <i>Giardia</i> Log Inactive: | 1 |
|--------------|--------------------------------|---------|-------|-------------|--------|-------------------------------------------|---|

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> | Contact Time (T) | Actual CT | Temp  | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand Flow |
|-------------|---------------------------------------------------------------|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]                                                 | [minutes]        | C X T     | [° C] |      | formula     | Yes / No             | [GPM]                   |
| 1           | 1                                                             | 94               | 94.0      | 11.0  | 7.00 | 36.2        | YES                  | 57                      |
| 2           | 1                                                             | 94               | 94.0      | 11.0  | 7.10 | 37.4        | YES                  | 57                      |
| 3           | 1.3                                                           | 94               | 122.2     | 11.0  | 7.10 | 38.7        | YES                  | 57                      |
| 4           | 1                                                             | 94               | 94.0      | 12.0  | 6.80 | 31.7        | YES                  | 57                      |
| 5           | 0.8                                                           | 94               | 75.2      | 12.0  | 6.80 | 31.0        | YES                  | 57                      |
| 6           | 0.8                                                           | 94               | 75.2      | 11.0  | 6.90 | 34.2        | YES                  | 57                      |
| 7           | 0.7                                                           | 94               | 65.8      | 13.0  | 6.80 | 27.9        | YES                  | 57                      |
| 8           | 0.9                                                           | 94               | 84.6      | 13.0  | 7.00 | 30.8        | YES                  | 57                      |
| 9           | 0.7                                                           | 94               | 65.8      | 12.0  | 7.00 | 32.8        | YES                  | 57                      |
| 10          | 0.8                                                           | 94               | 75.2      | 11.0  | 6.90 | 34.2        | YES                  | 57                      |
| 11          | 0.7                                                           | 94               | 65.8      | 11.0  | 6.90 | 33.8        | YES                  | 57                      |
| 12          | 0.7                                                           | 94               | 65.8      | 13.0  | 7.00 | 30.1        | YES                  | 57                      |
| 13          | 0.7                                                           | 94               | 65.8      | 11.0  | 7.10 | 36.2        | YES                  | 57                      |
| 14          | 0.7                                                           | 94               | 65.8      | 11.0  | 7.10 | 36.2        | YES                  | 57                      |
| 15          | 0.7                                                           | 94               | 65.8      | 12.0  | 7.20 | 35.1        | YES                  | 57                      |
| 16          | 0.6                                                           | 94               | 56.4      | 12.0  | 7.00 | 32.5        | YES                  | 57                      |
| 17          | 0.6                                                           | 94               | 56.4      | 13.0  | 7.50 | 35.8        | YES                  | 57                      |
| 18          | 0.9                                                           | 94               | 84.6      | 12.0  | 7.20 | 35.9        | YES                  | 57                      |
| 19          | 1.2                                                           | 94               | 112.8     | 10.0  | 7.20 | 42.3        | YES                  | 57                      |
| 20          | 0.7                                                           | 94               | 65.8      | 11.0  | 7.00 | 35.0        | YES                  | 57                      |
| 21          | 1.2                                                           | 94               | 112.8     | 11.0  | 7.10 | 38.3        | YES                  | 57                      |
| 22          | 1.3                                                           | 94               | 122.2     | 11.0  | 7.00 | 37.4        | YES                  | 57                      |
| 23          | 1.2                                                           | 94               | 112.8     | 11.0  | 6.90 | 35.7        | YES                  | 57                      |
| 24          | 1                                                             | 94               | 94.0      | 11.0  | 6.90 | 35.0        | YES                  | 57                      |
| 25          | 1.2                                                           | 94               | 112.8     | 12.0  | 6.90 | 33.5        | YES                  | 57                      |
| 26          | 0.6                                                           | 94               | 56.4      | 12.0  | 6.70 | 29.4        | YES                  | 57                      |
| 27          | 0.7                                                           | 94               | 65.8      | 13.0  | 6.70 | 26.9        | YES                  | 57                      |
| 28          | 0.6                                                           | 94               | 56.4      | 13.0  | 6.70 | 26.6        | YES                  | 57                      |
| 29          | 0.7                                                           | 94               | 65.8      | 12.0  | 6.70 | 29.7        | YES                  | 57                      |
| 30          | 0.9                                                           | 94               | 84.6      | 13.0  | 6.70 | 27.5        | YES                  | 57                      |
| 31          | 0.9                                                           | 94               | 84.6      | 13.0  | 6.80 | 28.6        | YES                  | 57                      |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350