

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Feb-26

System Name:	Clark Branch Water Association		ID#: 41	00548			WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.05	0.05	POL	POL	0.05	0.03	0.05	
2	0.05	0.03	0.03	POL	POL	POL	0.05	
3	0.05	0.03	0.03	0.05	0.05	0.05	0.05	
4	0.05	0.04	0.04	POL	0.05	0.03	0.05	
5	0.03	0.05	POL	0.05	0.03	POL	0.05	
6	POL	POL	0.05	0.05	0.05	0.05	0.05	
7	0.05	POL	POL	POL	0.05	0.05	0.05	
8	0.03	0.05	POL	POL	POL	0.05	0.05	
9	0.05	0.05	0.05	0.05	0.05	POL	0.05	
10	POL	POL	0.05	0.05	0.06	0.05	0.06	
11	0.05	POL	POL	POL	POL	0.05	0.05	
12	0.05	0.05	0.05	POL	POL	POL	0.05	
13	0.05	0.05	0.05	0.06	POL	POL	0.06	
14	POL	0.05	0.05	0.03	0.03	0.03	0.05	
15	0.03	0.03	0.03	POL	0.05	0.05	0.05	
16	0.05	0.03	0.03	POL	POL	POL	0.05	
17	0.05	0.05	0.03	0.05	0.05	POL	0.05	
18	POL	POL	POL	0.05	0.05	0.05	0.05	
19	0.05	POL	POL	0.05	0.03	0.03	0.05	
20	0.03	0.03	POL	POL	POL	0.05	0.05	
21	0.03	0.03	0.03	POL	POL	0.05	0.05	
22	0.05	0.05	POL	POL	0.05	0.05	0.05	
23	0.03	0.03	0.03	0.05	0.05	POL	0.05	
24	POL	POL	0.05	0.05	0.05	0.05	0.05	
25	0.05	0.05	0.05	0.05	0.06	0.05	0.06	
26	0.05	0.05	0.05	0.06	0.05	0.03	0.06	
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
28	POL	POL	POL	0.03	0.03	0.03	0.03	
29								
30								
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE <sup>2</sup> triggers	CT's met everyday? (see back) Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Daryn McNeil  
 SIGNATURE: *[Signature]* DATE: 3-7-26  
 PHONE #: (541) 680-4513 CERT #: 09178

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Clark Branch Water Association ID#: 41 00548 Month/Year: Feb. 26

Disinfection *Giardia* Log Inactive:

1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.9	94	84.6	12.0	7.50	39.9	YES	91
2	1.7	94	159.8	10.0	7.80	55.4	YES	59
3	1.2	94	112.8	9.0	7.90	58.0	YES	74
4	1.2	94	112.8	9.0	7.80	56.0	YES	65
5	1	94	94.0	9.0	7.80	54.7	YES	63
6	0.8	94	75.2	9.0	7.70	51.6	YES	61
7	1	94	94.0	10.0	7.70	49.3	YES	105
8	1	94	94.0	11.0	7.80	47.8	YES	68
9	1	94	94.0	10.0	7.80	51.1	YES	68
10	0.9	94	84.6	10.0	7.70	48.8	YES	64
11	0.9	94	84.6	10.0	7.60	47.1	YES	62
12	0.8	94	75.2	10.0	7.70	48.2	YES	77
13	1	94	94.0	10.0	7.60	47.6	YES	69
14	1	94	94.0	12.0	7.50	40.3	YES	41
15	0.9	94	84.6	13.0	7.70	39.9	YES	80
16	0.9	94	84.6	13.0	7.60	38.4	YES	65
17	0.8	94	75.2	13.0	7.60	38.0	YES	58
18	0.8	94	75.2	13.0	7.60	38.0	YES	56
19	0.9	94	84.6	13.0	7.60	38.4	YES	72
20	0.9	94	84.6	13.0	7.50	37.0	YES	71
21	0.8	94	75.2	13.0	7.50	36.6	YES	104
22	0.9	94	84.6	10.0	7.60	47.1	YES	32
23	0.8	94	75.2	11.0	7.50	42.1	YES	52
24	0.8	94	75.2	12.0	7.50	39.4	YES	56
25	0.8	94	75.2	12.0	7.40	38.1	YES	51
26	0.9	94	84.6	12.0	7.40	38.5	YES	84
27	0.9	94	84.6	13.0	7.40	35.7	YES	58
28	1.1	94	103.4	12.0	7.40	39.4	YES	68
29		94						
30		94						
31		94						

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350