

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Douglas**
 Month/Year: **Mar-26**

Conventional or Direct Filtration

System Name: **Clark Branch Water Association** ID#: **41** **00548** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	POL	POL	POL	0.03	0.03
3	0.03	0.03	0.03	0.03	0.05	0.03	0.05
4	0.03	POL	POL	POL	POL	POL	0.03
5	POL	POL	0.03	0.03	POL	POL	0.03
6	POL	POL	POL	0.03	0.03	0.03	0.03
7	POL	POL	POL	POL	0.05	0.03	0.05
8	0.03	0.03	POL	POL	0.03	0.03	0.03
9	0.03	0.03	0.03	0.05	POL	POL	0.05
10	POL	POL	POL	POL	0.03	0.03	0.03
11	0.03	POL	POL	0.03	0.03	0.03	0.03
12	POL	0.03	0.03	0.03	0.03	POL	0.03
13	POL	POL	POL	0.03	0.03	0.03	0.03
14	POL	POL	POL	0.05	0.05	0.05	0.05
15	0.03	POL	POL	0.03	0.03	POL	0.03
16	POL	0.03	0.03	0.05	POL	POL	0.05
17	POL	POL	POL	POL	0.04	0.04	0.04
18	0.04	POL	POL	POL	0.04	0.04	0.04
19	0.03	0.03	POL	POL	POL	POL	0.03
20	0.03	0.03	0.03	POL	POL	POL	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	POL	POL	POL	POL	0.03	0.03	0.03
23	0.03	POL	0.03	0.03	0.03	POL	0.03
24	POL	0.03	0.03	0.03	0.03	POL	0.03
25	POL	POL	0.03	0.04	0.03	0.03	0.04
26	0.03	0.03	0.03	0.03	0.03	POL	0.03
27	POL	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	POL	POL	POL	POL	POL	0.03
30	POL	POL	0.03	0.03	POL	POL	0.03
31	POL	POL	POL	0.04	0.04	0.04	0.04

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:

PRINTED NAME: *Daryn McNeil*
 SIGNATURE: *[Signature]* DATE: *4-3-26*
 PHONE #: *(541) 680 4513* CERT #: *9178*

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Clark Branch Water Association ID#: 41 00548 Month/Year: 26-Mar Disinfection *Giardia* Log Inactive: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.6	94	56.4	16.0	7.40	28.2	YES	46
2	0.7	94	65.8	16.0	7.40	28.6	YES	57
3	0.7	94	65.8	15.0	7.40	30.5	YES	72
4	0.9	94	84.6	15.0	7.40	31.2	YES	45
5	0.9	94	84.6	15.0	7.40	31.2	YES	52
6	0.8	94	75.2	15.0	7.50	32.0	YES	55
7	0.9	94	84.6	16.0	7.50	30.3	YES	45
8	0.8	94	75.2	16.0	7.50	30.0	YES	59
9	0.9	94	84.6	16.0	7.50	30.3	YES	49
10	1	94	94.0	16.0	7.50	30.7	YES	56
11	1	94	94.0	17.0	7.50	28.7	YES	66
12	1	94	94.0	17.0	7.40	27.6	YES	40
13	0.9	94	84.6	16.0	7.40	29.2	YES	56
14	0.9	94	84.6	16.0	7.50	30.3	YES	52
15	0.9	94	84.6	16.0	7.50	30.3	YES	56
16	1	94	94.0	16.0	7.50	30.7	YES	56
17	1	94	94.0	16.0	7.50	30.7	YES	59
18	0.9	94	84.6	16.0	7.50	30.3	YES	84
19	1	94	94.0	16.0	7.50	30.7	YES	55
20	1	94	94.0	16.0	7.50	30.7	YES	55
21	1	94	94.0	16.0	7.50	30.7	YES	28
22	0.8	94	75.2	16.0	7.50	30.0	YES	48
23	0.9	94	84.6	16.0	7.50	30.3	YES	65
24	0.9	94	84.6	16.0	7.50	30.3	YES	62
25	0.9	94	84.6	16.0	7.50	30.3	YES	62
26	0.9	94	84.6	16.0	7.70	32.7	YES	80
27	0.9	94	84.6	16.0	7.60	31.5	YES	93
28	0.9	94	84.6	16.0	7.50	30.3	YES	90
29	0.9	94	84.6	16.0	7.50	30.3	YES	50
30	0.9	94	84.6	16.0	7.50	30.3	YES	46
31	1	94	94.0	16.0	7.50	30.7	YES	66

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350