


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas
 Month/Year: Sep-21

Conventional or Direct Filtration

System Name:	Clarks Branch Water Association		ID#: 41	00548		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	0.06	0.05	0.06	0.06	0.06
2	0.06	POL	POL	POL	POL	POL	0.06
3	0.06	0.06	0.06	0.06	POL	POL	0.06
4	POL	POL	POL	0.06	0.05	0.06	0.06
5	0.06	0.06	POL	POL	0.06	0.06	0.06
6	0.06	0.06	POL	POL	POL	POL	0.06
7	POL	0.06	0.06	0.06	0.07	0.06	0.07
8	POL	POL	POL	POL	POL	0.08	0.08
9	0.06	0.06	0.06	0.06	POL	POL	0.06
10	POL	POL	POL	POL	0.06	0.06	0.06
11	0.06	0.06	POL	POL	POL	POL	0.06
12	POL	POL	0.06	0.06	0.06	0.06	0.06
13	0.06	POL	POL	POL	0.08	POL	0.08
14	POL	0.06	0.06	0.06	0.06	POL	0.06
15	POL	POL	POL	POL	POL	POL	POL
16	0.06	0.06	0.08	0.08	POL	POL	0.08
17	POL	POL	POL	0.06	0.06	0.08	0.08
18	0.08	0.08	POL	0.06	POL	POL	0.08
19	POL	POL	POL	0.06	0.09	0.11	0.11
20	0.09	POL	0.09	POL	POL	POL	0.09
21	POL	POL	0.09	0.08	0.08	0.06	0.09
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	0.06	0.06	0.07	0.06	0.07
24	POL	POL	POL	POL	0.08	0.08	0.08
25	POL	POL	POL	POL	POL	POL	POL
26	POL	0.06	0.06	0.06	0.06	0.08	0.08
27	POL	POL	POL	POL	0.09	POL	0.09
28	POL	POL	0.08	0.08	0.08	0.09	0.09
29	0.07	POL	POL	0.09	POL	POL	0.09
30	POL	POL	0.09	0.09	0.09	0.08	0.09
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE ² triggers Yes / No		

Notes:	PRINTED NAME: Daryn McNeil	
	SIGNATURE: 	DATE: 10-2-21
	PHONE #: (541) 680-4513	CERT #: 09178

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Clarks Branch Water Association

ID#: 41

00548

Month/Year: Sep-21

Disinfection *Giardia*
Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	94	75.2	23.0	8.20	24.3	YES	57
2	POL	94	POL	POL	POL	POL	POL	57
3	0.8	94	75.2	23.0	8.00	22.6	YES	57
4	0.6	94	56.4	22.0	8.00	23.6	YES	57
5	0.6	94	56.4	23.0	8.00	22.1	YES	57
6	POL	94	POL	POL	POL	POL	POL	57
7	0.7	94	65.8	23.0	8.20	24.1	YES	57
8	POL	94	POL	POL	POL	POL	POL	57
9	0.7	94	65.8	22.0	8.10	24.8	YES	57
10	0.7	94	65.8	22.0	8.20	25.7	YES	57
11	0.8	94	75.2	22.0	8.10	25.1	YES	57
12	0.6	94	56.4	22.0	8.20	25.4	YES	57
13	POL	94	POL	POL	POL	POL	POL	57
14	0.8	94	75.2	22.0	8.00	24.2	YES	57
15	POL	94	POL	POL	POL	POL	POL	57
16	0.6	94	56.4	21.0	8.30	28.2	YES	57
17	0.8	94	75.2	21.0	8.20	27.8	YES	57
18	0.8	94	75.2	21.0	8.30	28.9	YES	57
19	1.2	94	112.8	21.0	8.20	29.1	YES	57
20	0.8	94	75.2	20.0	8.20	29.8	YES	57
21	0.9	94	84.6	21.0	8.00	26.1	YES	57
22	POL	94	POL	POL	POL	POL	POL	57
23	0.7	94	65.8	20.0	8.10	28.3	YES	57
24	0.8	94	75.2	20.0	8.00	27.6	YES	57
25	POL	94	POL	POL	POL	POL	POL	57
26	0.8	94	75.2	20.0	8.20	29.8	YES	57
27	POL	94	POL	POL	POL	POL	POL	57
28	0.7	94	65.8	21.0	7.90	24.6	YES	57
29	POL	94	POL	POL	POL	POL	POL	57
30	1	94	94.0	19.0	8.10	31.4	YES	57
31		94						57

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013