


**OHA - Drinking Water Services -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: **Douglas**  
 Month/Year: **Mar-22**

System Name:	Clarks Branch Water Association			ID#: 41	00548	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	POL	POL	POL	POL	0.23	0.12	0.23
2	0.08	POL	POL	POL	POL	POL	0.08
3	POL	POL	POL	POL	0.09	0.11	0.11
4	0.09	POL	POL	POL	POL	POL	0.09
5	POL	POL	POL	0.15	0.20	0.25	0.25
6	POL	POL	0.25	POL	POL	POL	0.25
7	POL	POL	POL	POL	POL	0.28	0.28
8	0.25	0.25	0.21	POL	POL	POL	0.25
9	POL	POL	POL	0.22	0.06	0.05	0.22
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	0.05	0.05	0.05	0.05	0.05
12	0.05	POL	POL	POL	POL	POL	0.05
13	POL	POL	POL	0.06	0.06	0.03	0.06
14	0.03	POL	POL	POL	POL	POL	0.03
15	POL	POL	POL	POL	POL	POL	POL
16	0.03	0.03	0.03	POL	POL	POL	0.03
17	POL	POL	0.05	0.05	0.05	POL	0.05
18	POL	POL	POL	POL	POL	POL	POL
19	0.06	0.06	0.06	0.03	POL	POL	0.06
20	POL	POL	POL	POL	0.05	0.03	0.05
21	0.03	POL	POL	POL	POL	POL	0.03
22	POL	POL	0.06	0.05	0.05	POL	0.06
23	POL	POL	POL	POL	0.05	0.05	0.05
24	0.05	POL	POL	0.05	0.05	POL	0.05
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	0.05	0.05	POL	POL	0.05
27	POL	POL	POL	POL	0.05	0.05	0.05
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	POL	POL	POL	POL	POL	POL	POL
30	POL	0.05	0.03	0.03	0.03	0.03	0.05
31	POL	POL	POL	POL	POL	POL	POL

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		
Notes:	PRINTED NAME: <b>Daryn McNeil</b>	
	SIGNATURE: 	DATE: <b>4-9-22</b>
	PHONE #: ( 541 ) 680-4513	CERT #: <b>09178</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))



OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Clarks Branch Water Association

ID#: 41

00548

Month/Year: Mar-22

Mar-22

Disinfection *Giardia*  
Log Inactiv:

1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1	1.7	94	159.8	10.0	7.90	60.0	YES	57
2	POL	POL	POL	POL	POL	POL	POL	57
3	1.4	94	131.6	12.0	7.80	57.0	YES	57
4	POL	POL	POL	POL	POL	POL	POL	57
5	1.1	94	103.4	12.0	8.00	55.0	YES	57
6	1.3	94	122.2	12.0	7.60	57.0	YES	57
7	0.6	94	56.4	12.0	7.70	51.0	YES	57
8	POL	POL	POL	POL	POL	POL	POL	57
9	0.9	94	84.6	12.0	7.70	54.0	YES	57
10	POL	POL	POL	POL	POL	POL	POL	57
11	1	94	94.0	13.0	7.70	54.0	YES	57
12	POL	POL	POL	POL	POL	POL	POL	57
13	0.9	94	84.6	13.0	7.60	54.0	YES	57
14	POL	94	POL	POL	POL	POL	POL	57
15	POL	94	POL	POL	POL	POL	POL	57
16	1	94	94.0	13.0	7.60	38.9	54	57
17	0.9	94	84.6	13.0	7.70	39.9	54	57
18	POL	94	POL	POL	POL	POL	POL	57
19	0.7	94	65.8	16.0	7.60	30.8	35	57
20	POL	94	POL	POL	POL	POL	POL	57
21	POL	94	POL	POL	POL	POL	POL	57
22	POL	94	POL	POL	POL	POL	POL	57
23	0.7	94	65.8	16.0	7.70	31.9	35	57
24	0.5	94	47.0	16.0	7.60	30.1	34	57
25	POL	94	POL	POL	POL	POL	POL	57
26	0.5	94	47.0	20.0	7.60	23.0	26	57
27	POL	94	POL	POL	POL	POL	POL	57
28	1.1	94	103.4	16.0	7.40	29.9	YES	57
29	POL	94	POL	POL	POL	POL	POL	57
30	0.8	94	75.2	16.0	7.60	31.1	YES	57
31	POL	94	POL	POL	POL	POL	POL	57

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.