


OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Apr-22**

System Name:	Clarks Branch Water Association		ID#: 41	00548			WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	POL	POL	POL	POL	0.03	0.03	0.03	
2	0.03	POL	POL	POL	POL	POL	0.03	
3	POL	POL	0.05	0.05	0.03	0.03	0.05	
4	POL	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	0.03	POL	0.03	
6	POL	POL	POL	POL	POL	POL	POL	
7	0.08	0.05	0.03	0.03	0.03	POL	0.08	
8	POL	POL	POL	POL	POL	POL	POL	
9	POL	POL	0.05	0.03	0.03	0.03	0.05	
10	POL	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	0.06	0.05	0.05	0.06	
12	0.03	POL	POL	POL	POL	POL	0.03	
13	POL	POL	POL	POL	0.06	0.05	0.06	
14	0.03	0.04	POL	POL	POL	POL	0.04	
15	POL	POL	POL	POL	0.05	0.05	0.05	
16	0.05	POL	POL	POL	POL	POL	0.05	
17	POL	POL	0.05	0.05	0.03	0.03	0.05	
18	0.03	POL	POL	POL	POL	POL	0.03	
19	POL	POL	POL	POL	0.05	0.05	0.05	
20	0.05	0.05	POL	POL	POL	POL	0.05	
21	POL	POL	POL	POL	POL	POL	POL	
22	0.06	0.05	0.05	POL	POL	POL	0.06	
23	POL	POL	POL	POL	0.06	0.05	0.06	
24	0.05	0.05	POL	POL	POL	POL	0.05	
25	POL	POL	POL	0.05	0.05	0.05	0.05	
26	POL	POL	POL	POL	POL	POL	POL	
27	POL	POL	0.07	0.05	0.05	0.05	0.07	
28	POL	POL	POL	POL	POL	POL	POL	
29	POL	POL	0.05	0.05	0.05	0.03	0.05	
30	POL	POL	POL	POL	POL	POL	POL	
31								

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Daryn McNeil		
	SIGNATURE: 		DATE: 5-4-22
	PHONE #: (541) 680-4513		CERT #: 09178

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Clarks Branch Water Association ID#: 41 00548 Month/Year: Apr-22 Disinfection *Giardia* Log Inactiv: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	POL	94	POL	POL	POL	POL	POL	57
2	POL	94	POL	POL	POL	POL	POL	57
3	0.9	94	84.6	17.0	7.60	35.0	YES	57
4	POL	94	POL	POL	POL	POL	POL	57
5	POL	94	POL	POL	POL	POL	POL	57
6	0.9	94	84.6	16.0	7.60	35.0	YES	57
7	1	94	94.0	16.0	7.50	30.0	YES	57
8	POL	94	POL	POL	POL	POL	POL	57
9	0.8	94	75.2	15.0	7.60	35.0	YES	57
10	POL	94	POL	POL	POL	POL	POL	57
11	0.8	94	75.2	15.0	7.60	35.0	YES	57
12	POL	94	POL	POL	POL	POL	POL	57
13	POL	94	POL	POL	POL	POL	POL	57
14	0.9	94	84.6	15.0	7.60	36.0	YES	57
15	0.8	94	75.2	14.0	7.50	44.0	YES	57
16	POL	94	POL	POL	POL	POL	POL	57
17	1	94	94.0	13.0	7.30	45.0	YES	57
18	POL	94	POL	POL	POL	POL	POL	57
19	POL	94	POL	POL	POL	POL	POL	57
20	1	94	94.0	13.0	7.50	45.0	YES	57
21	POL	94	POL	POL	POL	POL	POL	57
22	1	94	94.0	13.0	7.50	45.0	YES	57
23	POL	94	POL	POL	POL	POL	POL	57
24	POL	94	POL	POL	POL	POL	POL	57
25	0.8	94	75.2	13.0	7.10	44.0	YES	57
26	0.8	94	75.2	14.0	7.10	44.0	YES	57
27	0.8	94	75.2	13.0	6.60	44.0	YES	57
28	POL	94	POL	POL	POL	POL	POL	57
29	0.8	94	75.2	14.0	6.70	37.0	YES	57
30	POL	94	POL	POL	POL	POL	POL	57
31		94						57

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.