


OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **May-22**

System Name: **Clarks Branch Water Association** **ID#: 41** **00548** **WTP : TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	0.06	0.05	0.05	0.05	0.06
2	0.03	POL	POL	POL	POL	POL	0.03
3	POL	POL	POL	POL	POL	POL	POL
4	POL	0.05	0.06	0.05	0.05	0.05	0.06
5	POL	POL	POL	POL	POL	POL	POL
6	POL	POL	POL	POL	POL	0.05	0.05
7	0.05	0.05	POL	POL	POL	POL	0.05
8	POL	POL	POL	POL	0.05	0.05	0.05
9	0.05	0.03	POL	POL	0.07	0.05	0.07
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	POL	0.05	0.06	0.05	0.06
12	0.05	POL	POL	POL	POL	POL	0.05
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	POL	POL	0.05	0.05	0.05
15	0.05	0.03	0.03	0.08	0.05	0.05	0.08
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	0.05	0.05	0.05
18	0.05	0.05	POL	POL	POL	POL	0.05
19	POL	POL	POL	POL	0.05	0.05	0.05
20	0.05	0.05	0.05	POL	POL	POL	0.05
21	POL	POL	POL	0.06	0.05	0.05	0.06
22	0.05	0.05	POL	POL	POL	POL	0.05
23	POL	POL	POL	0.05	0.05	0.05	0.05
24	0.05	POL	POL	POL	POL	POL	0.05
25	POL	POL	POL	POL	0.06	0.05	0.06
26	0.05	0.05	POL	POL	POL	POL	0.05
27	POL	POL	POL	0.06	0.06	0.05	0.06
28	0.05	0.05	POL	POL	POL	POL	0.05
29	POL	POL	POL	0.06	0.05	0.05	0.06
30	0.05	POL	POL	POL	POL	POL	0.05
31	POL	POL	POL	POL	0.06	0.05	0.06

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No			

Notes:	PRINTED NAME: Daryn McNeil
	SIGNATURE:  DATE: 6-1-22
	PHONE #: (541) 680-4513 CERT #: 09178

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name: Clarks Branch Water Association

ID#: 41

00548

Month/Year: May-22

May-22

Disinfection *Giardia*
Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1	94	94.0	14.0	7.30	45.0	YES	57
2	POL	94	POL	POL	POL	POL	POL	57
3	POL	94	POL	POL	POL	POL	POL	57
4	1.2	94	112.8	14.0	6.90	38.0	YES	57
5	POL	94	POL	POL	POL	POL	POL	57
6	POL	94	POL	POL	POL	POL	POL	57
7	POL	94	POL	POL	POL	POL	POL	57
8	POL	94	POL	POL	POL	POL	POL	57
9	1	94	94.0	15.0	7.00	25.0	YES	57
10	POL	94	POL	POL	POL	POL	POL	57
11	1.1	94	103.4	15.0	6.90	25.0	YES	57
12	POL	94	POL	POL	POL	POL	POL	57
13	POL	94	POL	POL	POL	POL	POL	57
14	1	94	94.0	14.0	7.40	45.0	YES	57
15	1.1	94	103.4	15.0	7.10	31.0	YES	57
16	POL	94	POL	POL	POL	POL	POL	57
17	0.9	94	84.6	16.0	7.20	27.1	30	57
18	POL	94	POL	POL	POL	POL	POL	57
19	POL	94	POL	POL	POL	POL	POL	57
20	1	94	94.0	16.0	7.00	25.5	25	57
21	0.9	94	84.6	16.0	7.60	31.5	36	57
22	POL	94	POL	POL	POL	POL	POL	57
23	0.9	94	84.6	16.0	7.30	28.2	30	57
24	POL	94	POL	POL	POL	POL	POL	57
25	POL	94	POL	POL	POL	POL	POL	57
26	1.5	94	141.0	15.0	7.30	32.2	32	57
27	POL	94	POL	POL	POL	POL	POL	57
28	POL	94	POL	POL	POL	POL	POL	57
29	0.9	94	84.6	16.0	7.40	29.2	30	57
30	POL	94	POL	POL	POL	POL	POL	57
31	POL	94	POL	POL	POL	POL	POL	57

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.