


OHA - Drinking Water Services - Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: Jun-22

System Name:	Clarks Branch Water Association		ID#: 41	00548			WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.05	POL	POL	POL	0.06	0.05	0.06	
2	0.05	POL	POL	POL	POL	POL	0.05	
3	POL	POL	0.05	0.06	0.05	0.05	0.06	
4	0.05	POL	POL	POL	POL	POL	0.05	
5	POL	POL	0.06	0.05	0.05	0.05	0.06	
6	0.05	POL	POL	POL	POL	POL	0.05	
7	POL	POL	POL	POL	0.05	0.05	0.05	
8	0.03	0.03	0.03	POL	POL	POL	0.03	
9	POL	POL	POL	0.05	0.05	0.05	0.05	
10	0.03	POL	POL	POL	POL	POL	0.03	
11	POL	POL	0.05	0.05	0.05	0.05	0.05	
12	POL	POL	POL	POL	POL	POL	POL	
13	POL	POL	POL	POL	0.09	0.06	0.09	
14	0.05	0.05	POL	POL	POL	POL	0.05	
15	0.05	POL	POL	POL	0.05	0.05	0.05	
16	0.05	0.05	POL	POL	POL	POL	0.05	
17	POL	POL	POL	POL	0.05	0.05	0.05	
18	0.05	POL	POL	POL	POL	POL	0.05	
19	POL	POL	POL	POL	0.05	0.05	0.05	
20	0.05	POL	0.05	0.06	POL	POL	0.06	
21	POL	0.05	0.05	0.05	0.05	POL	0.05	
22	POL	POL	POL	POL	POL	0.06	0.06	
23	0.05	0.05	0.05	0.05	POL	POL	0.05	
24	POL	POL	POL	0.06	0.06	0.06	0.06	
25	0.05	0.05	0.05	POL	POL	POL	0.05	
26	0.06	0.06	0.06	POL	POL	POL	0.06	
27	POL	POL	0.07	0.06	0.06	0.05	0.07	
28	0.05	0.05	POL	POL	POL	POL	0.05	
29	POL	POL	0.05	0.05	0.05	0.05	0.05	
30	0.05	POL	POL	POL	0.05	0.05	0.05	
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Daryn McNeil
	SIGNATURE:  DATE: 7-1-22
	PHONE #: ( 541 ) 680-4513 CERT #: 09178

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Clarks Branch Water Association ID#: 41 00548 Month/Year: Jun-22 Disinfection *Giardia* Log Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1	1.2	94	112.8	16.0	7.10	31.0	Yes	57
2	POL	94	POL	POL	POL	POL	POL	57
3	1	94	94.0	16.0	7.00	25.5	YES	57
4	POL	94	POL	POL	POL	POL	POL	57
5	0.8	94	75.2	16.0	7.30	27.8	YES	57
6	POL	94	POL	POL	POL	POL	POL	57
7	POL	94	POL	POL	POL	POL	POL	57
8	1.4	94	131.6	16.0	7.20	28.7	YES	57
9	POL	94	POL	POL	POL	POL	POL	57
10	POL	94	POL	POL	POL	POL	POL	57
11	0.8	94	75.2	18.0	7.30	24.3	YES	57
12	POL	94	POL	POL	POL	POL	POL	57
13	0.8	94	75.2	18.0	7.20	23.5	YES	57
14	POL	94	POL	POL	POL	POL	POL	57
15	POL	94	POL	POL	POL	POL	POL	57
16	1	94	94.0	18.0	7.20	24.0	YES	57
17	POL	94	POL	POL	POL	POL	POL	57
18	POL	94	POL	POL	POL	POL	POL	57
19	POL	94	POL	POL	POL	POL	POL	57
20	0.8	94	75.2	18.0	7.20	23.5	YES	57
21	0.8	94	75.2	18.0	7.30	24.3	YES	57
22	POL	94	POL	POL	POL	POL	POL	57
23	1	94	94.0	17.0	7.30	26.6	YES	57
24	POL	94	POL	POL	POL	POL	POL	57
25	POL	94	POL	POL	POL	POL	POL	57
26	POL	94	POL	POL	POL	POL	POL	57
27	0.9	94	84.6	19.0	7.30	23.0	YES	57
28	POL	94	POL	POL	POL	POL	POL	57
29	0.9	94	84.6	20.0	7.30	21.5	YES	57
30	1.2	94	112.8	22.0	7.40	20.2	YES	57
31		94						57

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.