


OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Dec-22**

System Name:	Clarks Branch Water Association		ID#: 41	00548		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	POL	POL	0.06	0.06
2	0.09	0.06	POL	POL	POL	POL	0.09
3	POL	POL	POL	POL	0.09	0.06	0.09
4	0.06	0.04	POL	POL	POL	POL	0.06
5	POL	POL	POL	POL	POL	0.06	0.06
6	0.05	0.05	POL	POL	POL	POL	0.05
7	POL	POL	POL	POL	POL	0.05	0.05
8	0.05	0.05	POL	POL	POL	POL	0.05
9	POL	POL	POL	POL	0.05	0.05	0.05
10	0.05	POL	POL	POL	POL	POL	0.05
11	POL	POL	POL	POL	0.08	0.09	0.09
12	0.06	0.06	POL	POL	POL	POL	0.06
13	POL	POL	POL	POL	0.08	0.05	0.08
14	0.05	0.05	POL	POL	POL	POL	0.05
15	POL	POL	POL	POL	0.05	0.05	0.05
16	0.05	0.05	POL	0.05	0.05	POL	0.05
17	POL	POL	POL	POL	POL	POL	POL
18	POL	0.05	0.05	0.05	0.05	POL	0.05
19	POL	POL	POL	POL	POL	POL	POL
20	POL	0.05	0.05	0.05	POL	POL	0.05
21	POL	POL	POL	0.05	POL	POL	0.05
22	0.05	0.05	0.05	POL	POL	POL	0.05
23	POL	POL	POL	0.09	0.09	0.09	0.09
24	0.08	0.06	0.06	POL	POL	POL	0.08
25	POL	POL	POL	0.09	0.08	0.06	0.09
26	0.05	0.05	POL	POL	POL	POL	0.05
27	POL	POL	0.10	POL	POL	POL	0.10
28	POL	POL	0.12	0.18	POL	0.13	0.18
29	0.09	0.08	0.08	0.06	0.05	0.12	0.12
30	0.09	POL	POL	POL	POL	POL	0.09
31	POL	POL	POL	0.12	0.11	0.11	0.12

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE ² triggers Yes / No		

Notes:	PRINTED NAME: Daryn McNeil
	SIGNATURE:  DATE: 1-6-23
	PHONE #: (541) 680-4513 CERT #: 09178

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name: Clarks Branch Water Association ID#: 41 00548 Month/Year: Dec-22							Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1	94	94.0	11.0	7.60	54.0	YES	57
2	1	94	94.0	11.0	7.50	45.0	YES	57
3	0.9	94	84.6	8.0	7.80	72.0	YES	57
4	0.9	94	84.6	10.0	7.70	54.0	YES	57
5	1	94	94.0	10.0	7.60	54.0	YES	57
6	0.9	94	84.6	10.0	7.70	54.0	YES	57
7	1.1	94	103.4	10.0	7.60	55.0	YES	57
8	1.2	94	112.8	10.0	7.60	55.0	YES	57
9	1	94	94.0	10.0	7.70	54.0	YES	57
10	1	94	94.0	10.0	7.80	54.0	YES	57
11	1	94	94.0	11.0	7.50	45.0	YES	57
12	0.9	94	84.6	8.0	7.20	45.0	YES	57
13	1	94	94.0	10.0	7.50	45.0	YES	57
14	1	94	94.0	10.0	7.40	46.0	YES	57
15	1	94	94.0	11.0	7.60	54.0	YES	57
16	0.9	94	84.6	10.0	7.50	45.0	YES	57
17	0.9	94	84.6	10.0	7.60	54.0	YES	57
18	0.9	94	84.6	10.0	7.60	54.0	YES	57
19	1.1	94	103.4	10.0	7.60	55.0	YES	57
20	1	94	94.0	10.0	7.60	54.0	YES	57
21	1	94	94.0	10.0	7.70	54.0	YES	57
22	1	94	94.0	10.0	7.60	54.0	YES	57
23	1.2	94	112.8	10.0	7.60	55.0	YES	57
24	1.2	94	112.8	10.0	7.50	46.0	YES	57
25	1.1	94	103.4	10.0	7.60	55.0	YES	57
26	1	94	94.0	10.0	7.60	54.0	YES	57
27	1	94	94.0	9.0	7.60	72.0	YES	57
28	0.8	94	75.2	10.0	7.60	53.0	YES	57
29	0.9	94	84.6	10.0	7.50	44.0	YES	57
30	0.9	94	84.6	10.0	7.60	54.0	YES	57
31	1.2	94	112.8	11.0	7.30	46.0	YES	57