

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration**

System Name: TRI-CITY JW&SA ID #: OR4100549 WTP:-WTP-A Month/Year: FEB 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	OFF	OFF	OFF	OFF	OFF	.032	.042
2	.032	.032	.032	OFF	OFF	OFF	.032
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	.033	.032	.032	.032	.041
5	.032	OFF	OFF	OFF	OFF	OFF	.032
6	OFF	OFF	OFF	OFF	OFF	.034	.043
7	.033	.032	.032	.033	OFF	OFF	.033
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	.035	.033	.033	.038
10	.032	.032	OFF	OFF	OFF	OFF	.032
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	.035	.033	.032	.033	.032	OFF	.035
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	.036	.032	.031	.039
15	.031	.031	OFF	OFF	OFF	OFF	.031
16	OFF	OFF	OFF	OFF	OFF	OFF	.041
17	.034	.033	.033	.033	.033	OFF	.034
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	.035	.033	.036
20	.033	.033	OFF	OFF	OFF	OFF	.033
21	OFF	OFF	OFF	OFF	OFF	OFF	.046
22	.034	.033	.033	.033	OFF	OFF	.034
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	.035	.033	.033	.042
25	.033	.033	OFF	OFF	OFF	OFF	.054
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	.035	.034	.033	.034	.038
28	.034	OFF	OFF	OFF	OFF	OFF	.034
29							
30							
31							

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
Notes:	PRINTED NAME: BRIAN KELLY		
	SIGNATURE: <i>Brian Kelly</i>	DATE: 3-1-22	
	PHONE #: (541) 560-2581	CERT #: D-8441 J-8301	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

# OHA - Drinking Water Program – Surface Water Quality Data Form

TRI-CITY JW&SA ID #: OR4100549 WTP-: WTP-A Month/Year:

**FEB 2022**

Required Log Inactivation: **5**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/7/17 P	.85	60	51	8.4	7.3	29	YES	778
2/8:00 A	1.07	60	64	7.4	7.3	30	YES	778
3/ OFF	-	-	-	-	-	-	-	OFF
4/6:39 A	1.08	60	64	8.0	7.3	30	YES	774
5/1:00 A	1.10	60	66	7.5	7.6	37	YES	774
6/9:32 P	1.09	60	65	8.0	7.5	30	YES	776
7/10:10 A	1.10	60	66	7.5	7.4	30	YES	776
8/ OFF	-	-	-	-	-	-	-	OFF
9/11:09	1.05	60	63	8.1	7.4	30	YES	776
10/4:00 A	1.06	60	63	8.0	7.6	36	YES	776
11/ OFF	OFF	-	-	-	-	-	-	OFF
12/12:20 A	1.03	60	61	8.7	7.4	30	YES	783
13/ OFF	-	-	-	-	-	-	-	OFF
14/11:24 P	1.11	60	66	9.4	7.3	30	YES	813
15/3:00 A	1.10	60	66	8.8	7.3	30	YES	813
16/ OFF	-	-	-	-	-	-	-	OFF
17/12:51 A	1.10	60	66	9.3	7.1	30	YES	780
18/ OFF	-	-	-	-	-	-	-	OFF
19/12:49 P	1.01	60	61	9.2	7.2	30	YES	773
20/1:00 A	.99	60	59	9.0	7.7	36	YES	773
21/10:42 P	.96	60	57	9.3	7.7	36	YES	790
22/11:00 P	1.10	60	66	8.3	7.9	37	YES	790
23/ OFF	-	-	-	-	-	-	-	-
24/11:20 A	1.06	60	63	8.6	7.8	36	YES	774
25/12:29 P	.79	60	47	7.1	8.0	35	YES	814
26/ OFF	-	-	-	-	-	-	-	-
27/7:54 A	.89	60	53	7.5	7.8	36	YES	776
28/1:00 A	.96	60	57	7.8	8.4	43	YES	776
29/								
30/								
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.