

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: TRI-CITY JW&SA ID #: OR4100549 WTP:-WTP-A. Month/Year: NOV 23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.040	.039	.039	OFF	OFF	OFF	.040
2	OFF	OFF	OFF	OFF	OFF	.044	.052
3	.041	.040	.040	OFF	OFF	OFF	.041
4	OFF	OFF	OFF	OFF	.046	.042	.052
5	.042	.041	.042	OFF	OFF	OFF	.042
6	OFF	OFF	OFF	OFF	OFF	OFF	.057
7	.047	.040	.039	.039	OFF	OFF	.047
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	.042	.040	.039	.039	.038	.051
10	.038	OFF	OFF	OFF	OFF	OFF	.038
11	OFF	OFF	OFF	.041	.039	.038	.047
12	.038	OFF	OFF	OFF	OFF	OFF	.038
13	OFF	OFF	.041	.039	.038	.040	.179
14	.081	.038	OFF	OFF	OFF	OFF	.081
15	OFF	OFF	OFF	OFF	.042	.039	.052
16	.039	.038	OFF	OFF	OFF	OFF	.039
17	OFF	OFF	OFF	OFF	.040	.038	.048
18	.038	.038	.038	OFF	OFF	OFF	.038
19	OFF	OFF	OFF	OFF	OFF	.041	.049
20	.039	.038	.038	OFF	OFF	OFF	.039
21	OFF	OFF	OFF	OFF	.040	.039	.044
22	.038	.038	.038	OFF	OFF	OFF	.038
23	OFF	OFF	OFF	OFF	OFF	OFF	.051
24	.039	.038	.038	OFF	OFF	OFF	.039
25	OFF	OFF	OFF	OFF	OFF	.040	.048
26	.039	.038	.038	.038	.038	OFF	.039
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	.040	.039	.039	.039	.038	.115
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	.042	.039	.039	.042
31	.038	.038	OFF	OFF	OFF	OFF	.038

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / No			
Notes:	PRINTED NAME: BRIAN KELLY		
	SIGNATURE: <i>Brian Kelly</i>	DATE: 12-4-23	
	PHONE #: (541) 580-2581	CERT #: 0-8441 T-8301	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

TRI-CITY JW&SA ID #: OR4100549 WTP-: WTP-A Month/Year: **NOV 23**

Required Log
Inactivation: **5**

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required -CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/8:00 ^A	1.07	60	64	10.6	7.6	27	YES	767
2/9:36 ^A	1.30	60	78	11.3	7.5	23	YES	786
3/8:10 ^A	1.09	60	65	11.7	7.6	27	YES	786
4/5:49 ^P	1.32	60	79	12.4	7.5	23	YES	767
5/10:30 ^A	1.20	60	72	12.8	7.5	23	YES	767
6/9:06 ^P	1.29	60	77	13.2	7.4	23	YES	770
7/17:57 ^A	1.21	60	72	12.6	7.3	23	YES	770
8/ OFF	-	-	-	-	-	-	-	-
9/5:20 ^A	1.41	60	84	12.6	7.3	23	YES	767
10/12:30 ^A	1.17	60	70	10.9	7.5	23	Yes	767
11/11:51 ^A	1.33	60	79	11.4	7.4	23	Yes	763
12/12:30 ^A	1.16	60	69	10.9	7.6	28	Yes	763
13/8:49 ^A	1.29	60	77	11.4	7.5	23	YES	769
14/4:36 ^A	1.18	60	70	11.2	7.6	28	YES	769
15/4:04 ^P	1.36	60	81	12.0	7.6	28	YES	772
16/5:30 ^A	1.20	60	72	11.4	7.6	28	YES	772
17/2:02 ^P	1.40	60	84	12.0	7.6	28	YES	764
18/11:00 ^A	1.18	60	71	11.6	7.6	27	YES	764
19/9:25 ^P	1.31	60	78	11.6	7.4	23	YES	768
20/8:12 ^A	1.24	60	74	10.5	7.5	23	YES	768
21/4:30 ^P	1.43	60	85	10.7	7.5	23	YES	768
22/8:06 ^A	1.25	60	75	9.0	7.4	31	YES	768
23/11:24 ^P	1.42	60	85	9.7	7.4	31	YES	769
24/9:30 ^A	1.24	60	74	8.9	7.5	31	YES	769
25/9:20 ^P	1.40	60	84	9.0	7.5	31	YES	770
26/10:57 ^A	1.19	60	71	7.4	7.6	37	YES	770
27/ OFF	-	-	-	-	-	-	-	-
28/3:02 ^A	1.38	60	82	7.9	7.6	38	YES	774
29/ OFF	-	-	-	-	-	-	-	-
30/11:03 ^P	1.38	60	82	6.8	7.7	38	YES	776
31/11:03 ^A	1.74	60	68	5.8	7.7	37	YES	776

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.