

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: TRI-CITY JW&SA ID #: OR4100549 WTP:-WTP-A Month/Year:

DEC 23
DEC 23
Highest Reading of
the Day¹
[NTU]

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.038	.038	OFF	OFF	OFF	OFF	.038
2	OFF	OFF	OFF	OFF	OFF	.040	.056
3	.039	.039	OFF	OFF	OFF	OFF	.039
4	OFF	OFF	OFF	.040	.040	.040	.045
5	.039	.039	OFF	OFF	OFF	OFF	.039
6	OFF	OFF	OFF	OFF	OFF	.042	.045
7	.039	.039	.038	OFF	OFF	OFF	.039
8	OFF	OFF	OFF	OFF	.041	.039	.047
9	.038	.038	OFF	OFF	OFF	OFF	.038
10	OFF	OFF	OFF	OFF	OFF	.040	.133
11	.038	.038	.038	.038	OFF	OFF	.038
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	.044	.038	.038	.038	.038	.045
14	.037	OFF	OFF	OFF	OFF	OFF	.037
15	OFF	OFF	OFF	OFF	.040	.038	.045
16	.038	.038	OFF	OFF	OFF	OFF	.038
17	OFF	OFF	OFF	OFF	OFF	OFF	.118
18	.038	.038	.038	.038	.038	OFF	.038
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	.040	.038	.038	.095
21	.038	.038	OFF	OFF	OFF	OFF	.038
22	OFF	OFF	OFF	OFF	OFF	.038	.045
23	.037	.037	.037	OFF	OFF	OFF	.037
24	OFF	OFF	OFF	OFF	OFF	.039	.043
25	.038	.038	.038	OFF	OFF	OFF	.038
26	OFF	OFF	OFF	OFF	.039	.038	.039
27	.037	.038	.038	OFF	OFF	OFF	.038
28	OFF	OFF	OFF	OFF	OFF	.038	.038
29	.038	.038	.038	OFF	OFF	OFF	.038
30	OFF	OFF	OFF	OFF	.040	.037	.040
31	.037	.037	.037	.037	OFF	OFF	.037

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	Notes:		
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	PRINTED NAME: BRIAN KELLY		
	SIGNATURE: <i>Brian Kelly</i>	DATE: 1-2-24	
	PHONE #: (541) 560-2581	CERT #: D-8441	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

TRI-CITY JW&SA ID #: OR4100549 WTP-: WTP-A Month/Year:

DEC 23

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
11/1:03 A	1.14	60	68	5.8	7.7	37	YES	776
2/5:50 P	1.25	60	75	6.7	7.7	37	YES	778
3/1:02 A	1.23	60	74	6.6	7.6	37	YES	778
4/12:09 P	1.40	60	84	7.4	7.5	31	YES	777
5/5:01 A	1.40	60	84	9.7	7.3	31	YES	777
6/8:09 P	1.59	60	95	10.1	7.3	24	Yes	787
7/7:00 A	1.35	60	81	10.0	7.4	23	Yes	787
8/4:15 P	1.51	60	90	10.1	7.4	24	YES	787
9/6:00 A	1.37	60	82	8.7	7.4	31	Yes	787
10/8:27 P	1.60	60	96	9.1	7.4	32	YES	779
11/8:15 A	1.38	60	82	8.3	7.4	31	YES	779
12/ OFF	-	-	-	-	-	-	-	-
13/5:55 A	1.65	60	99	9.2	7.4	32	YES	775
14/12:20 A	1.33	60	79	8.5	7.4	31	YES	775
15/3:33 P	1.54	60	92	9.0	7.4	32	YES	785
16/6:30 A	1.26	60	75	7.9	7.5	31	YES	785
17/10:37 P	1.31	60	78	8.4	7.5	31	YES	765
18/8:30 A	1.31	60	78	7.1	7.5	31	YES	765
19/ OFF	-	-	-	-	-	-	-	-
20/11:22 A	1.50	60	90	8.0	7.5	32	YES	774
21/3:00 A	1.25	60	75	9.1	7.5	31	Yes	774
22/5:58 P	1.45	60	87	9.5	7.5	31	Yes	773
23/7:00 A	1.21	60	72	8.7	7.5	31	Yes	773
24/8:37 P	1.37	60	82	8.7	7.5	31	Yes	772
25/7:00 A	1.20	60	72	7.4	7.6	37	Yes	772
26/4:04 P	1.44	60	86	8.1	7.6	38	YES	773
27/1:00 A	1.18	60	70	7.7	7.7	37	YES	773
28/4:06 P	1.45	60	87	8.2	7.5	31	YES	782
29/1:00 A	1.24	60	74	8.1	7.5	31	YES	782
30/6:50 P	1.40	60	84	8.8	7.5	31	YES	777
31/1:12 A	1.21	60	73	9.2	7.6	37	YES	777

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.