

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration**

System Name: TRI-CITY JW&SA ID #: OR4100549 WTP:-WTP-A Month/Year:

MAR 24

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	.042	.038	.038	.038	.037	.042
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	.037	.037	.037	.042
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	.039	.038	.038	.101
7	.038	.038	.037	OFF	OFF	OFF	.038
8	OFF	OFF	OFF	OFF	OFF	.039	.043
9	.037	.037	.037	.037	OFF	OFF	.037
10	OFF	OFF	OFF	OFF	OFF	OFF	.055
11	.041	.037	.037	OFF	OFF	OFF	.041
12	OFF	OFF	OFF	OFF	OFF	.037	.044
13	.037	.036	.035	.035	OFF	OFF	.037
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	.042	.024	.023	.034	.035	OFF	.042
16	OFF	OFF	OFF	OFF	OFF	.038	.043
17	.037	.037	.037	.038	OFF	OFF	.037
18	OFF	OFF	OFF	OFF	OFF	.043	.052
19	.039	.038	.038	.038	.038	OFF	.039
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	.041	.039	.038	.038	.045
22	.037	OFF	OFF	OFF	OFF	OFF	.037
23	OFF	OFF	OFF	OFF	.040	.038	.064
24	.037	OFF	OFF	OFF	OFF	OFF	.037
25	OFF	OFF	OFF	.040	.039	.038	.045
26	.037	.037	OFF	OFF	OFF	OFF	.038
27	OFF	OFF	OFF	OFF	OFF	.042	.042
28	.038	.038	.038	OFF	OFF	OFF	.038
29	OFF	OFF	OFF	OFF	OFF	.039	.040
30	.038	.038	.038	.038	OFF	OFF	.038
31	OFF	OFF	OFF	OFF	OFF	OFF	.048

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No ²		
Notes:	PRINTED NAME: BRIAN KELLY	
	SIGNATURE: <i>Brian Kelly</i>	DATE: 4-1-24
	PHONE #: (541) 582-2581	CERT #: D-8441 T-8301

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

TRI-CITY JW&SA ID #: OR4100549 WTP-: WTP-A Month/Year:

MAR 24

Required Log Inactivation: .5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 / OFF	-	-	-	-	-	-	-	-
2 / 2:07 ^A	1.49	60	87	8.7	7.5	31	YES	777
3 / OFF	-	-	-	-	-	-	-	-
4 / 10:05 ^A	1.36	60	81	8.2	7.3	31	YES	775
5 / OFF	-	-	-	-	-	-	-	-
6 / 12:36 ^P	1.35	60	81	7.8	7.4	31	YES	771
7 / 9:06 ^A	1.18	60	70	7.2	7.3	31	YES	771
8 / 8:34 ^P	1.34	60	80	7.5	7.4	31	YES	769
9 / 9:56 ^A	1.22	60	73	7.7	7.4	31	YES	769
10 / 11:50 ^A	1.37	60	82	8.0	7.4	31	YES	773
11 / 8:27 ^A	1.24	60	74	7.9	7.4	31	YES	773
12 / 9:05 ^P	1.44	60	86	8.3	7.3	31	YES	773
13 / 7:38 ^A	1.26	60	75	8.3	7.3	31	YES	773
14 / OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15 / 1:52 ^A	1.44	60	86	8.5	7.4	31	YES	778
16 / 6:52 ^P	1.31	60	78	9.1	7.5	31	YES	778
17 / 9:00 ^A	1.24	60	74	8.6	7.4	31	YES	778
18 / 9:40 ^A	1.42	60	85	9.2	7.4	31	YES	773
19 / 10:35 ^A	1.26	60	75	8.9	7.3	31	YES	773
20 / OFF	-	-	-	-	-	-	-	-
21 / 7:19 ^A	1.46	60	87	9.9	7.4	31	YES	775
22 / 12:05 ^A	1.20	60	72	10.1	7.5	23	YES	775
23 / 2:35 ^P	1.42	60	85	10.4	7.5	23	Yes	778
24 / 2:00 ^A	1.19	60	71	9.4	7.5	31	Yes	778
25 / 1:16 ^P	1.45	60	87	9.8	7.5	31	Yes	770
26 / 7:00 ^A	1.26	60	75	9.4	7.5	31	Yes	770
27 / 8:03 ^A	1.49	60	89	9.8	7.5	31	yes	775
28 / 1:00 ^A	1.25	60	75	9.7	7.5	31	yes	775
29 / 6:23 ^P	1.46	60	87	9.8	7.5	31	YES	780
30 / 1:07 ^A	1.26	60	75	9.4	7.5	31	YES	780
31 / 10:48 ^P	1.50	60	90	9.2	7.4	32	YES	777

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.