

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas  
Conventional or Direct Filtration**

System Name: TRI-CITY JW&SA ID #: OR4100549 WTP:-WTP-A Month/Year: JUN 24

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	.041	.038	.036	.036	.036	.124
2	.037	OFF	OFF	OFF	OFF	.046	.056
3	.038	.038	.037	OFF	OFF	OFF	.038
4	OFF	OFF	OFF	.042	.037	.037	.056
5	.038	.038	.038	OFF	OFF	OFF	.038
6	OFF	OFF	.037	.037	.038	.037	.048
7	.037	.037	.039	.040	OFF	OFF	.041
8	OFF	OFF	.042	.038	.037	.032	.063
9	.037	OFF	OFF	OFF	.036	.030	.048
10	.037	.038	.039	.039	OFF	OFF	.039
11	OFF	OFF	.040	.038	.039	.039	.056
12	.042	.036	OFF	OFF	OFF	OFF	.046
13	.035	.035	.035	.030	OFF	OFF	.035
14	OFF	OFF	.041	.036	.039	.039	.047
15	.043	OFF	OFF	OFF	OFF	.047	.057
16	.037	.036	.037	OFF	OFF	OFF	.037
17	OFF	.039	.029	.036	.036	OFF	.096
18	OFF	OFF	OFF	.043	.038	.035	.045
19	.029	.038	.039	.041	OFF	OFF	.041
20	OFF	.039	.039	.039	.040	.043	.056
21	OFF	OFF	OFF	OFF	OFF	.041	.045
22	.036	.038	.039	.039	OFF	OFF	.039
23	OFF	OFF	.039	.035	.036	.038	.039
24	.039	.035	OFF	OFF	OFF	OFF	.046
25	.035	.035	.034	.037	.039	.038	.039
26	OFF	OFF	OFF	OFF	.035	.037	.045
27	.028	.038	.037	.038	OFF	OFF	.038
28	OFF	OFF	.045	.040	.042	.042	.053
29	.041	.040	OFF	OFF	OFF	.054	.069
30	.064	.062	.059	OFF	OFF	.057	.064
31							

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl <sub>2</sub> residuals at entry point $\geq$ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings $\leq$ 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes / No <sup>2</sup>			
Notes:	PRINTED NAME: <b>BRIAN KELLY</b>		
	SIGNATURE: <i>Brian Kelly</i>	DATE: <b>7-1-24</b>	
	PHONE #: (541) 580-2581	CERT #: <b>T. 8301 D. 8441</b>	

including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

# OHA - Drinking Water Program – Surface Water Quality Data Form

TRI-CITY JW&SA ID #: OR4100549 WTP-: WTP-A Month/Year:

JUN 24

Required Log Inactivation: **5**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/14:15 A	1.15	60	69	17.2	7.3	15	YES	812
2/19:26 P	1.08	60	64	18.6	7.4	15	YES	802
3/19:50 A	1.22	60	73	17.7	7.3	15	YES	802
4/11:00 A	1.09	60	65	17.8	7.3	15	YES	801
5/17:45 A	1.20	60	72	18.4	7.3	15	YES	801
6/16:21 A	1.13	60	67	18.1	7.6	19	YES	801
7/19:15 A	1.17	60	70	19.9	7.6	19	YES	801
8/15:37 A	.98	60	58	19.7	7.5	15	YES	818
9/12:15 P	1.09	60	65	21.4	7.5	11	YES	838
10/8:45 A	1.16	60	69	21.3	7.5	12	YES	838
11/7:15 A	1.10	60	66	21.0	7.4	12	YES	907
12/10:08 P	1.09	60	65	21.6	7.4	11	YES	906
13/3:15 P	1.21	60	72	21.0	7.4	12	YES	906
14/8:17 A	1.11	60	66	20.3	7.4	12	Yes	902
15/9:40 P	1.09	60	65	20.5	7.4	11	Yes	903
16/7:00 A	1.22	60	73	19.5	7.4	15	Yes	903
17/3:17 A	1.14	60	68	18.9	7.4	15	Yes	919
18/1:35 P	1.12	60	67	18.2	7.4	15	YES	965
19/8:38 A	1.25	60	75	18.7	7.4	15	YES	905
20/2:28 A	1.16	60	69	18.9	7.4	15	YES	909
21/6:24 P	1.09	60	65	22.1	7.5	11	YES	914
22/1:26 A	1.20	60	72	22.7	7.5	11	YES	914
23/5:30 A	1.06	60	63	22.0	7.4	11	YES	908
24/10:45 P	1.10	60	66	22.0	7.4	12	YES	908
25/2:00 P	1.21	60	72	22.3	7.4	12	YES	908
26/4:08 P	1.07	60	64	23.6	7.5	11	YES	905
27/12:30 P	1.18	60	70	21.8	7.6	14	YES	905
28/8:04 A	1.05	60	63	21.4	7.5	11	YES	906
29/8:12 P	.99	60	59	23.1	7.4	11	YES	912
30/9:32 P	.97	60	58	22.5	7.4	11	YES	917
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.