

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Douglas
Conventional or Direct Filtration

System Name: TRI-CITY JW&SA ID #: OR4100549 WTP:-WTP-A Month/Year:

JUN 25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	.039	.037	.088
2	.042	.038	.044	.043	OFF	OFF	.044
3	OFF	OFF	.053	.045	.046	.045	.058
4	.044	.044	OFF	OFF	OFF	.052	.088
5	.046	.045	.044	.044	OFF	OFF	.046
6	OFF	OFF	OFF	.048	.044	.044	.056
7	.044	.043	OFF	OFF	OFF	.054	.078
8	.047	.043	.044	.048	.050	.047	.056
9	OFF	OFF	OFF	OFF	.063	.049	.067
10	.047	.044	.036	.047	OFF	OFF	.047
11	OFF	OFF	.049	.046	.047	.049	.096
12	.049	.047	OFF	OFF	OFF	.054	.056
13	.045	.041	.042	.042	OFF	OFF	.045
14	OFF	OFF	OFF	.055	.044	.047	.057
15	.046	.043	OFF	OFF	OFF	OFF	.059
16	.046	.041	.041	.041	OFF	OFF	.046
17	OFF	OFF	.042	.038	.035	.038	.071
18	.047	OFF	OFF	OFF	OFF	.054	.060
19	.044	.043	.042	.042	OFF	OFF	.044
20	OFF	OFF	OFF	.044	.045	.046	.075
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	.037	.036	.035	OFF	OFF	.063
23	OFF	OFF	OFF	OFF	.049	.044	.054
24	.047	.044	.045	OFF	OFF	OFF	.047
25	OFF	OFF	.047	.045	.042	.043	.055
26	.047	.040	OFF	OFF	OFF	OFF	.079
27	.051	.047	.047	.046	OFF	OFF	.051
28	OFF	OFF	.052	.046	.047	.048	.093
29	.050	OFF	OFF	OFF	OFF	.054	.070
30	.048	.046	.045	.047	OFF	OFF	.048
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / No	CT's met everyday? (see back) ☒ Yes / No	All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? ☒ Yes / No	
All the 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / No			
All turbidity readings < IFE ² triggers? ☒ Yes / No ²			
Notes:	PRINTED NAME: BRIAN KELLY		
	SIGNATURE: <i>Brian Kelly</i>	DATE: 7-1-25	
	PHONE #: (541) 580-2581	CERT #: D-8441 T-8301	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

TRI-CITY JW&SA ID #: OR4100549 WTP-: WTP-A Month/Year:

JUN 25

Required Log Inactivation: .5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/2:26P	1.11	60	66	20.3	7.3	12	YES	810
2/10:44A	1.21	60	72	19.6	7.3	15	YES	810
3/9:19A	1.08	60	64	19.3	7.3	15	YES	886
4/9:31P	1.05	60	63	20.3	7.4	11	YES	884
5/2:27P	1.15	60	69	20.2	7.4	12	YES	884
6/11:12A	1.06	60	63	20.0	7.3	11	YES	887
7/9:36A	1.06	60	63	21.6	7.4	11	YES	890
8/9:32A	1.14	60	68	22.6	7.4	12	YES	890
9/4:33P	.94	60	56	24.8	7.4	11	YES	887
10/11:03A	1.12	60	67	24.7	7.4	12	YES	887
11/6:40A	.95	60	57	24.1	7.3	11	YES	880
12/7:44P	.99	60	59	23.5	7.5	11	YES	884
13/1:05A	1.09	60	65	23.3	7.5	11	YES	884
14/11:48A	1.04	60	62	21.2	7.4	11	YES	889
15/9:54P	1.02	60	61	20.5	7.5	11	YES	895
16/9:15A	1.11	60	66	20.5	7.5	12	YES	895
17/7:43A	1.01	60	60	20.3	7.3	11	YES	914
18/8:29P	.99	60	59	22.0	7.3	11	YES	896
19/9:07A	1.11	60	66	20.9	7.2	12	YES	896
20/9:51A	1.03	60	61	20.6	7.2	11	YES	907
21/ OFF	—	—	—	—	—	—	—	—
22/2:09A	1.00	60	60	19.8	7.3	15	YES	908
23/3:27P	1.02	60	61	18.8	7.2	15	YES	904
24/11:08A	1.15	60	63	20.3	7.2	12	YES	904
25/7:23A	1.05	60	63	20.1	7.2	11	YES	896
26/10:14A	.99	60	59	22.5	7.3	11	YES	896
27/7:57A	1.12	60	67	22.4	7.3	12	YES	896
28/7:11A	.95	60	57	22.0	7.2	11	Yes	898
29/7:10P	.89	60	53	24.6	7.3	11	Yes	895
30/2:14P	1.14	60	68	24.2	7.2	12	YES	895
31/								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf