

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Oct-21

System Name: City Of Myrtle Creek		ID#: 41 00550B		WTP : TP - B			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	NIS	NIS	NIS	0.02	NIS	NIS	0.02
2	NIS	NIS	NIS	NIS	NIS	NIS	NIS
3	NIS	NIS	NIS	NIS	NIS	NIS	NIS
4	NIS	NIS	NIS	NIS	NIS	NIS	NIS
5	NIS	NIS	NIS	0.02	0.02	0.02	0.02
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02
12	0.02	0.02	0.02	0.02	NIS	NIS	0.02
13	NIS	NIS	NIS	NIS	NIS	NIS	NIS
14	NIS	NIS	NIS	NIS	NIS	NIS	NIS
15	NIS	NIS	NIS	0.02	0.02	0.02	0.02
16	0.02	0.02	0.02	0.02	NIS	NIS	0.02
17	NIS	NIS	NIS	NIS	NIS	NIS	NIS
18	NIS	NIS	NIS	NIS	0.02	0.01	0.02
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	NIS	NIS	NIS	0.02	0.02	0.02	0.02
21	NIS	NIS	NIS	NIS	NIS	NIS	NIS
22	NIS	NIS	NIS	NIS	NIS	NIS	NIS
23	NIS	NIS	NIS	NIS	NIS	NIS	NIS
24	NIS	NIS	NIS	NIS	NIS	NIS	NIS
25	NIS	NIS	NIS	NIS	0.03	0.03	0.03
26	NIS	NIS	NIS	NIS	NIS	NIS	NIS
27	NIS	NIS	NIS	NIS	NIS	NIS	NIS
28	NIS	NIS	NIS	NIS	NIS	NIS	NIS
29	NIS	NIS	NIS	NIS	NIS	NIS	NIS
30	NIS	NIS	NIS	NIS	NIS	NIS	NIS
31	NIS	NIS	NIS	NIS	NIS	NIS	NIS

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Sean Negherbon	
	SIGNATURE: <i>Sean Negherbon</i>	DATE: 11/4/2021
	PHONE #: (541) 863-3171	CERT #: 6111

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

B

System Name: City Of Myrtle Creek ID#: 41 00550B Month/Year: Oct-21

Disinfection
Giardia Log
Inactiv:

0.5

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	18:40	0.38	115	43.7	15.6	7.90	17.0	YES
2	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
3	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
4	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
5	21:40	1.49	115	171.4	14.90	8.00	21.0	YES
6	23:56	1.19	115	136.9	14.90	7.90	19.5	YES
7	12:02	1.15	115	132.3	14.50	8.00	20.7	YES
8	10:09	1.16	115	133.4	14.00	8.00	21.5	YES
9	23:54	0.97	115	111.6	14.10	7.80	19.4	YES
10	5:06	0.89	115	102.4	14.30	7.90	19.7	YES
11	11:49	1.12	115	128.8	13.80	7.90	20.9	YES
12	11:02	0.49	115	56.4	13.40	7.90	19.9	YES
13	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
14	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
15	19:21	0.41	115	47.2	13.50	8.00	20.4	YES
16	11:48	1.89	115	217.4	13.40	7.90	23.4	YES
17	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
18	21:36	0.40	115	46.0	14.50	8.00	19.0	YES
19	13:20	0.33	115	38.0	13.60	7.90	19.3	YES
20	13:49	1.43	115	164.5	13.10	8.10	24.4	YES
21	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
22	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
23	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
24	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
25	13:10	0.21	115	24.2	14.40	7.80	17.4	YES
26	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
27	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
28	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
29	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
30	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS
31	NIS	NIS	NIS	NIS	NIS	NIS	NIS	NIS

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012