

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: March 2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	0.04	0.09	0.04	----	0.09
2	----	----	----	----	----	----	----
3	----	----	----	----	----	----	----
4	----	----	0.04	----	0.04	----	0.04
5	----	----	0.04	0.06	0.04	----	0.06
6	----	----	0.04	0.08	0.04	----	0.08
7	----	----	----	0.15	0.04	0.04	0.15
8	----	----	0.04	0.08	0.04	----	0.08
9	----	----	----	----	----	----	----
10	----	----	----	----	----	----	----
11	----	----	0.04	----	0.04	----	0.04
12	----	----	0.02	0.03	0.04	----	0.04
13	----	----	0.03	0.03	0.04	----	0.04
14	----	----	0.04	0.04	0.03	----	0.04
15	----	----	0.03	0.05	0.03	0.03	0.05
16	----	----	----	----	----	----	----
17	----	----	----	----	----	----	----
18	----	----	0.03	0.04	0.03	----	0.04
19	----	----	0.03	0.03	0.03	----	0.03
20	----	----	0.03	0.03	0.03	----	0.03
21	----	----	0.03	0.03	0.03	0.03	0.03
22	----	----	----	0.03	0.03	0.03	0.03
23	----	----	----	----	----	----	----
24	----	----	----	----	----	----	----
25	----	----	0.03	0.03	0.03	----	0.03
26	----	----	0.03	0.03	0.03	----	0.03
27	----	----	0.04	0.03	0.03	----	0.04
28	----	----	0.03	0.03	0.03	----	0.03
29	----	----	0.03	0.03	----	----	0.03
30	----	----	----	----	----	----	----
31	----	----	----	----	----	----	----

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
All the 4 hour turbidity readings ≤ 1 NTU? Yes/No		
All turbidity readings < IFE ² triggers? Yes/No²		
Notes:	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: April 1, 2024
	PHONE #: (541) 572-2589	CERT #: 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: March 2024 Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1/ 11 AM	1.3	105	141	10.0	8.5	67	Yes	850
2/ 11 AM	----	----	----	----	----	----	----	----
3/ 11 AM	----	----	----	----	----	----	----	----
4/ 11 AM	1.1	105	111	8.9	8.7	77	Yes	850
5/ 11 AM	1.3	105	135	7.8	8.7	86	Yes	850
6/ 11 AM	1.3	105	137	8.9	8.6	77	Yes	850
7/ 11 AM	1.2	105	130	12.2	8.4	56	Yes	850
8/ 11 AM	1.2	105	127	11.7	8.4	58	Yes	850
9/ 11 AM	----	----	----	----	----	----	----	----
10/ 11 AM	----	----	----	----	----	----	----	----
11/ 11 AM	1.0	105	103	11.1	8.4	60	Yes	850
12/ 11 AM	1.2	105	122	9.4	8.7	75	Yes	850
13/ 11 AM	1.2	105	128	8.9	8.8	80	Yes	850
14/ 11 AM	1.3	105	132	8.9	8.9	84	Yes	850
15/ 11 AM	1.4	105	144	9.4	8.8	79	Yes	850
16/ 11 AM	----	----	----	----	----	----	----	----
17/ 11 AM	----	----	----	----	----	----	----	----
18/ 11 AM	1.1	105	112	10.6	8.5	65	Yes	850
19/ 11 AM	1.2	105	126	10.0	8.2	61	Yes	850
20/ 11 AM	1.3	105	133	10.0	8.2	60	Yes	850
21/ 11 AM	1.2	105	130	10.0	8.2	60	Yes	850
22/ 11 AM	1.4	105	143	10.6	8.2	58	Yes	850
23/ 11 AM	----	----	----	----	----	----	----	----
24/ 11 AM	----	----	----	----	----	----	----	----
25/ 11 AM	1.2	105	126	10.6	8.1	56	Yes	850
26/ 11 AM	1.2	105	130	13.3	8.1	46	Yes	850
27/ 11 AM	1.2	105	123	10.6	8.0	53	Yes	850
28/ 11 AM	1.2	105	124	10.6	8.0	54	Yes	850
29/ 11 AM	1.3	105	135	10.0	8.0	57	Yes	850
30/ 11 AM	----	----	----	----	----	----	----	----
31/ 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012