

## OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: April 2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	----	----	0.03	0.04	0.04	----	0.04
2	----	----	0.03	0.03	0.03	----	0.03
3	----	----	0.03	0.03	0.03	----	0.03
4	----	----	0.03	0.03	0.03	----	0.03
5	----	----	0.03	0.03	0.03	----	0.03
6	----	----	----	----	----	----	----
7	----	----	----	----	----	----	----
8	----	----	0.03	----	0.03	----	0.03
9	----	----	0.04	0.03	----	----	0.04
10	----	----	0.04	0.02	----	----	0.04
11	----	----	0.02	0.02	----	----	0.02
12	----	----	0.03	0.01	----	----	0.03
13	----	----	----	----	----	----	----
14	----	----	----	----	----	----	----
15	----	----	0.03	0.01	0.01	----	0.03
16	----	----	0.02	0.02	----	----	0.02
17	----	----	0.02	----	----	----	0.02
18	----	----	0.02	0.02	----	----	0.02
19	----	----	0.02	----	----	----	0.02
20	----	----	----	----	----	----	----
21	----	----	----	----	----	----	----
22	----	----	0.02	0.02	0.02	----	0.02
23	----	----	0.02	0.02	----	----	0.02
24	----	----	0.02	0.02	----	----	0.02
25	----	----	0.02	----	----	----	0.02
26	----	----	0.02	----	----	----	0.02
27	----	----	----	----	----	----	----
28	----	----	----	----	----	----	----
29	----	----	0.03	0.02	0.02	----	0.03
30	----	----	----	0.02	----	----	0.02
31	----	----	----	----	----	----	----

<b>Conventional or Direct Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes / No</b>
All the 4 hour turbidity readings ≤ 1 NTU? <b>Yes / No</b>		
All turbidity readings < IFE <sup>2</sup> triggers? <b>Yes / No<sup>2</sup></b>		
<b>Notes:</b>	<b>PRINTED NAME:</b> <i>Ryan A. Sherman</i>	
	<b>SIGNATURE:</b> <i>Ryan A. Sherman</i>	<b>DATE:</b> May 1, 2024
	<b>PHONE #:</b> (541) 572-2589	<b>CERT #:</b> 9184

<sup>1</sup> Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

**MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: April 2024** Required Log Inactivation: 1

Date / Time	Min. Cl <sub>2</sub> Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	<b>C x T</b>	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	105	119	10.9	7.9	50	Yes	850
2 / 11 AM	1.2	105	122	11.1	7.9	50	Yes	850
3 / 11 AM	1.2	105	123	11.1	8.1	53	Yes	850
4 / 11 AM	1.2	105	125	11.1	8.1	54	Yes	850
5 / 11 AM	1.2	105	128	11.1	8.2	56	Yes	850
6 / 11 AM	----	----	----	----	----	----	----	----
7 / 11 AM	----	----	----	----	----	----	----	----
8 / 11 AM	1.0	105	106	11.1	8.2	56	Yes	850
9 / 11 AM	1.2	105	122	11.1	8.3	58	Yes	850
10 / 11 AM	1.1	105	119	11.1	8.1	54	Yes	850
11 / 11 AM	1.1	105	120	11.7	8.1	52	Yes	850
12 / 11 AM	1.1	105	119	12.2	8.1	50	Yes	850
13 / 11 AM	----	----	----	----	----	----	----	----
14 / 11 AM	----	----	----	----	----	----	----	----
15 / 11 AM	1.0	105	105	12.8	8.1	47	Yes	850
16 / 11 AM	0.8	105	83	13.9	8.0	42	Yes	850
17 / 11 AM	1.0	105	105	14.4	7.7	37	Yes	850
18 / 11 AM	1.1	105	110	15.0	7.8	37	Yes	850
19 / 11 AM	1.1	105	116	15.0	7.8	38	Yes	850
20 / 11 AM	----	----	----	----	----	----	----	----
21 / 11 AM	----	----	----	----	----	----	----	----
22 / 11 AM	1.0	105	109	15.6	7.9	36	Yes	850
23 / 11 AM	1.1	105	113	15.6	7.9	37	Yes	850
24 / 11 AM	1.1	105	116	15.6	7.9	37	Yes	850
25 / 11 AM	1.1	105	116	15.6	7.9	36	Yes	850
26 / 11 AM	1.1	105	116	15.0	7.9	39	Yes	850
27 / 11 AM	----	----	----	----	----	----	----	----
28 / 11 AM	----	----	----	----	----	----	----	----
29 / 11 AM	0.9	105	99	12.8	7.9	43	Yes	850
30 / 11 AM	1.1	105	113	13.9	8.5	51	Yes	850
31 / 11 AM	----	----	----	----	----	----	----	----

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012