

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: May 2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	---	---	0.02	---	---	---	0.02
2	----	----	0.02	----	----	----	0.02
3	----	----	0.02	0.02	----	----	0.02
4	----	----	----	----	----	----	----
5	----	----	----	----	----	----	----
6	----	----	0.02	0.02	0.02	----	0.02
7	----	----	0.02	0.02	0.02	----	0.02
8	----	----	----	0.02	0.02	----	0.02
9	----	----	0.02	0.02	0.02	----	0.02
10	----	----	0.02	0.02	----	----	0.02
11	----	----	----	----	----	----	----
12	----	----	----	----	----	----	----
13	----	----	0.02	0.02	----	----	0.02
14	----	----	----	0.02	----	----	0.02
15	----	----	0.02	0.02	----	----	0.02
16	----	----	----	----	----	----	----
17	----	----	0.03	0.03	0.03	----	0.03
18	----	----	----	----	----	----	----
19	----	----	----	----	----	----	----
20	----	----	0.03	0.03	0.03	----	0.03
21	----	----	0.03	0.03	----	----	0.03
22	----	----	----	----	----	----	----
23	----	----	0.03	0.03	0.03	----	0.03
24	----	----	0.03	0.03	----	----	0.03
25	----	----	----	----	----	----	----
26	----	----	----	----	----	----	----
27	----	----	0.04	0.03	----	----	0.04
28	----	----	0.04	0.03	0.03	----	0.04
29	----	----	0.03	0.03	0.03	----	0.03
30	----	----	----	0.03	----	----	0.03
31	----	----	0.03	0.03	----	----	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / No ²		
Notes:	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: June 3, 2024
	PHONE #: (541) 572-2589	CERT #: 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: May 2024 Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	105	117	13.9	7.7	39	Yes	850
2 / 11 AM	1.2	105	121	13.9	7.8	40	Yes	850
3 / 11 AM	1.2	105	130	14.4	7.9	41	Yes	850
4 / 11 AM	----	----	----	----	----	----	----	----
5 / 11 AM	----	----	----	----	----	----	----	----
6 / 11 AM	0.8	105	84	13.9	8.2	44	Yes	850
7 / 11 AM	0.8	105	88	13.3	8.2	47	Yes	850
8 / 11 AM	1.0	105	102	13.9	8.3	47	Yes	850
9 / 11 AM	1.1	105	114	13.9	8.4	50	Yes	850
10 / 11 AM	1.2	105	121	14.4	8.5	51	Yes	850
11 / 11 AM	----	----	----	----	----	----	----	----
12 / 11 AM	----	----	----	----	----	----	----	----
13 / 11 AM	1.0	105	104	13.9	8.0	42	Yes	850
14 / 11 AM	1.1	105	116	13.9	7.9	42	Yes	850
15 / 11 AM	1.1	105	110	13.9	7.8	39	Yes	850
16 / 11 AM	----	----	----	----	----	----	----	----
17 / 11 AM	0.8	105	86	15.0	7.9	37	Yes	850
18 / 11 AM	----	----	----	----	----	----	----	----
19 / 11 AM	----	----	----	----	----	----	----	----
20 / 11 AM	0.7	105	78	15.0	7.9	37	Yes	850
21 / 11 AM	1.1	105	116	15.0	7.8	37	Yes	850
22 / 11 AM	----	----	----	----	----	----	----	----
23 / 11 AM	1.1	105	113	15.0	7.8	36	Yes	850
24 / 11 AM	1.2	105	122	15.0	7.8	37	Yes	850
25 / 11 AM	----	----	----	----	----	----	----	----
26 / 11 AM	----	----	----	----	----	----	----	----
27 / 11 AM	1.1	105	111	15.6	7.9	36	Yes	850
28 / 11 AM	1.1	105	116	15.6	7.8	36	Yes	850
29 / 11 AM	1.2	105	122	15.6	7.9	37	Yes	850
30 / 11 AM	1.2	105	130	15.6	7.8	36	Yes	850
31 / 11 AM	1.2	105	126	15.6	7.8	37	Yes	850

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012