

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS  
Conventional or Direct Filtration**

**System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: September 2024**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	----	----	----	----	----	----	----
2	----	----	0.05	0.03	0.03	----	0.05
3	----	----	0.03	0.03	0.03	----	0.03
4	----	----	0.03	0.03	0.03	----	0.03
5	----	----	----	0.03	0.03	----	0.03
6	----	----	0.03	0.03	0.03	----	0.03
7	----	----	----	----	----	----	----
8	----	----	----	----	----	----	----
9	----	----	0.04	0.03	0.04	----	0.04
10	----	----	0.04	0.04	0.04	----	0.04
11	----	----	0.04	0.04	0.04	----	0.04
12	----	----	----	0.03	0.03	----	0.03
13	----	----	0.03	0.03	----	----	0.03
14	----	----	----	----	----	----	----
15	----	----	----	----	----	----	----
16	----	----	0.04	0.03	0.03	----	0.04
17	----	----	0.04	0.03	0.03	----	0.04
18	----	----	0.04	0.03	0.03	----	0.04
19	----	----	0.03	0.03	----	----	0.03
20	----	----	0.03	0.03	----	----	0.03
21	----	----	----	----	----	----	----
22	----	----	----	----	----	----	----
23	----	----	0.04	0.03	0.03	----	0.04
24	----	----	0.04	0.03	----	----	0.04
25	----	----	0.03	0.03	0.03	----	0.03
26	----	----	0.03	0.05	0.03	----	0.05
27	----	----	0.03	0.03	0.03	----	0.03
28	----	----	----	----	----	----	----
29	----	----	----	----	----	----	----
30	----	----	0.04	0.03	0.03	----	0.04
31	----	----	----	----	----	----	----

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <b>Yes</b> / No	CT's met everyday? (see back) <b>Yes</b> / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes</b> / No	
All the 4 hour turbidity readings ≤ 1 NTU? <b>Yes</b> / No			
All turbidity readings < IFE <sup>2</sup> triggers? <b>Yes</b> / No <sup>2</sup>			
<b>Notes:</b>	PRINTED NAME: <i>Ryan A. Sherman</i>		
	SIGNATURE: <i>Ryan A. Sherman</i>		DATE: October 1, 2024
	PHONE #: (541) 572-2589		CERT #: 9184

<sup>1</sup> Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.  
<sup>2</sup> IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**MYRTLE POINT, CITY OF ID #: OR4100551 WTP:- WTP-A Month/Year: September 2024** Required Log Inactivation: .5

Date / Time	Min. Cl <sub>2</sub> Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	----	----	----	----	----	----	----	----
2 / 11 AM	0.7	105	74	19.4	8.4	16	Yes	1200
3 / 11 AM	0.7	105	75	19.4	8.5	17	Yes	1200
4 / 11 AM	0.7	105	78	19.4	8.5	17	Yes	1200
5 / 11 AM	0.7	105	72	19.4	8.7	18	Yes	1200
6 / 11 AM	0.7	105	76	19.4	8.6	18	Yes	1200
7 / 11 AM	----	----	----	----	----	----	----	----
8 / 11 AM	----	----	----	----	----	----	----	----
9 / 11 AM	0.5	105	53	20.6	8.5	15	Yes	1200
10 / 11 AM	0.6	105	62	20.6	8.4	15	Yes	1200
11 / 11 AM	0.7	105	70	20.6	8.4	15	Yes	1200
12 / 11 AM	0.8	105	81	20.6	8.4	16	Yes	1200
13 / 11 AM	0.8	105	85	20.6	8.5	16	Yes	1200
14 / 11 AM	----	----	----	----	----	----	----	----
15 / 11 AM	----	----	----	----	----	----	----	----
16 / 11 AM	0.7	105	71	20.0	8.5	16	Yes	1200
17 / 11 AM	0.8	105	80	20.0	8.6	17	Yes	1200
18 / 11 AM	0.9	105	91	20.0	8.5	17	Yes	1200
19 / 11 AM	0.9	105	98	20.0	8.6	17	Yes	1200
20 / 11 AM	1.0	105	106	20.0	8.5	17	Yes	1200
21 / 11 AM	----	----	----	----	----	----	----	----
22 / 11 AM	----	----	----	----	----	----	----	----
23 / 11 AM	0.8	105	80	18.3	8.5	18	Yes	1200
24 / 11 AM	0.8	105	86	18.3	8.5	19	Yes	1200
25 / 11 AM	0.9	105	92	18.3	8.4	18	Yes	1200
26 / 11 AM	1.0	105	104	18.3	8.4	18	Yes	1200
27 / 11 AM	1.0	105	109	18.3	8.4	18	Yes	1200
28 / 11 AM	----	----	----	----	----	----	----	----
29 / 11 AM	----	----	----	----	----	----	----	----
30 / 11 AM	1.2	105	121	17.8	8.2	18	Yes	1200
31 / 11 AM	----	----	----	----	----	----	----	----

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

*Revised February 2012*