

## OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

**System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP-:WTP-A Month/Year: October 2024**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	----	----	0.03	0.03	0.03	----	0.03
2	----	----	0.03	0.03	0.03	----	0.03
3	----	----	0.03	0.03	----	----	0.03
4	----	----	0.03	0.03	----	----	0.03
5	----	----	----	----	----	----	----
6	----	----	----	----	----	----	----
7	----	----	0.03	0.03	0.03	----	0.03
8	----	----	0.03	0.03	0.03	----	0.03
9	----	----	0.04	0.03	0.03	----	0.04
10	----	----	0.03	0.03	0.03	----	0.03
11	----	----	0.03	0.03	----	----	0.03
12	----	----	----	----	----	----	----
13	----	----	----	----	----	----	----
14	----	----	0.04	0.04	0.04	----	0.04
15	----	----	0.04	0.04	0.04	----	0.04
16	----	----	----	0.04	0.04	----	0.04
17	----	----	0.04	0.04	0.05	----	0.05
18	----	----	0.05	0.04	0.05	----	0.05
19	----	----	----	----	----	----	----
20	----	----	----	----	----	----	----
21	----	----	0.05	0.04	0.05	----	0.05
22	----	----	----	0.03	0.03	----	0.03
23	----	----	0.04	0.03	0.03	----	0.04
24	----	----	0.04	0.03	0.03	----	0.04
25	----	----	0.04	0.04	----	----	0.04
26	----	----	----	----	----	----	----
27	----	----	----	----	----	----	----
28	----	----	0.03	0.04	0.04	----	0.04
29	----	----	0.04	0.04	0.03	----	0.04
30	----	----	0.03	0.03	0.03	----	0.03
31	----	----	0.03	0.03	----	----	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <span style="float: right;">Yes / No</span>	CT's met everyday? (see back) Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes / No
All the 4 hour turbidity readings ≤ 1 NTU? <span style="float: right;">Yes / No</span>		
All turbidity readings < IFE <sup>2</sup> triggers? <span style="float: right;">Yes / No<sup>2</sup></span>		
<b>Notes:</b>	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: November 1, 2024
	PHONE #: ( 541 ) 572-2589	
	CERT #: <i>9184</i>	

<sup>1</sup> Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: October 2024** Required Log Inactivation: .5

Date / Time	Min. Cl <sub>2</sub> Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.2	105	129	18.3	8.2	17	Yes	1200
2 / 11 AM	0.8	105	81	17.8	8.5	19	Yes	1200
3 / 11 AM	1.1	105	120	15.6	8.2	21	Yes	1200
4 / 11 AM	1.3	105	134	17.2	8.5	21	Yes	1200
5 / 11 AM	----	----	----	----	----	----	----	----
6 / 11 AM	----	----	----	----	----	----	----	----
7 / 11 AM	1.1	105	113	17.8	8.3	18	Yes	1200
8 / 11 AM	1.2	105	122	17.8	8.4	19	Yes	1200
9 / 11 AM	0.8	105	81	17.8	8.4	19	Yes	1200
10 / 11 AM	0.8	105	84	17.2	8.4	20	Yes	1200
11 / 11 AM	0.8	105	88	15.6	8.3	21	Yes	1200
12 / 11 AM	----	----	----	----	----	----	----	----
13 / 11 AM	----	----	----	----	----	----	----	----
14 / 11 AM	0.9	105	96	15.0	8.2	21	Yes	1200
15 / 11 AM	1.1	105	111	15.0	8.3	22	Yes	1200
16 / 11 AM	0.8	105	86	15.0	8.1	20	Yes	1200
17 / 11 AM	1.0	105	102	15.6	8.2	20	Yes	1200
18 / 11 AM	1.0	105	108	16.1	8.2	20	Yes	1200
19 / 11 AM	----	----	----	----	----	----	----	----
20 / 11 AM	----	----	----	----	----	----	----	----
21 / 11 AM	0.9	105	95	16.7	7.9	17	Yes	1200
22 / 11 AM	0.9	105	99	16.1	8.0	18	Yes	1200
23 / 11 AM	1.0	105	102	16.1	8.0	19	Yes	1200
24 / 11 AM	1.0	105	109	15.6	8.2	20	Yes	1200
25 / 11 AM	1.2	105	122	15.6	8.2	21	Yes	1200
26 / 11 AM	----	----	----	----	----	----	----	----
27 / 11 AM	----	----	----	----	----	----	----	----
28 / 11 AM	0.6	105	63	16.7	8.0	17	Yes	1200
29 / 11 AM	0.8	105	88	15.0	8.0	19	Yes	1200
30 / 11 AM	0.9	105	93	14.4	8.1	21	Yes	1200
31 / 11 AM	1.0	105	101	14.4	8.2	22	Yes	1200

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012