

## OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

**System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: November 2024**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	---	---	0.04	0.05	---	---	0.05
2	---	---	---	---	---	---	---
3	---	---	---	---	---	---	---
4	---	---	---	0.03	0.03	---	0.03
5	---	---	0.04	0.04	0.03	---	0.04
6	---	---	0.04	0.04	0.04	---	0.04
7	---	---	0.04	0.04	---	---	0.04
8	---	---	0.04	0.04	---	---	0.04
9	---	---	---	---	---	---	---
10	---	---	---	---	---	---	---
11	---	---	---	0.05	0.05	---	0.05
12	---	---	0.06	0.05	0.05	---	0.06
13	---	---	0.06	0.05	0.05	---	0.06
14	---	---	---	0.07	0.08	---	0.08
15	---	---	---	0.12	0.03	---	0.12
16	---	---	---	---	---	---	---
17	---	---	---	---	---	---	---
18	---	---	0.03	0.03	0.03	0.03	0.03
19	---	---	0.03	---	---	---	0.03
20	---	---	0.03	0.03	0.03	---	0.03
21	---	---	0.03	0.03	0.03	---	0.03
22	---	---	0.03	0.03	0.03	---	0.03
23	---	---	---	---	---	---	---
24	---	---	---	---	---	---	---
25	---	---	0.03	0.03	0.03	---	0.03
26	---	---	---	0.03	0.03	---	0.03
27	---	---	0.03	0.03	0.03	---	0.03
28	---	---	0.03	0.03	0.03	---	0.03
29	---	---	0.04	0.03	0.03	---	0.04
30	---	---	---	---	---	---	---
31	---	---	---	---	---	---	---

<b>Conventional or Direct Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
<b>Notes:</b>	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: December 2, 2024
	PHONE #: (541) 572-2589	
	CERT #: 9184	

<sup>1</sup> Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

**MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: November 2024** Required Log Inactivation: .5

Date / Time	Min. Cl <sub>2</sub> Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	<b>C x T</b>	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	105	118	13.9	8.3	24	Yes	850
2 / 11 AM	----	----	----	----	----	----	----	----
3 / 11 AM	----	----	----	----	----	----	----	----
4 / 11 AM	0.7	105	74	12.2	8.5	27	Yes	850
5 / 11 AM	0.8	105	80	12.2	8.4	27	Yes	850
6 / 11 AM	0.8	105	88	11.7	8.4	28	Yes	850
7 / 11 AM	0.9	105	99	11.1	8.5	30	Yes	850
8 / 11 AM	1.3	105	141	12.2	8.0	25	Yes	850
9 / 11 AM	----	----	----	----	----	----	----	----
10 / 11 AM	----	----	----	----	----	----	----	----
11 / 11 AM	1.2	105	123	11.7	8.2	27	Yes	850
12 / 11 AM	1.2	105	125	11.1	8.3	29	Yes	850
13 / 11 AM	1.3	105	131	12.8	8.1	24	Yes	850
14 / 11 AM	1.2	105	122	12.2	8.0	24	Yes	850
15 / 11 AM	1.1	105	117	11.1	8.0	25	Yes	850
16 / 11 AM	----	----	----	----	----	----	----	----
17 / 11 AM	----	----	----	----	----	----	----	----
18 / 11 AM	1.0	105	103	10.0	8.2	29	Yes	850
19 / 11 AM	1.1	105	111	10.0	8.2	30	Yes	850
20 / 11 AM	1.2	105	124	10.0	8.2	30	Yes	850
21 / 11 AM	1.0	105	109	9.4	7.9	27	Yes	850
22 / 11 AM	1.2	105	127	9.4	8.0	29	Yes	850
23 / 11 AM	----	----	----	----	----	----	----	----
24 / 11 AM	----	----	----	----	----	----	----	----
25 / 11 AM	0.8	105	85	8.9	8.0	29	Yes	850
26 / 11 AM	1.1	105	112	9.4	7.9	28	Yes	850
27 / 11 AM	1.1	105	110	10.0	8.6	34	Yes	850
28 / 11 AM	1.2	105	122	10.0	8.6	34	Yes	850
29 / 11 AM	1.1	105	116	10.6	8.6	33	Yes	850
30 / 11 AM	----	----	----	----	----	----	----	----
31 / 11 AM	----	----	----	----	----	----	----	----

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

*Revised February 2012*