

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 **WTP:-**WTP-A **Month/Year:** February 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-----	-----	-----	-----	-----	-----	-----
2	-----	-----	-----	-----	-----	-----	-----
3	-----	-----	0.03	0.03	0.03	-----	0.03
4	-----	-----	0.03	0.03	0.03	-----	0.03
5	-----	-----	0.03	0.03	0.03	-----	0.03
6	-----	-----	0.03	0.03	0.03	-----	0.03
7	-----	-----	0.03	0.03	-----	-----	0.03
8	-----	-----	-----	-----	-----	-----	-----
9	-----	-----	-----	-----	-----	-----	-----
10	-----	-----	0.03	0.03	0.03	-----	0.03
11	-----	-----	-----	0.03	0.03	-----	0.03
12	-----	-----	0.03	0.03	0.03	-----	0.03
13	-----	-----	0.03	0.03	0.03	-----	0.03
14	-----	-----	0.03	0.03	-----	-----	0.03
15	-----	-----	-----	-----	-----	-----	-----
16	-----	-----	-----	-----	-----	-----	-----
17	-----	-----	0.03	0.03	0.03	-----	0.03
18	-----	-----	0.04	0.03	0.03	-----	0.04
19	-----	-----	0.03	0.03	0.03	-----	0.03
20	-----	-----	0.03	0.03	0.03	-----	0.03
21	-----	-----	0.03	0.03	-----	-----	0.03
22	-----	-----	-----	-----	-----	-----	-----
23	-----	-----	-----	-----	-----	-----	-----
24	-----	-----	0.03	-----	-----	-----	0.03
25	-----	-----	-----	0.04	0.03	-----	0.04
26	-----	-----	0.03	0.03	0.03	-----	0.03
27	-----	-----	0.03	0.03	-----	-----	0.03
28	-----	-----	0.04	0.03	0.03	-----	0.04
29	-----	-----	-----	-----	-----	-----	-----
30	-----	-----	-----	-----	-----	-----	-----
31	-----	-----	-----	-----	-----	-----	-----

Conventional or Direct Filtration 95% of the 4 hour turbidity readings ≤ 0.3 NTU? <u>Yes</u> / No All the 4 hour turbidity readings ≤ 1 NTU? <u>Yes</u> / No All turbidity readings < IFE ² triggers? <u>Yes</u> / No ²	Monthly Summary (Answer Yes or No) <table style="width: 100%;"> <tr> <td style="width: 33%;"> CT's met everyday? (see back) <u>Yes</u> / No </td> <td style="width: 67%;"> All Cl₂ residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No </td> </tr> </table>		CT's met everyday? (see back) <u>Yes</u> / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No				
CT's met everyday? (see back) <u>Yes</u> / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No							
Notes:	<table style="width: 100%;"> <tr> <td colspan="2">PRINTED NAME: <u>Ryan A. Sherman</u></td> </tr> <tr> <td>SIGNATURE: <u>Ryan A. Sherman</u></td> <td>DATE: March 3, 2025</td> </tr> <tr> <td>PHONE #: (541) 572-2589</td> <td>CERT #: <u>9184</u></td> </tr> </table>		PRINTED NAME: <u>Ryan A. Sherman</u>		SIGNATURE: <u>Ryan A. Sherman</u>	DATE: March 3, 2025	PHONE #: (541) 572-2589	CERT #: <u>9184</u>
PRINTED NAME: <u>Ryan A. Sherman</u>								
SIGNATURE: <u>Ryan A. Sherman</u>	DATE: March 3, 2025							
PHONE #: (541) 572-2589	CERT #: <u>9184</u>							

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: February 2025								Required Log Inactivation: .5
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	----	----	----	----	----	----	----	----
2 / 11 AM	----	----	----	----	----	----	----	----
3 / 11 AM	1.0	105	105	3.3	8.6	54	Yes	850
4 / 11 AM	1.1	105	111	3.9	8.7	55	Yes	850
5 / 11 AM	0.9	105	95	6.1	8.6	43	Yes	850
6 / 11 AM	0.7	105	74	7.2	8.5	38	Yes	850
7 / 11 AM	0.9	105	95	7.2	8.3	37	Yes	850
8 / 11 AM	----	----	----	----	----	----	----	----
9 / 11 AM	----	----	----	----	----	----	----	----
10 / 11 AM	0.9	105	98	6.7	8.3	39	Yes	850
11 / 11 AM	1.0	105	102	6.1	8.4	41	Yes	850
12 / 11 AM	1.0	105	106	6.1	8.3	40	Yes	850
13 / 11 AM	1.1	105	110	6.1	8.4	42	Yes	850
14 / 11 AM	1.2	105	127	6.1	8.8	49	Yes	850
15 / 11 AM	----	----	----	----	----	----	----	----
16 / 11 AM	----	----	----	----	----	----	----	----
17 / 11 AM	1.1	105	110	7.8	8.4	37	Yes	850
18 / 11 AM	1.1	105	116	7.8	8.5	39	Yes	850
19 / 11 AM	1.1	105	120	7.8	8.4	38	Yes	850
20 / 11 AM	1.1	105	114	7.8	8.8	42	Yes	850
21 / 11 AM	1.1	105	120	7.8	8.8	44	Yes	850
22 / 11 AM	----	----	----	----	----	----	----	----
23 / 11 AM	----	----	----	----	----	----	----	----
24 / 11 AM	1.0	105	108	12.8	8.3	26	Yes	850
25 / 11 AM	1.1	105	110	11.7	8.4	28	Yes	850
26 / 11 AM	1.1	105	114	10.0	8.3	31	Yes	850
27 / 11 AM	1.2	105	122	10.0	8.2	30	Yes	850
28 / 11 AM	1.2	105	126	10.0	8.1	29	Yes	850
29 / 11 AM	----	----	----	----	----	----	----	----
30 / 11 AM	----	----	----	----	----	----	----	----
31 / 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.