

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: May 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	0.02	0.02	----	----	0.02
2	----	----	0.02	0.02	----	----	0.02
3	----	----	----	----	----	----	----
4	----	----	----	----	----	----	----
5	----	----	----	0.02	0.02	----	0.02
6	----	----	0.03	0.03	0.02	----	0.03
7	----	----	0.03	0.03	0.03	----	0.03
8	----	----	0.03	0.03	----	----	0.03
9	----	----	0.04	----	----	----	0.04
10	----	----	----	----	----	----	----
11	----	----	----	----	----	----	----
12	----	----	0.03	0.02	0.01	----	0.03
13	----	----	0.01	0.01	0.01	----	0.01
14	----	----	0.01	0.01	0.01	----	0.01
15	----	----	0.01	0.01	----	----	0.01
16	----	----	0.01	0.06	----	----	0.06
17	----	----	----	----	----	----	----
18	----	----	----	----	----	----	----
19	----	----	----	0.06	0.03	----	0.06
20	----	----	0.02	0.02	0.02	----	0.02
21	----	----	0.02	0.06	0.02	----	0.06
22	----	----	0.02	0.02	0.02	----	0.02
23	----	----	0.02	0.02	----	----	0.02
24	----	----	----	----	----	----	----
25	----	----	----	----	----	----	----
26	----	----	----	0.02	0.02	----	0.02
27	----	----	0.02	0.02	0.02	----	0.02
28	----	----	----	----	----	----	----
29	----	----	0.03	0.02	0.02	0.02	0.03
30	----	----	0.02	0.02	0.02	----	0.02
31	----	----	----	----	----	----	----

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes / No All the 4 hour turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < IFE ² triggers? Yes / No ²	CT's met everyday? (see back) Yes / No All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No		
Notes: 		PRINTED NAME: <u>Ryan A. Sherman</u> SIGNATURE: <u>Ryan A. Sherman</u> DATE: June 3, 2025 PHONE #: (541) 572-2589 CERT #: <u>9184</u>	

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: May 2025

**Required Log
Inactivation: .5**

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	0.9	105	95	15.6	8.2	21	Yes	850
2 / 11 AM	1.0	105	103	13.9	8.4	25	Yes	850
3 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
4 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
5 / 11 AM	1.2	105	128	16.1	8.4	22	Yes	850
6 / 11 AM	1.3	105	133	15.0	8.6	26	Yes	850
7 / 11 AM	1.3	105	137	15.6	8.6	25	Yes	850
8 / 11 AM	1.2	105	128	15.6	8.4	23	Yes	850
9 / 11 AM	1.5	105	161	16.1	8.9	27	Yes	850
10 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
11 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
12 / 11 AM	1.1	105	116	15.6	8.4	23	Yes	850
13 / 11 AM	1.2	105	129	15.0	8.5	25	Yes	850
14 / 11 AM	1.3	105	138	15.0	8.8	28	Yes	850
15 / 11 AM	1.4	105	145	15.6	8.9	27	Yes	850
16 / 11 AM	1.5	105	161	15.6	8.9	28	Yes	850
17 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
18 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
19 / 11 AM	1.2	105	130	15.0	8.8	27	Yes	850
20 / 11 AM	1.3	105	135	15.0	8.7	26	Yes	850
21 / 11 AM	1.3	105	139	15.0	8.9	29	Yes	850
22 / 11 AM	1.3	105	137	15.0	8.6	25	Yes	850
23 / 11 AM	1.3	105	141	15.6	8.3	22	Yes	850
24 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
25 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
26 / 11 AM	1.3	105	141	15.0	8.3	23	Yes	850
27 / 11 AM	1.3	105	139	16.1	8.4	22	Yes	850
28 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----
29 / 11 AM	1.1	105	117	16.1	8.4	22	Yes	850
30 / 11 AM	1.3	105	132	17.2	8.8	24	Yes	850
31 / 11 AM	-----	-----	-----	-----	-----	-----	-----	-----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012