

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: June 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-----	-----	-----	-----	-----	-----	-----
2	-----	-----	0.02	0.02	-----	-----	0.02
3	-----	-----	-----	0.02	0.02	-----	0.02
4	-----	-----	0.02	0.02	0.02	-----	0.02
5	-----	-----	0.02	0.02	0.02	-----	0.02
6	-----	-----	0.02	0.02	0.03	-----	0.03
7	-----	-----	-----	-----	-----	-----	-----
8	-----	-----	-----	-----	-----	-----	-----
9	-----	-----	0.04	0.04	0.03	0.03	0.04
10	-----	-----	0.03	0.03	0.03	-----	0.03
11	-----	-----	0.03	0.02	0.02	-----	0.03
12	-----	-----	0.02	0.02	0.04	-----	0.04
13	-----	-----	-----	0.02	0.02	-----	0.02
14	-----	-----	-----	-----	-----	-----	-----
15	-----	-----	-----	-----	-----	-----	-----
16	-----	-----	0.02	0.02	0.02	-----	0.02
17	-----	-----	0.02	0.03	0.05	-----	0.05
18	-----	-----	0.02	0.02	0.02	-----	0.02
19	-----	-----	0.02	0.02	0.02	-----	0.02
20	-----	-----	0.02	0.02	0.02	-----	0.02
21	-----	-----	-----	-----	-----	-----	-----
22	-----	-----	-----	-----	-----	-----	-----
23	-----	-----	-----	0.11	0.02	-----	0.11
24	-----	-----	0.02	0.02	0.02	-----	0.02
25	-----	-----	0.03	0.02	0.02	-----	0.03
26	-----	-----	0.02	0.02	-----	-----	0.02
27	-----	-----	0.02	0.02	-----	-----	0.02
28	-----	-----	-----	-----	-----	-----	-----
29	-----	-----	-----	-----	-----	-----	-----
30	-----	-----	-----	0.03	0.03	-----	0.03
31	-----	-----	-----	-----	-----	-----	-----

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings $\leq$ 0.3 NTU? <u>Yes</u> / No	CT's met everyday? (see back) <u>Yes</u> / No	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l? <u>Yes</u> / No	
All the 4 hour turbidity readings $\leq$ 1 NTU? <u>Yes</u> / No			
All turbidity readings < IFE ² triggers? <u>Yes</u> / No ²			
Notes:		PRINTED NAME: <u>Ryan A. Sherman</u>	
		SIGNATURE: <u>Ryan A. Sherman</u>	DATE: July 1, 2025
		PHONE #: (541) 572-2589	CERT #: <u>9484</u>

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP:- WTP-A Month/Year: June 2025

**Required Log
Inactivation: .5**

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	----	----	----	----	----	----	----	----
2 / 11 AM	0.8	105	79	17.2	8.7	21	Yes	1200
3 / 11 AM	1.3	105	131	17.2	8.7	23	Yes	1200
4 / 11 AM	1.2	105	124	18.3	8.9	22	Yes	1200
5 / 11 AM	1.2	105	130	18.9	8.8	21	Yes	1200
6 / 11 AM	1.2	105	121	19.4	8.8	20	Yes	1200
7 / 11 AM	----	----	----	----	----	----	----	----
8 / 11 AM	----	----	----	----	----	----	----	----
9 / 11 AM	1.1	105	116	20.0	8.7	18	Yes	1200
10 / 11 AM	1.1	105	116	20.6	8.7	18	Yes	1200
11 / 11 AM	1.1	105	111	20.0	8.6	18	Yes	1200
12 / 11 AM	1.0	105	101	20.6	8.7	17	Yes	1200
13 / 11 AM	1.0	105	107	20.0	8.7	18	Yes	1200
14 / 11 AM	----	----	----	----	----	----	----	----
15 / 11 AM	----	----	----	----	----	----	----	----
16 / 11 AM	1.0	105	107	19.4	8.7	19	Yes	1200
17 / 11 AM	1.1	105	113	19.4	8.7	19	Yes	1200
18 / 11 AM	0.9	105	95	18.9	7.7	13	Yes	1200
19 / 11 AM	1.1	105	110	20.6	7.9	13	Yes	1200
20 / 11 AM	1.2	105	129	19.4	8.0	15	Yes	1200
21 / 11 AM	----	----	----	----	----	----	----	----
22 / 11 AM	----	----	----	----	----	----	----	----
23 / 11 AM	1.1	105	114	18.3	8.1	17	Yes	1200
24 / 11 AM	1.2	105	123	18.3	8.2	17	Yes	1200
25 / 11 AM	1.2	105	129	17.8	8.2	18	Yes	1200
26 / 11 AM	1.1	105	119	18.9	8.4	18	Yes	1200
27 / 11 AM	1.2	105	121	18.9	8.4	18	Yes	1200
28 / 11 AM	----	----	----	----	----	----	----	----
29 / 11 AM	----	----	----	----	----	----	----	----
30 / 11 AM	0.9	105	90	17.8	8.2	18	Yes	1200
31 / 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012