

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: August 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	0.02	0.02	0.02	----	0.02
2	----	----	----	----	----	----	----
3	----	----	----	----	----	----	----
4	----	----	0.02	0.02	0.02	----	0.02
5	----	----	0.02	0.02	0.02	----	0.02
6	----	----	0.02	0.02	0.02	----	0.02
7	----	----	0.03	0.03	0.02	0.02	0.03
8	----	----	0.03	0.02	0.02	----	0.03
9	----	----	----	----	----	----	----
10	----	----	----	----	----	----	----
11	----	----	----	0.03	0.02	----	0.03
12	----	----	0.02	0.02	0.03	0.03	0.03
13	----	----	0.03	0.06	0.07	----	0.07
14	----	----	----	0.03	0.03	0.03	0.03
15	----	----	0.03	0.03	----	----	0.03
16	----	----	----	----	----	----	----
17	----	----	----	----	----	----	----
18	----	----	0.04	0.03	0.02	----	0.04
19	----	----	0.02	0.03	0.03	----	0.03
20	----	----	0.03	0.03	0.03	0.04	0.04
21	----	----	0.03	0.03	0.06	----	0.06
22	----	----	0.03	0.03	0.03	----	0.03
23	----	----	----	----	----	----	----
24	----	----	----	----	----	----	----
25	----	----	0.03	0.03	0.03	0.03	0.03
26	----	----	0.03	0.03	0.02	0.02	0.03
27	----	----	0.03	0.02	0.02	0.02	0.03
28	----	----	0.03	0.02	0.02	0.02	0.03
29	----	----	0.03	0.02	0.02	0.02	0.03
30	----	----	----	----	----	----	----
31	----	----	0.03	0.02	0.02	0.02	0.03

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of the 4 hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / ☐ No
 All the 4 hour turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No
 All turbidity readings < IFE² triggers? ☒ Yes / ☐ No²

CT's met everyday?
 (see back)
☒ Yes / ☐ No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l?
☒ Yes / ☐ No

Notes:

PRINTED NAME: *Ryan A. Sherman*

SIGNATURE: *Ryan A. Sherman*

DATE: September 1, 2025

PHONE #: (541) 572-2589

CERT #: *9184*

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP:- WTP-A Month/Year: August 2025

**Required Log
Inactivation: .5**

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.2	105	127	22.2	8.5	15	Yes	1200
2 / 11 AM	----	----	----	----	----	----	----	----
3 / 11 AM	----	----	----	----	----	----	----	----
4 / 11 AM	0.8	105	86	22.2	8.6	15	Yes	1200
5 / 11 AM	1.1	105	113	21.7	8.5	16	Yes	1200
6 / 11 AM	1.2	105	122	21.7	8.7	16	Yes	1200
7 / 11 AM	1.1	105	113	21.1	8.6	16	Yes	1200
8 / 11 AM	1.1	105	119	21.1	8.5	16	Yes	1200
9 / 11 AM	----	----	----	----	----	----	----	----
10 / 11 AM	----	----	----	----	----	----	----	----
11 / 11 AM	0.8	105	85	22.2	8.4	14	Yes	1200
12 / 11 AM	0.9	105	98	22.8	8.7	15	Yes	1200
13 / 11 AM	1.0	105	104	22.8	8.8	16	Yes	1200
14 / 11 AM	1.1	105	110	23.3	8.8	16	Yes	1200
15 / 11 AM	1.0	105	107	23.3	9.0	16	Yes	1200
16 / 11 AM	----	----	----	----	----	----	----	----
17 / 11 AM	----	----	----	----	----	----	----	----
18 / 11 AM	0.6	105	59	22.8	8.5	13	Yes	1200
19 / 11 AM	1.0	105	103	21.7	8.6	16	Yes	1200
20 / 11 AM	1.1	105	111	22.2	8.6	15	Yes	1200
21 / 11 AM	1.1	105	119	22.2	8.6	15	Yes	1200
22 / 11 AM	1.2	105	124	22.2	8.5	15	Yes	1200
23 / 11 AM	----	----	----	----	----	----	----	----
24 / 11 AM	----	----	----	----	----	----	----	----
25 / 11 AM	0.8	105	86	22.2	8.6	15	Yes	1200
26 / 11 AM	1.1	105	113	21.7	8.6	16	Yes	1200
27 / 11 AM	0.8	105	88	22.2	8.8	16	Yes	1200
28 / 11 AM	1.0	105	103	22.2	8.7	16	Yes	1200
29 / 11 AM	1.2	105	127	22.2	8.6	16	Yes	1200
30 / 11 AM	----	----	----	----	----	----	----	----
31 / 11 AM	0.8	105	83	21.7	8.6	15	Yes	1200

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012