

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: MYRTLE POINT, CITY OF ID:OR4100551 WTP:-WTP-A Month/Year: Sept 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-----	-----	0.03	0.02	0.02	-----	0.03
2	-----	-----	0.03	0.02	0.02	-----	0.03
3	-----	-----	0.03	0.03	-----	-----	0.03
4	-----	-----	-----	-----	0.03	-----	0.03
5	-----	-----	0.03	0.03	0.02	-----	0.03
6	-----	-----	-----	-----	-----	-----	-----
7	-----	-----	-----	-----	-----	-----	-----
8	-----	-----	0.03	0.02	0.02	-----	0.03
9	-----	-----	0.02	0.04	0.04	-----	0.04
10	-----	-----	-----	-----	-----	-----	-----
11	-----	-----	0.03	0.02	0.03	0.03	0.03
12	-----	-----	0.03	0.03	0.04	-----	0.04
13	-----	-----	-----	-----	-----	-----	-----
14	-----	-----	-----	-----	-----	-----	-----
15	-----	-----	-----	0.03	0.03	-----	0.03
16	-----	-----	0.03	0.03	0.03	-----	0.03
17	-----	-----	0.03	0.03	0.03	-----	0.03
18	-----	-----	0.03	0.03	0.03	-----	0.03
19	-----	-----	0.03	0.04	0.05	-----	0.05
20	-----	-----	-----	-----	-----	-----	-----
21	-----	-----	-----	-----	-----	-----	-----
22	-----	-----	-----	0.03	0.03	-----	0.03
23	-----	-----	-----	0.03	0.03	-----	0.03
24	-----	-----	-----	0.05	0.03	-----	0.05
25	-----	-----	0.03	0.03	0.03	-----	0.03
26	-----	-----	0.03	0.03	0.03	-----	0.03
27	-----	-----	-----	-----	-----	-----	-----
28	-----	-----	-----	-----	-----	-----	-----
29	-----	-----	-----	0.03	0.03	-----	0.03
30	-----	-----	-----	0.03	0.04	-----	0.04
31	-----	-----	-----	-----	-----	-----	-----

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes / No All the 4 hour turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < IFE ² triggers? Yes / No ²		CT's met everyday? (see back) Yes / No	
		All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No	
Notes: 		PRINTED NAME: Ryan A. Sherman	
		SIGNATURE: <i>Ryan A. Sherman</i>	
		DATE: October 1, 2025	
		PHONE # : (541) 572-2589	
		CERT # : 9184	

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not

OHA - Drinking Water Program - Surface Water Quality Data Form

MYRTLE POINT, CITY OF ID #: OR4100551 WTP-: WTP-A Month/Year: Sept 2025

**Required Log
Inactivation: .5**

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	105	120	21.7	8.5	15	Yes	1200
2 / 11 AM	0.9	105	95	21.7	8.7	16	Yes	1200
3 / 11 AM	1.1	105	118	21.1	8.5	16	Yes	1200
4 / 11 AM	1.1	105	119	21.1	8.5	16	Yes	1200
5 / 11 AM	1.1	105	112	21.1	8.6	16	Yes	1200
6 / 11 AM	----	----	----	----	----	----	----	----
7 / 11 AM	----	----	----	----	----	----	----	----
8 / 11 AM	0.6	105	63	21.7	8.5	14	Yes	1200
9 / 11 AM	1.0	105	103	21.7	8.5	15	Yes	1200
10 / 11 AM	----	----	----	----	----	----	----	----
11 / 11 AM	0.6	105	63	21.1	8.5	15	Yes	1200
12 / 11 AM	1.0	105	106	21.1	8.6	16	Yes	1200
13 / 11 AM	----	----	----	----	----	----	----	----
14 / 11 AM	----	----	----	----	----	----	----	----
15 / 11 AM	1.0	105	108	19.4	8.5	18	Yes	1200
16 / 11 AM	0.9	105	91	20.0	8.3	16	Yes	1200
17 / 11 AM	1.1	105	112	20.0	8.3	16	Yes	1200
18 / 11 AM	1.2	105	121	19.4	8.3	17	Yes	1200
19 / 11 AM	1.3	105	134	20.0	8.6	18	Yes	1200
20 / 11 AM	----	----	----	----	----	----	----	----
21 / 11 AM	----	----	----	----	----	----	----	----
22 / 11 AM	1.1	105	120	19.4	8.8	20	Yes	1200
23 / 11 AM	1.2	105	124	18.9	8.8	21	Yes	1200
24 / 11 AM	1.2	105	122	19.4	9.0	21	Yes	1200
25 / 11 AM	1.0	105	102	18.9	8.8	20	Yes	1200
26 / 11 AM	1.1	105	110	18.3	8.6	20	Yes	1200
27 / 11 AM	----	----	----	----	----	----	----	----
28 / 11 AM	----	----	----	----	----	----	----	----
29 / 11 AM	0.9	105	90	18.3	8.6	19	Yes	1200
30 / 11 AM	0.9	105	96	17.8	8.6	20	Yes	1200
31 / 11 AM	----	----	----	----	----	----	----	----

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012